



2019 INTEGRATED RESOURCE PLAN

Report
Prepared by GM BluePlan Engineering
March 2020

GLOSSARY OF TERMS AND ACRONYMS

The following table provides a summary of terms and acronyms that are commonly used throughout the report.

Term or Acronym	Definition
AMI	Advanced Metering Infrastructure
AMPs	Asset Management Plans
AO's	Aesthetic Objectives
CCME	Canadian Council of Ministers of the Environment
CEF	Cost Estimation Framework
CSMMW	Canada-wide Strategy for the Management of Municipal Wastewater Effluent
CSO	Combined Sewer Overflows
DFO	Department of Fisheries and Oceans
DSM	Demand Side Management
ECCC	Environment and Climate Change Canada
EPA	Environmental Protection Agency
ERM	Enterprise Risk Management
GIS	Geographic Information System
HC	Health Canada
HHSP	Halifax Harbour Solutions Project
HRM	Halifax Regional Municipality
HRWC	Halifax Regional Water Commission
I/I	Inflow and Infiltration
IRP	Integrated Resource Plan
IT	Information Technology
KPIs	Key Performance Indicators
LID	Low Impact Development
LoWSCA	Regional Centre Local Wastewater Servicing Capacity Analysis
LTCP	Long-Term Capital Plan
LTPF	Long-Term Planning Framework
MAC's	Maximum Acceptable Concentrations
MDD	Maximum Day Demand
MHD	Minimum Hour Demand
MPIR	Ministry of Public Infrastructure Renewal
NSE	Nova Scotia Environment
NSUARB	Nova Scotia Utility and Review Board
PHD	Peak Hour Demand
RDC	Regional Development Charge
RDII	Rainfall Derived Inflow and Infiltration
RWWFP	Regional Wastewater Functional Plan
SSM	Supply Side Management
SSO	Sanitary Sewer Overflows
WQMP	Water Quality Master Plan Update
WRWIP	West Region Wastewater Infrastructure Plan
WSER	Wastewater System Effluent Regulations
WSP	Water Supply Plants
WWMP	Wet Weather Management Program
WWTF	Wastewater Treatment Facilities

TABLE OF CONTENTS

1.0 INTEGRATED RESOURCE PLANNING.....	1
1.1 Overview	1
1.2 Goals and Objectives	3
1.3 Integrated Resource Plan Vision.....	3
1.4 Drivers and Objectives	3
2.0 BACKGROUND AND PLANNING FRAMEWORK.....	5
2.1 Background	5
2.1.1 2012 IRP	5
2.1.2 Relevant Studies, Frameworks and Initiatives	6
2.2 Governance.....	8
2.2.1 Halifax Regional Municipality (HRM).....	8
2.2.2 Halifax Water.....	8
2.2.3 Halifax Water Board of Commissioners Water Board of Commissioners.....	9
2.2.4 Nova Scotia Utility and Review Board.....	9
2.2.5 Nova Scotia Environment.....	9
2.3 Study Area.....	10
2.4 Halifax Water Infrastructure.....	11
2.4.1 Water System.....	11
2.4.2 Wastewater System	11
2.4.3 Stormwater System.....	12
2.5 Planning Data and Population Projections	14
2.6 Design Criteria and Level of Service.....	15
2.6.1 Design Criteria	15
2.6.2 Level of Service.....	15
3.0 INTEGRATED RESOURCE PLAN DRIVERS AND OBJECTIVES	16
3.1 Compliance	16
3.1.1 Water System.....	16
3.1.2 Wastewater System	17
3.1.3 Wastewater Overflows	18
3.1.4 Stormwater System	19
3.1.5 Compliance Objectives	19
3.2 Asset Renewal	20
3.2.1 Asset Data Gaps	20
3.2.2 Asset Renewal Objectives	21
3.3 Growth.....	21
3.3.1 Impact of Growth on the Existing Systems	22
3.3.2 Growth Objectives	22

TABLE OF CONTENTS

3.4 Challenges, Opportunities and Risks	23
3.4.1 Compliance – Water	23
3.4.2 Compliance - Wastewater	23
3.4.3 Compliance - Stormwater	23
3.4.4 Asset Renewal	24
3.4.5 Growth	24
4.0 2019 INTEGRATED RESOURCE PLAN DEVELOPMENT	25
4.1 Foundational Studies	27
4.1.1 Infrastructure Master Plan	28
4.1.2 Compliance Plan	29
4.1.3 Asset Management Plans	31
4.1.4 Corporate Projects	32
4.2 Demand Side Management and Supply Side Management Review	33
4.3 Data / GIS Linkage and Geospatial Integration	34
4.3.1 Geospatial Integration Tool	35
4.4 Expenditure Analysis and Costing Review	36
4.5 Program Integration	38
4.5.1 Decision Making Trees	39
4.5.2 Program Smoothing	41
4.5.3 2019 IRP Update Consultation	42
5.0 LONG-TERM CAPITAL PLAN	43
5.1 2019 IRP Update Capital Program	43
5.1.1 2019 IRP Update 5-Year Expenditure Needs	45
5.1.2 2019 IRP Comparison with the 2012 IRP	46
5.1.3 2019 IRP Update Timeline of Key Projects and Programs	47
5.1.4 2019 IRP Long-Term Capital Plan Tables	50
5.1.5 Integrated Resource Plan Strategy to Achieve Objectives	50
6.0 INTEGRATED RESOURCE PLAN IMPLEMENTATION	53
6.1 Implementation Plan	53
6.1.1 Resource Needs	54
6.1.2 Long-Term Planning Study Schedule	54
6.2 Recommendations	57

FIGURE LIST

Figure 1 – IRP Iterative Planning Process	1
Figure 2 – Relationship of the Integrated Resource Plan to other initiatives	2
Figure 3 – 2012 Integrated Resource Plan	5
Figure 4 – Study Area	10
Figure 5 – Overview of the Existing Water System.....	11
Figure 6 – Overview of the Existing Wastewater System.....	11
Figure 7 – Halifax Water Stormwater Service Boundary.....	12
Figure 8 – Population Growth Allocation	14
Figure 9 – Integrated Resource Plan Drivers.....	16
Figure 10 – 2019 Integrated Resource Plan Development, Process Flow Chart.....	26
Figure 11 – IRP Foundational Studies.....	27
Figure 12 – Infrastructure Master Plan.....	28
Figure 13 – Infrastructure Master Plan Wastewater and Water Components	29
Figure 14 – Compliance Plan	29
Figure 15 – Compliance Plan Wastewater and Water Components	30
Figure 17 – AMPs Wastewater, Stormwater and Water Components.....	31
Figure 16 – Asset Management Plans	31
Figure 19 – Corporate Projects Wastewater, Stormwater and Water Components	32
Figure 18 – Corporate Projects	32
Figure 21 – Geospatial Integration Opportunity Example	35
Figure 20 – Geospatial Integration Tool	35
Figure 22 – Costing Analysis Approach	36
Figure 23 – LTCP: Program Integration Approach	38
Figure 24 – Decision Making Tree (Step 2).....	39
Figure 25 – Sample Decision Making Tree (Step 3)	40
Figure 26 – IRP Capital Program Before and After Smoothing.....	41
Figure 27 – 2019 IRP Recommended Expenditure by Year	43
Figure 28 – 2019 IRP Recommended Expenditure by Driver	43
Figure 29 – 2019 IRP Recommended Expenditure by Year	44
Figure 30 – 2019 IRP Recommended Expenditure by System.....	45
Figure 31 – 2019 IRP Recommended Expenditure (5-Year).....	45
Figure 32 – 2012 Integrated Resource Plan	46
Figure 33 – 2019 Integrated Resource Plan	46
Figure 34 – Water Infrastructure IRP Timeline 2019-2048.....	48
Figure 35 – Wastewater & Stormwater Infrastructure IRP Timeline 2019-2048.....	49
Figure 36 – Projects and Studies that Address the Integrated Resource Plan Objectives	50
Figure 37 – IRP Iterative Planning Process	54
Figure 38 – 5-year Studies Schedule	56

TABLE LIST

Table 1 – IRP Drivers and Objectives	4
Table 2 – Studies, Frameworks and Initiatives	6
Table 3 – Stormwater System Jurisdiction	12
Table 4 – Infrastructure Inventory and Replacement Costs	13
Table 5 – Halifax Regional Municipality Planning Estimates	14
Table 6 – Peaking Factors for Infrastructure Planning	15
Table 7 – Compliance Objectives	19
Table 8 – Asset Renewal Objectives	21
Table 9 – Growth Objectives	22
Table 10 – Data / GIS Linkage Report	34
Table 11 – Costing Analysis Sources	37
Table 12 – 2019 IRP Recommended Expenditure (30-Year)	43
Table 13 – 2019 IRP Recommended Expenditure (5-Year)	45
Table 14 – Integrated Resource Plan Key Actions to Achieve Objectives	51
Table 15 – Historical Approved Capital Budget and Capital Delivery Resources	54
Table 16 – 2019 IRP Recommendations	57

APPENDIX LIST

Appendix A - Relevant Technical Memos

- Appendix A.1 - #1 Background Data and Legislation Review
- Appendix A.2 - #2 DSM/SSM Measures
- Appendix A.3 - #3 Costing and Expenditure Analysis

Appendix B – Study Inputs Executive Summaries

- Appendix B.1 – Infrastructure Master Plan
- Appendix B.2 – Compliance Plan
- Appendix B.3 – Asset Management Plan

Appendix C - IRP Capital Program

1.0 INTEGRATED RESOURCE PLANNING

1.1 OVERVIEW

The Halifax Regional Water Commission (HRWC), also known as Halifax Water, was the first regulated and publicly owned water, wastewater and stormwater utility in Canada. With a long history dating back to the 1940s, Halifax Water is the water, wastewater and stormwater utility servicing residents of the Halifax Regional Municipality (HRM).

As part of its mandate and services, Halifax Water continuously undertakes initiatives and programs to maintain and operate its systems while striving to provide world class service to its customers and environment. These initiatives and programs require integration into a single capital program that identifies the long-term resource needs and financial expenditures.

The long-term program is consolidated into a comprehensive document: The Integrated Resource Plan (IRP) for Halifax Water. As part of the IRP approach, it is intended to complete IRP updates at regular intervals to ensure the consolidated long-term program remains current. Halifax Water retained GM BluePlan Engineering Limited (GM BluePlan) to complete the IRP Update. This IRP update is a critical project that brings together projects, initiatives and programs from separate studies, into a singular integrated capital plan. This study applies the considerations of compliance, asset renewal and growth, to ensure the integrated recommendations achieve the desired service delivery goals, as well as identify any additional gaps and programs required in the long-term plan.

The IRP update is a key component of Halifax Water's iterative planning process as shown in **Figure 1**. The process was initiated in 2012 with the preparation of the first IRP. The 2012 IRP highlighted existing data gaps, outlined assumptions made in its preparation and recommended next steps, kick starting a cycle of continuous improvement that has fed into the preparation of the foundation documents: **Infrastructure Master Plan, Compliance Plan and Asset Management Plans, and ultimately the 2019 IRP Update**. This iterative planning approach will ensure an ever-stronger base to prepare the next iteration of plans and programs and improve confidence in recommendations and project delivery.




Figure 1 – IRP Iterative Planning Process

Since the 2012 IRP, Halifax Water has improved its understanding of the existing infrastructure systems and developed supporting studies and frameworks. Elements such as increased wastewater flow monitoring data collection and analysis, development / update of comprehensive and calibrated water and wastewater hydraulic models and improved understanding of existing assets condition, has vastly supported the preparation of the servicing strategies in the 2019 IRP's foundational documents.

The results of these strategies are then transformed into capital and implementation plans that feed into Halifax Water capital budgets, regional development charges and rate structure. The process repeats itself in a typical 5-year cycle with the development of the Integrated Resource Plan Update which provides a path for the next 5 years.

The 2019 IRP Update is built on the foundation of the 2012 IRP and provides Halifax Water with the required programs and resources for a 30-year period covering each of the three drivers: **Compliance, Asset renewal and Growth.** This update will feed directly into Halifax Water's Business Plans, Capital and Operating Budgets and future rate applications. However, the 2019 IRP Update is not intended to provide analysis of capital program impacts on the operating budget, debt, depreciation, rates and affordability as part of the development of the long-term capital program and implementation.

Figure 2 shows graphically how the various key individual studies and plans feed into the Integrated Resource Plan process and output Halifax Water business planning and Regional Development Charge deliverables.




Figure 2 – Relationship of the Integrated Resource Plan to other initiatives

1.2 GOALS AND OBJECTIVES

The 2019 IRP Update is a critical component of Halifax Water's financial and resource planning. The primary goal of the 2019 IRP Update is to combine the outputs from the foundational studies and programs (Infrastructure Master Plan, Compliance Plan, Asset Management Plan) to create one holistic project and study program that will inform Halifax Water activities for the next 5 years and provide a guide for the next 30 years.

In order to achieve this goal, the following key objectives were completed:

- Complete a baseline understanding from previous studies.
- Complete detailed review of Supply Side Management (SSM) and Demand Side Management (DSM) options.
- Coordinate and align needs identified in the Infrastructure Master Plan, Compliance Plan and Asset Management Plans.
- Identify the projects and driver splits that meet the three drivers of Compliance, Asset Renewal and Growth.
- Provide the preliminary preferred long-term capital infrastructure program as an input into financial models.
- Provide recommendations for future initiatives and improvements.
- Create a foundation for ongoing capital budgeting processes.

1.3 INTEGRATED RESOURCE PLAN VISION

The vision for the 2019 IRP is to be an integrated forward-looking document based on the following principles:

- Build on the foundation and structure of the 2012 IRP
- Layer multiple infrastructure inputs and recommendations to establish an integrated long-term capital plan
- Strategic planning for the long-term
- Real steps in the short-term
- Tactical level document
- Integrated capital program and strategy
- Supported collectively

1.4 DRIVERS AND OBJECTIVES

The 2019 IRP Update focuses on three drivers: **Compliance, Asset Renewal and Growth**. In support of the three drivers, fourteen objectives based on Halifax Water's level of service, compliance requirements (existing and future), asset renewal requirements, as well as other important considerations such as adaptation to climate change, system reliability and servicing growth were further identified.

The fourteen objectives were first developed under the 2012 IRP and further reviewed and refined through this update process. The objectives reflect a greater level of granularity and specific criteria related to the current and anticipated compliance requirements for the three infrastructure systems, optimal asset renewal requirements and growth. Many of the 2012 objectives remain valid and have not changed while others required context update or changes to the main driver to better reflect the current and planned Halifax Water planning and delivery program.

The IRP Update does not focus on Enterprise Risk Management (ERM) as a specific objective, however the risk lens is applied through consideration of objectives such as adaptation to climate change and system reliability. The IRP Update commenced prior to Halifax Water implementing a formalized ERM. The outcomes of the ERM will be considered for future updates to the IRP and in the implementation of the IRP capital program.

1.4 DRIVERS AND OBJECTIVES CONTINUED

The 2019 IRP Update objectives are summarized in **Table 1**. Changes between the 2012 and 2019 objectives are highlighted in blue.

Table 1 – IRP Drivers and Objectives

Driver	Infrastructure System	Objective
Compliance	Regulatory	Wastewater 1 Meet current Nova Scotia Environment WWTF Permit to Operate Requirements
		Water 2 Meet or exceed current Nova Scotia Environment WSP Permit to Operate
		Wastewater Stormwater 3 Meet Current Overflow Compliance (Monitor and Report)
		Wastewater 4 Meet or exceed Future WWTF Compliance
		Water 5 Meet or exceed future drinking water compliance
	Level of Service	Wastewater Stormwater 6 Meet future overflow compliance
		Water Wastewater Stormwater 7 Endeavour to provide existing systems that are adequately sized to meet Halifax Water Level of Service
		Stormwater 8 Meet Future Stormwater Quality Compliance
		Water Wastewater Stormwater 9 Ensure planning and sizing of infrastructure considers the impact of climate change
Asset Renewal	Water Wastewater Stormwater 10	Implement optimal level of asset re-investment
	Water Wastewater Stormwater 11	Enhance the reliability, redundancy and security of the water, wastewater and stormwater systems with attention to high risk and critical areas
	Water Wastewater 12	Reduce energy consumption, operating costs and GHG contributions
Growth	Water Wastewater Stormwater 13	Provide regional water, wastewater and stormwater infrastructure needed to support planned growth
	Water Wastewater 14	Manage flow and demand to maximize capacity for growth and minimize the need for new hard infrastructure

Further details on the IRP drivers and objectives are provided in **Section 2.6.1** of this report.

2.0 BACKGROUND AND PLANNING FRAMEWORK

2.1 BACKGROUND

2.1.1 2012 IRP

The Integrated Resource Plan (IRP) was developed in 2012, in collaboration with the Nova Scotia Utility and Review Board (NSUARB), to identify required programs and resources for the next thirty years (2013-2042) covering each of the three drivers: growth, compliance and asset renewal. The IRP served as the first step in an on-going and evolving process of continuous improvement.

The purpose of the IRP was to guide Halifax Water's financial planning by focusing on the following:

- Providing a framework for Halifax Water to evaluate alternative planning scenarios for its water, wastewater and stormwater services
- Help to identify and achieve Halifax Water service goals while considering environmental requirements
- Provide long term direction for Halifax Water and be a platform for assessing investment options
- Serve as a basis under which more detailed, facility or program-specific capital investment analyses can take place
- Identify and plan for the management of risks
- Provide the board with information to make fully informed decisions about proposed future capital investments, revenue, requirements and rates

Preparation of the IRP resulted in various next steps and recommendations including an evaluation of the adequacy of the existing institutional capacity of Halifax Water required for successful implementation of the IRP components including programs and projects identified. Recommendations for the water, wastewater and stormwater systems included, but were not limited to:

- Implementing various wastewater programs and plans including an I/I Pilot program, Wet Weather System Plan, assessment of eight wastewater treatment facilities, and a Wastewater Master Plan
- Development of a Water Master Plan applying water use trends and design criteria
- Assessment of stormwater quality compliance requirements and clarification of the role of Halifax Water in stormwater planning and management
- Assessment of Climate Change impacts on all systems which will require an update of design standards and operational practices

The proposed 30-year expenditures for the recommended 2012 IRP is presented in **Figure 3**.



Figure 3 – 2012 Integrated Resource Plan

2.1.2 RELEVANT STUDIES, FRAMEWORKS AND INITIATIVES

Halifax Water has been very active in implementing recommendations from the 2012 IRP as well as other initiatives to inform the decision-making and long-term planning process. Several studies, frameworks and initiatives have provided Halifax Water with a much-enhanced understanding of Halifax Water's existing infrastructure and better planning approaches to meet future needs. **Table 2** presents some of the main relevant studies, frameworks and initiatives in the IRP Update context.

Table 2 – Studies, Frameworks and Initiatives

Studies and Initiatives
Regional Development Charge (RDC) — Approved in 2014. Provides a justifiable and transparent framework to implement an RDC incorporating 20 years of the proposed capital program and scenarios to assess potential impacts of varying RDC assumptions.
Regional Centre Local Wastewater Servicing Capacity Analysis (LoWSCA) — Completed in 2016 for HRM. Provides an understanding of local wastewater collection system capacity constraints within six target intensification areas.
Water Quality Master Plan Update (WQMP) — Completed in 2017. Guides Halifax Water's work and ongoing research on water quality related to understanding and adapting to lake recovery, maintaining distribution system water quality and water quality data mining.
West Region Wastewater Infrastructure Plan (WRWIP) — Completed in 2017. The foundation of policies for the West Region of Halifax regarding regional infrastructure planning, preferred servicing solutions and preliminary designs for wastewater infrastructure servicing needs.
Wet Weather Management Program (WWMP) — Initiated in 2013 and ongoing. Program that guides how to effectively manage wet weather flows within the sanitary wastewater systems including monitoring and separating combined sewer systems when possible and in the most cost-effective way.
Five-year Business Plans — Most recent plan completed for the 2018/19 to 2022/23 period. Developed to provide Halifax Water with a comprehensive financial plan related to the impact of current and imminent capital projects as well as future capital demands.
Asset Management Plans (AMPs) — Provides an annual summary of Halifax Water's asset inventory and outlines how the Utility manages its assets, the state of regional infrastructure, the level of service provided by assets, and associated costs.
Infrastructure Master Plan — Completed in 2019. Focuses on producing optimal servicing strategies for the water and wastewater networks within Halifax.
Compliance Plan — Completed in 2019. Plans to establish current and future federal, provincial and municipal level compliance regulations to create a path forward for Halifax Water to maintain and achieve compliance over the next 30 years.
Integrated Stormwater Management Policy — Ongoing policy development with HRM. Developed to implement policies that guide municipal utility operations and governance while delivering stormwater management services within both legislative requirements and community expectations.

2.1.2 RELEVANT STUDIES, FRAMEWORKS AND INITIATIVES CONTINUED

Table 2 – Studies, Frameworks and Initiatives (continued)

Frameworks
Climate Change Management Framework — Developed in 2018. Created in the form of a simple flow diagram to represent how infrastructure systems of individual assets progress from being assessed against climate change to having a mitigation strategy implemented.
Cost Estimation Framework (CEF) — Developed in 2017. Provides a consistent, transparent and audit-able approach to costing capital projects both internally and externally.
Long-Term Planning Framework (LTPF) — Developed in 2017. Provides Halifax Water with direction for holistic long-term infrastructure planning activities considering all drivers of infrastructure management.
Initiatives to Close Data Gaps
Sewer Inspection and Survey Program — Provides Halifax Water with information regarding the condition and performance of sewers in order to identify defects requiring rehabilitation or replacement.
Condition Assessments by Asset Class — Formal condition assessments used to inform the development of Asset Management Plans for various asset classes using available asset attribute data.
Flow Monitoring Program — Initiated in 2016 and implemented in phases from Spring 2016 to Spring 2018. Developed to monitor and inform wet weather analysis and includes permanent flow monitors, short term flow monitors which are used for the WWMP and temporary monitors which are used to inform capital projects.
Wet Weather Management Program and I/I Reduction Pilot Area Assessments — Addition to the WWMP. Identification of five high inflow and infiltration (I/I) areas to enable Halifax Water to validate the Rainfall Derived I/I reduction that can be accomplished through various I/I reduction strategies.
GIS Update — Information Technology Strategic plan developed in 2017. Provides a structured approach for implementing technological investment strategies including new ways to update and integrate GIS in Halifax Water operations.
Water and Wastewater Hydraulic Models — Built and calibrated for Halifax Water to assess the water and wastewater distribution and collection systems in terms of operational strategies and to inform capital project needs.
Lead Service Replacement Program — Approved in 2017. Program is intended to remove all lead service lines in an effort to limit the opportunity for lead to come in contact with drinking water.
Advanced Metering Infrastructure (AMI) & Customer Connect Program — Launched in 2017. The program's efforts are aimed at replacing all water meters with Advanced Metering Infrastructure Technology to enable two-way digital communication between Halifax Water and its customers and allow them to effectively manage their usage and footprint.

Appendix A.1 provides a summary of the studies, frameworks and initiatives that Halifax Water is currently undertaking or has completed since the 2012 IRP. For detailed information of the past studies and initiatives that support the work undertaken for the IRP Update, refer to the Infrastructure Master Plan Background Review.

2.2 GOVERNANCE

2.2.1 HALIFAX REGIONAL MUNICIPALITY (HRM)

Halifax Regional Municipality (HRM) was established in 1996 when the City of Halifax, the City of Dartmouth, the Town of Bedford and Halifax County were united to form one municipal unit. HRM is comprised of an estimated population density of 71.1 per km², spanning across a total of 5,490 km², or 10% of Nova Scotia's total land area. However, the majority of the HRM population is situated around the Urban Core centered on and around the Halifax Harbour. Outside the Urban Core, the majority of residents are concentrated in a number of rural communities.

Halifax Water is an autonomous, self-financed utility owned by HRM. The role of HRM is to maintain and oversee overall planning authority and provide the specific direction for the nature and location of future growth.

2.2.2 HALIFAX WATER

Halifax Water is the water, wastewater and stormwater utility servicing residents of HRM. Halifax Water, previously known as the Public Service Commission, was created in 1945 to maintain and operate the water supply system for the City of Halifax. When the City of Halifax amalgamated with the City of Dartmouth, Town of Bedford, and Halifax County in 1996, Halifax Water merged with the water utilities of those former municipalities. In 2007, Halifax Water further expanded its mandate with the transfer of all wastewater and stormwater assets from HRM.



Halifax Water owns, operates and maintains the water and wastewater systems within HRM, as well as the stormwater infrastructure located within the road right-of-way or easements owned by the utility. Halifax Water builds and maintains infrastructure to treat, deliver and move water and wastewater across the region while servicing over 109,000 customers and employing approximately 500 people.

2.2.2.1 Mission and Vision

Halifax Water Mission and Vision statements are as follows:



2.2.3 HALIFAX WATER BOARD OF COMMISSIONERS

Halifax is governed by the Halifax Board of Commissioners which includes four members of Halifax Regional Council appointed by Council, three residents of HRM appointed by council and the Chief Administration Officer of HRM, or a Halifax municipal employee appointed by the Chief Administrative Officer.

The roles and functions of the Halifax Water Board of Commissioners are to uphold a policy of openness and transparency, balanced with its roles in representing the interests of Halifax Water, its customers and other stakeholders.

Two provincial bodies have responsibility for oversight of Halifax Water: Nova Scotia Utility and Review Board (NSUARB) and Nova Scotia Environment (NSE).

2.2.4 NOVA SCOTIA UTILITY AND REVIEW BOARD

The NSUARB is an independent body with both regulatory and adjudicative jurisdiction. The NSUARB provides general supervision over all public water utilities within the province, including involvement in rate setting, approval of large capital expenditure projects and reviewing complaints. The NSUARB ensures projects meet the requirements of the public utilities act. When approving capital expenditures, the NSUARB assesses, among other things, the need for the proposed project, the reasonableness of the expenditure, and the financial impact on the Utility and its customers.

2.2.5 NOVA SCOTIA ENVIRONMENT

NSE is the provincial government department that acts as environmental regulator ensuring public health and environmental quality. NSE oversees wastewater and water supply standards, issues approvals and audits compliance with standards. NSE specifically regulates drinking water quality as well as municipal and industrial discharges from wastewater treatment facilities and other sources such as overflows.

In addition to the NSUARB and NSE, federal departments including Department of Fisheries and Oceans (DFO), Environment and Climate Change Canada (ECCC) and Health Canada (HC) may also play an oversight role for specific projects and activities.

2.3 STUDY AREA

HRM is comprised of 18 community planning areas, spanning 5,500 km², with an approximate population of 411,014 people (2016 census estimate). The boundary of the 2019 IRP Update includes the existing and planned Central, East and West service areas for water and wastewater in HRM, as well as the stormwater service boundary.

The study area of the 2019 IRP Update is provided in **Figure 4**.




Figure 4 – Study Area

Halifax Water owns and operates the water distribution system and the wastewater collection system. It also owns and operates the stormwater collection system within the right-of-way inside the Halifax Water stormwater service boundary.

The following section, details Halifax Water's existing water, wastewater and stormwater infrastructure.

2.4 HALIFAX WATER INFRASTRUCTURE

2.4.1 WATER SYSTEM

Halifax Water provides drinking water and fire protection services to approximately 370,000 people. The water distribution system is made up of 1,558 km of watermains (including transmission and distribution mains), eight water supply plants (WSP), two back-up water supplies, six water supply dams, 21 booster stations and 143 chambers. An overview of the water supply system is illustrated in **Figure 5**.

Halifax has three main water supply plants; J.D Kline WSP, Lake Major WSP and Bennery Lake WSP. In addition, Halifax Water services five smaller community supply plants that service rural / suburban areas. Each WSP has a water withdrawal permit and meets the Canadian Drinking Water Standards.

J.D. Kline WSP services the West and Central Region including the greater urban core of Halifax, Bedford, Sackville, Fall River, Waverley, Herring Cove and Timberlea. The plant uses a direct dual media filtration process to treat water from the Pockwock Lake.

Lake Major WSP services the East Region including Dartmouth, Eastern Passage, Shearwater, North Preston and Forrest Hills / Colby Village. The plant uses a sedimentation and multi-media filtration process to treat water from Lake Major.

Bennery Lake WSP services the Halifax Stanfield International Airport and Aerotech Business Park. The plant uses a direct filtration process to treat water from Bennery Lake.




Figure 5 – Overview of the Existing Water System




Figure 6 – Overview of the Existing Wastewater System

2.4.2 WASTEWATER SYSTEM

The wastewater collection system is made up of 1,424 km of sewers (including forcemains and gravity sewers), 14 treatment facilities, one biosolids processing facility and 166 pumping stations.

Halifax Water currently owns and operates five major wastewater treatment facilities (WWTF), Halifax, Dartmouth, Herring Cove, Mill Cove and Eastern Passage and nine smaller WWTF that service rural / suburban areas providing a level of treatment from primary to tertiary. Five of the WWTFs discharge to salt water bodies and nine discharge to small freshwater bodies. **Figure 6** provides an overview of the wastewater network.

2.4.2 WASTEWATER SYSTEM CONTINUED

The major wastewater collection system for each of the regions is as follows:

The West Region is comprised of the urban areas of the Halifax Peninsula and mainland serviced by the Halifax WWTF, and outlying suburbs including Beechville, Lakeside and Timberlea are serviced by the BLT WWTF and the trunk sewer which conveys flow to Halifax sewershed, while the outer regions of Spryfield and Herring Cove are serviced by the Herring Cove WWTF.

The East Region is comprised of the Dartmouth area which includes combined and separated sewers tributary to the Dartmouth WWTF. The Dartmouth catchment is particularly complex with separated networks entering combined networks, high Inflow and Infiltration (I&I) levels and several flow splits which create complexity when characterizing flow paths and defining catchment areas. The outlying suburbs of Cole Harbour, Shearwater and Eastern Passage are tributary to the Eastern Passage WWTF.

The Central Region comprises of Bedford and Sackville which are tributary to the Mill Cove WWTF. A large portion of the Central Region is not serviced by the municipal wastewater system, relying on on-site sewage disposal.

2.4.3 STORMWATER SYSTEM

The stormwater collection system is made up of 878 km of storm sewers, 2,337 cross culverts, approximately 16,000 driveway culverts, and 40 stormwater management structures.

The stormwater system is multi-jurisdictional, with the provincial and municipal governments, Halifax Water and private owners having distinct roles and responsibilities within the stormwater cycle.

Figure 7 on the right provides an overview of Halifax Water's stormwater service boundary.

Table 3 below presents the stormwater system jurisdiction and roles and responsibilities for each entity.

Table 4 below presents the inventory of Halifax Water's infrastructure and the associated replacement cost.




Figure 7 – Halifax Water Stormwater Service Boundary

Table 3 – Stormwater System Jurisdiction

Entity	Roles and Responsibilities
Province of Nova Scotia	<ul style="list-style-type: none"> • Protection of water resources including natural watercourses (stream, rivers, lakes) • Issues a Permit to Construct for the installation of a public stormwater system
Halifax Water	<ul style="list-style-type: none"> • Municipal water, wastewater and stormwater utility serving HRM residents • Authority to own and operate stormwater systems within a defined service boundary which comprises of catch basins, pipes, manholes, roadside, ditches, swales, culverts, stormwater holding tanks, ponds, and dams

2.4.3 STORMWATER SYSTEM CONTINUED

Table 3 – Stormwater System Jurisdiction (continued)

Entity	Roles and Responsibilities
Halifax Regional Municipality	<ul style="list-style-type: none"> Regulation of land development activities including siting of buildings, grading of land, and assessment of impacts of overland flow resulting from development of land and stormwater systems Owns and maintains minor drainage system elements including pipes, ditches, culverts, etc. that fall outside of Halifax Water's service boundary Owns and maintains public street system
Private Property Owners	<ul style="list-style-type: none"> Stormwater flow across individual properties, across adjacent property boundaries and stormwater management systems located on individual property Private stormwater systems include rainwater leads, footing drains, private community systems, and slope protection within privately-owned property Maintain drainage corridors and privately-owned drainage infrastructure free of vegetation and debris

Table 4 – Infrastructure Inventory and Replacement Costs

Asset Group	Asset*	Number / Length	Replacement Costs (\$2019 Millions)
Water	Water Distribution Mains	1235 km	\$1,384
	Water Transmission Mains	323 km	\$690
	Water Pumping Stations	21	\$17
	Chambers and PRV	143	\$50
	Water Reservoirs	16	\$95
	Dams	6	\$44
	Water Supply Plants	10**	\$306
Water System Sub-Total			\$2,586
Wastewater	Sewers	1296 km	\$1,714
	Forcemains	129 km	\$275
	Pumping Stations	166	\$561
	Holding Tanks	5	\$12
	Treatment Facilities	14	\$652
	Wastewater System Sub-Total		
Stormwater	Pipes	878 km	\$1,369
	Cross Culverts	2,337	\$268
	Driveway Culverts	16,000	\$56
	Structures	40***	\$3
	Stormwater System Sub-Total		
All Systems Total			\$7,496
<p>*There are other categories of assets funded through the capital program that are not represented above (e.g. Information systems and other corporate programs)</p> <p>**Includes back up supply plants</p> <p>***Excludes Sullivans Pond and Ellenvale Run</p>			

2.5 PLANNING DATA AND POPULATION PROJECTIONS

As part of the Infrastructure Master Plan process, Halifax Water's project team including HRM staff collaborated to define the planning projection dataset, required to develop the Infrastructure Master Plan. HRM confirmed the starting baseline populations, the ultimate planning projection approach and growth rate over a 30-year horizon, from 2016 to 2046. The resulting planning estimates were the basis for the water demand and wastewater flow projections for the Infrastructure Master Plan. **Table 5** summarizes the HRM planning estimates as developed in the Infrastructure Master Plan and **Figure 8** presents the location of projected growth in the study area.

Table 5 – Halifax Regional Municipality Planning Estimates

Sub-boundary	Employment Growth (2016 - 2046)	Population Growth (2016 - 2046)	Total Growth (2016 - 2046)
Regional Centre	42,123	53,507	95,630
Suburban	36,963	77,706	114,669
Rural	6,877	17,000	23,877
Total	85,963	148,213	234,176
Service Area*	79,086	131,213	210,299

*Excludes rural planning projections.




Figure 8 – Population Growth Allocation

2.6 DESIGN CRITERIA AND LEVEL OF SERVICE

2.6.1 DESIGN CRITERIA

A comprehensive review of Halifax Water's existing design criteria for water supply and wastewater collection systems was completed as part of the WRWIP and Infrastructure Master Plan. In addition to the review, trend analyses and a summary of industry best practice were used to validate the appropriateness of the criteria.

Key design criteria for wastewater collection system:

- Per capita sanitary flow = 300 L/cap/day
- I/I allowance rate = 0.28 L/s/ha

Key design criteria for water supply system:

- Per capita average day demand = 375 L/cap/day
- Peaking factors summarized in **Table 6**

Table 6 – Peaking Factors for Infrastructure Planning

Category	MDD	PHD
System Supply	1.40	2.10
Storage	1.90	2.85
Pumping and PRVs (Zones > 10,000 people)	1.90	2.85
Pumping and PRVs (Zones < 10,000 people)	2.20	3.30

2.6.2 LEVEL OF SERVICE

A comprehensive review of Halifax Water's level of service for water supply and wastewater collection systems was completed as part of the Infrastructure Master Plan. The level of service recommended as part of the Infrastructure Master Plan includes:

Wastewater collection systems

- A 1 in 5-year design event is to be used to assess peak flows and infrastructure capacity.
- Ensure that new development does not increase the frequency and/or volume of CSOs or SSOs, or impact on the water quality.
- In recognition of the high amenity value of the Northwest Arm, a more stringent limit of 10 overflow events per year is to be applied at each individual CSO along the Northwest Arm.

Water supply systems

- Pressures between 40-100 psi under Minimum Hour Demand (MHD) and Peak Hour Demand (PHD) scenarios.
- Pressures above 22 psi during a fire under a Maximum Day Demand (MDD) scenario.
- Available storage capacity in accordance with the Atlantic Canada Guidelines.

3.0 INTEGRATED RESOURCE PLAN DRIVERS AND OBJECTIVES

The 2019 IRP purpose is to develop an integrated 30-year capital infrastructure plan covering all systems (water, wastewater, stormwater) and drivers (growth, compliance, asset renewal). In support of the three drivers, fourteen objectives based on Halifax Water's level of service, compliance requirements (existing and future), asset renewal requirements, as well as other important considerations such as adaptation to climate change, system reliability and servicing growth were further identified.




Figure 9 – Integrated Resource Plan Drivers

3.1 COMPLIANCE

For the 2019 IRP Update the compliance driver has been divided into two main categories: Regulatory Compliance and Level of Service Compliance. Regulatory compliance is based on Halifax Water's goal to ensure, through their efforts, that appropriate measures are taken to be in conformity with current policies and regulations. The level of service component of compliance is based on Halifax Water aspiring to provide customers with high quality water, wastewater and stormwater services, in accordance with the Halifax Water's vision.

3.1.1 WATER SYSTEM

Regulatory Compliance — Nova Scotia Environment (NSE) is the department of the provincial government responsible for overseeing drinking water with emphasis on water works approvals, facility classification and operator certification, drinking water quality, as well as monitoring and reporting. Compliance for drinking water treatment and delivery is regulated by NSE through approvals issued under the Environment Act. These approvals are issued for a period of 10 years and provide the terms and conditions for the operation of the water supply plants.

Health Canada publishes the Guidelines for Canadian Drinking Water Quality. These guidelines provide direction on the acceptable levels of microbiological, chemical and radiological contaminants in drinking water and on the physical characteristics of drinking water (e.g. odour, taste). The guidelines can be published as either Maximum Acceptable Concentrations (MAC's) which are health related parameters; Aesthetic Objectives (AO's) and Operational Objectives. Drinking Water Approvals in Nova Scotia require that all MAC's must be achieved. While achievement of AO's is not required, many of them must be monitored and reported on. Any new or revised MAC's published during the life of an Approval is deemed to form part of the Approval by NSE.

3.1.1 WATER SYSTEM CONTINUED

Regulatory requirements related to the operation of the water transmission and distribution system include the following:

- Free chlorine residual of 0.20 mg/L at all locations in the distribution system at all times.
- Distribution system turbidity of < 5 NTU.
- Total Trihalomethanes < 100 ug/L based on a locational running annual average (LRAA).
- Haloacetic Acids (5), < 80 ug/L based on LRAA.
- Continuous chlorine residual monitoring on the outlet of all storage facilities.
- Provide water that is not corrosive to lead.

Through the Compliance Plan, water facilities and distribution system were reviewed to determine Halifax Water's current state of compliance with regulations, and recommendations were then incorporated into the IRP Update.

Level of Service Compliance — Level of service compliance for the water system focuses on meeting Halifax Water's level of service for system pressures and available storage capacity (as described in **Section 2.6.2**) and ensuring that climate change considerations are taken into account when planning and sizing water infrastructure.

3.1.2 WASTEWATER SYSTEM

Regulatory Compliance — Wastewater management in Canada is governed federally, provincially and at the municipal level. Legislation is issued federally to stipulate minimum standards for wastewater effluent, while provincial governments are responsible for issuing permits or licenses to wastewater treatment facilities to construct and operate under their regulatory framework. Permits are typically site specific and may require increased stringency based on provincial legislation to improve human health and ensure environmental protection based on population density and assimilative capacity of the receiving waters.

Halifax Water has been consistently working toward achieving the provincial level of wastewater treatment as stipulated by Nova Scotia Environment (NSE) permits and Federal Wastewater System Effluent Regulations (WSER). Historically, NSE has set compliance standards for each wastewater treatment facility (WWTF) issuing Approval for Operation which sets the effluent limits, and the Canada-wide Strategy for the Management of Municipal Wastewater Effluent (CSMMW) provided national standards for combined sewer overflows (CSO) and sanitary sewer overflows (SSO). In June of 2012, the WSER was enacted which set national standards for WWTF effluent discharge and CSO and SSO monitoring. The NSE, CSMMW and WSER requirements are detailed in the following sections.

Nova Scotia Environment: Nova Scotia Environment has local jurisdiction to implement additional or more stringent requirements pertaining to wastewater effluent. In 1992, NSE developed provincial regulatory direction on wastewater effluent requirements. This direction was amended and incorporated into the Atlantic Provinces approach; the "Atlantic Canada Wastewater Guidance Manual for Collection, Treatment and Disposal". Based upon wastewater assimilation studies, the Atlantic Canada Guideline provides a procedure for determining effluent quality requirements for new or upgraded wastewater treatment plants. Each municipal wastewater treatment facility is required to obtain an Approval to Operate that outlines how the facility shall be managed and operated to achieve effluent requirements specific to the receiving waters.

3.1.2 WASTEWATER SYSTEM CONTINUED

Canada-wide Strategy for the Management of Municipal Wastewater Effluent (CSMMW): Prior to the WSER, the most significant policy / regulation related to Halifax Water's long-term wastewater planning objectives was the Canada-wide Strategy for the Management of Municipal Wastewater Effluent (CSMMW), which is endorsed by the Canadian Council of Ministers of the Environment (CCME). The objective of the CCME was to achieve regulatory clarity in managing municipal wastewater effluent under a harmonized framework that is protective of human health and the environment. Since the establishment of the CCME guidelines, the WSER (2012) became law.

Wastewater System Effluent Regulations (WSER): The WSER were enacted in June 2012 and amended January 2015. The WSER were implemented by the federal government and became both the provincial and federal wastewater standards for compliance. The WSER regulations are intended to phase out the release of under-treated wastewater effluent and improve the understanding on CSO and SSO spills through monitoring. The WSER define the following as deleterious substances, and set national standards for their discharge:

- Carbonaceous Biochemical Oxygen Demand (CBOD): 25 mg/L
- Suspended Solids (TSS): 25 mg/L
- Total Residual Chlorine (TRC) for facilities using chlorine disinfection: 0.02 mg/L
- Uni-ionized Ammonia as N at $15^{\circ}\text{C} \pm 1^{\circ}\text{C}$: 1.25 mg/L

WWTFs are authorized to discharge these substances at levels below the defined limits, provided that the effluent is not acutely lethal to trout as determined by standard toxicity testing. Facilities not in compliance must apply for a Transitional Authorization (TA) to deposit effluent exceeding those limits. The Authorization will be valid for a period of 10, 20 or 30 years, depending on the risk level associated with the effluent, as determined by a defined risk-ranking system in the WSER.

Through the Compliance Plan, wastewater facilities and collection system were reviewed to determine Halifax Water's current state of compliance with regulations, and recommendations were then incorporated into the IRP Update.

3.1.3 WASTEWATER OVERFLOWS

Regulatory Compliance — Halifax Water records the volume and frequency (# of events and # of days active) of overflows associated with the combined sewer overflows (CSOs) and reports this information annually to Nova Scotia Environment and Environment Canada. There is currently no effluent quality monitoring or reporting requirements for overflows from CSOs.

A number of regulations and guidelines speak to combined sewer overflows (CSOs) however, there is little concrete direction concerning SSOs. In the Canadian Council of Ministers for the Environment (CCME) Guideline the recommended national standard for SSOs is, "sanitary sewer overflow frequencies will not increase due to development or redevelopment". However, this standard was not adopted into the WSER.

Level of Service Compliance — Since the development of the Regional Wastewater Functional Plan (RWWFP) in 2012, Halifax Water has taken a proactive approach to managing the impacts of growth on the wastewater system. The RWWFP states "Therefore, Halifax Water intends to manage the system such that planned serviced growth impacts will not increase the frequency and volume of CSOs and SSOs." This approach was carried forward in the WRWIP which further states "In general, it is recommended that the CCME national standard guidelines for CSOs and SSOs continue to be followed and infrastructure solutions be identified so that, in light of growth, current LOS be maintained, particularly overflow frequency and volume performance."

Level of service compliance for wastewater overflows focuses on meeting Halifax Water's level of service recommended as part of the Infrastructure Master Plan further discussed in **Section 2.6.2** of this report.

3.1.4 STORMWATER SYSTEM

Currently, there are no regulatory compliance requirements with respect to the stormwater system. However, it is expected that future regulation could potentially look into mitigating and/or avoiding negative impacts of stormwater on receiving water quality, as well as the effects of flooding and erosion.

3.1.5 COMPLIANCE OBJECTIVES

There are nine specific IRP objectives covering the compliance driver. Objectives 1 to 5 are directly associated with meeting or exceeding current and future regulatory compliance. Objectives 6 to 9 are associated with Halifax Water's desired level of service including meeting future compliance requirements for overflows, stormwater quality and adaption to climate change.

Table 7 below present the IRP objectives associated with Regulatory and Level of Service Compliance.

Table 7 – Compliance Objectives

Driver	Infrastructure System	Objective	
Compliance	Regulatory	Wastewater	1 Meet or exceed current Nova Scotia Environment WWTF Permit to Operate Requirements
		Water	2 Meet or exceed current Nova Scotia Environment WSP Permit to Operate
		Wastewater Stormwater	3 Meet Current Overflow Compliance (Monitor and Report)
		Wastewater	4 Meet or exceed Future WWTF Compliance
		Water	5 Meet or exceed future drinking water compliance
	Level of Service	Wastewater Stormwater	6 Meet future overflow compliance
		Water Wastewater Stormwater	7 Endeavour to provide existing systems that are adequately sized to meet Halifax Water Level of Service
		Stormwater	8 Meet Future Stormwater Quality Compliance
		Water Wastewater Stormwater	9 Ensure planning and sizing of infrastructure considers the impact of climate change

3.2 ASSET RENEWAL

Asset renewal encompasses the replacement or rehabilitation of an existing asset with a new asset capable of delivering the same or improved level of service. Asset renewal was the major strategic driver identified in the 2012 IRP and will continue as the main driver for the foreseeable future, all with the intention to elevate the level of service to customers and protect the environment.

Managing infrastructure assets now and in the future ensures that as assets continuously age and deteriorate, they will deliver the desired level of service into the long term and that appropriate financial planning is in place for timely asset renewal implementation. To guarantee effective asset management practices, Halifax Water currently develops annual Asset Management Plans (AMPs) that provide a summary of asset inventory and state of Halifax Water's infrastructure, level of service the assets provide to the customers, infrastructure replacement and maintenance strategies, and associated costs and expenditures. The level of detail in each of the AMPs varies among asset classes, but all the recommendations are incorporated into the IRP Update.

3.2.1 ASSET DATA GAPS

Effective asset renewal is based on solid understanding of the asset inventory and current asset condition. However, during the development of the 2012 IRP, asset data gaps were identified as major challenges for the development of the asset renewal program. The following are some of the data gaps identified in the 2012 IRP:

- Water, wastewater and stormwater assets were missing from GIS datasets.
- Linear asset information such as material, diameter and age were missing at some extent for water, wastewater and stormwater linear asset classes.
- Breakdown of assets to equipment / component level was not available for pumping stations and treatment plants.
- Significant limitations on asset condition data.
- Historical capital expenditure was not available for all asset classes.
- Limited renewal/rehabilitation data.

Since the development of the 2012 IRP, Halifax Water has proactively established programs, undertaken assessments and collected information to close data gaps. Halifax Water has focused efforts on gathering missing data on asset attributes such as size, material, age, and condition which has supported the establishment and preparation of formal annual AMPs.

Through the completion of the Wastewater Treatment Facility Condition Assessment, Wastewater Pumping Station Condition Assessment, Stormwater Culvert Inventory and Condition Assessment, and Sewer Condition Assessments, the level of existing asset information has greatly improved the baseline understanding and provided data needed to complete the AMPs for those asset classes. For remaining asset classes, best available information was used to theoretically establish condition with the understanding that future AMPs will be refined as new information is collected.

Other initiatives and programs to close data gaps include:

- Corporate Flow Monitoring Program
- Wet Weather Management Program
- I/I Reduction Pilot Area Assessments
- GIS Update
- Customer Connect Program
- Water and Wastewater Hydraulic Models Build and Calibration
- Lead Service Replacement Program
- Advanced Metering Infrastructure (AMI)

For more details on asset data gaps, assumptions and initiatives to close data gaps, please refer to [Appendix A.1, Section 3](#).

3.2.2 ASSET RENEWAL OBJECTIVES

There are three specific IRP objectives covering the asset renewal driver. Asset renewal objectives are not only related to the replacement and/or rehabilitation of existing assets, but also with enhancing the existing system for reliability, redundancy, security of supply and reduction of energy, GHG emissions and operating costs.

Table 8 below present the IRP objectives associated with Asset Renewal.

Table 8 – Asset Renewal Objectives

Driver	Infrastructure System		Objective
Asset Renewal	Water Wastewater Stormwater	10	Implement optimal level of asset re-investment
	Water Wastewater Stormwater	11	Enhance the reliability, redundancy and security of the water, wastewater and stormwater systems with attention to high risk and critical areas
	Water Wastewater	12	Reduce energy consumption, operating costs and GHG contributions

3.3 GROWTH

Projected growth within greenfield and intensification areas is a fundamental component for the long-term infrastructure planning of the water, wastewater and stormwater systems. The 2012 IRP utilized high level growth estimates that were generated by HRM in collaboration with Halifax Water during the RWWFP. The planning numbers were a key input into the creation of the infrastructure requirements in the RWWFP, but they were not subject to additional analysis during the development of the 2012 IRP.

Since the 2012 IRP, the Halifax Water project teams including HRM staff collaborated to define the planning projections dataset required to complete the Infrastructure Master Plan. Planning data and growth projections formed the baseline and growth demands on the systems, spanning the period from 2016-2046 (a 30-year planning horizon).

The growth projections defined under the Infrastructure Master Plan, reflect Census growth trends, known developments and planning guidelines, as outlined in the HRM Centre Plan and Integrated Mobility Plan. The growth projections for HRM service area are:

- Population Growth (2016-2046) = 131,213
- Employment Growth (2016-2046) = 79,086
- Total Growth (2016-2046) = 210,299

These growth numbers cover Halifax Water service areas (e.g. exclude rural planning projections). The Infrastructure Master Plan growth projections are presented in more detail in **Section 2.5** of this report.

3.3.1 IMPACT OF GROWTH ON THE EXISTING SYSTEMS

Significant growth is planned for the Halifax Water service area. The location of this growth will put additional stress on infrastructure systems that are in places already at capacity, particularly as it relates to wastewater infrastructure. In line with HRM growth projections, a significant amount of growth is expected to occur through intensification within the Regional Centre. Downtown Halifax and Dartmouth are key areas where intensification is planned and where existing infrastructure systems are sensitive to growth. In both locations, the presence of combined sewer systems and some of the oldest infrastructure present significant challenges without infrastructure improvements/solutions. In these areas, growth will increase the amount of CSO discharge occurring and exacerbate capacity issues that are known to exist.

Suburban growth on the edge of the existing urban boundary will stress regional infrastructure. For the East water system, Lake Major supply is not adequate to service the planned growth on its own and the Pockwock transmission main and requirement for full back up supply become more critical with a larger population. For the East wastewater system, the Eastern Passage gravity pressure sewer is under capacity with planned growth. For the wastewater system, sewer separation and I/I reduction have great potential to recapture capacity for growth.

More detailed information of growth impacts on Halifax Water systems are provided in ***Appendix B.1 – Infrastructure Master Plan Executive Summary***.

3.3.2 GROWTH OBJECTIVES

There are two specific IRP objectives covering the growth driver. The first objective is directly related to providing the system with new infrastructure to support growth. The second objective is related to managing the existing water demands and sanitary flows to maximize the use of the existing systems and free up capacity to minimize the need for new infrastructure to service growth.

Table 9 below present the IRP objectives associated with Growth.

Table 9 – Growth Objectives

Driver	Infrastructure System		Objective
Growth	Water Wastewater Stormwater	13	Provide regional water, wastewater and stormwater infrastructure needed to support planned growth
	Water Wastewater	14	Manage flow and demand to maximize capacity for growth and minimize the need for new hard infrastructure

3.4 CHALLENGES, OPPORTUNITIES AND RISKS

Identifying the primary Integrated Resource Plan constraints and opportunities will provide an understanding of the risk associated with the individual projects that form the final capital program. The opportunities, challenges and risks identified in the 2012 IRP are largely still relevant and as such the following section provides an update.

The IRP provides an opportunity to integrate the drivers of compliance, renewal and growth across the water, wastewater and stormwater systems. This integration will provide efficiencies in project delivery and ensure that the IRP objectives are met in the most cost-effective way. The challenge related to this integration is to ensure that the approach is repeatable and becomes an embedded process that Halifax Water can continue to update throughout the program implementation.

3.4.1 COMPLIANCE – WATER

The water system is currently compliant with all regulatory requirements and the risk of unknown future, more stringent, compliance requirements are negligible. However, there are challenges with regard to the water system and maintenance of compliance and level of service in light of growth. The Infrastructure Master Plan, for the first time, provided a comprehensive review of the water system considering existing conditions and growth. The outcome identified two key needs that relate to Halifax Water's ability to maintain compliance into the future: the safe yield study of the two primary supply sources, Lake Pockwock and Lake Major, and the transmission main risk assessment. In addition to these risks, climate change is ever present and Halifax Water's intent to progress the implementation of water supply plant vulnerability assessments will be critical to manage the risks posed by climate change into the future.

3.4.2 COMPLIANCE - WASTEWATER

WWTF compliance is currently not consistently attained across all facilities. With the potential need for upgrades to meet WSER requirements at Halifax Water's Halifax and Dartmouth Halifax Harbour Solutions Project (HHSP) facilities there are opportunities for Halifax Water to consider alternative technologies and enhanced treatment to ensure compliance of all WSER requirements.

At present, the WSER regulations require monitoring and reporting of CSO and SSO discharges. It is anticipated that within the 30-year horizon of the IRP there will be more stringent requirements on discharges, likely with annual limits applied, consistent with the majority of other comparable international jurisdictions. The IRP program includes CSO and SSO management plan projects to assess the needs to achieve future reductions. This work presents opportunities for Halifax Water to integrate these needs with those of renewal, growth and climate change mitigation to ensure that they are obtained in the most cost-effective approaches building on the rainfall derived inflow and infiltration (RDII) and sewer separation programs currently recommended.

3.4.3 COMPLIANCE - STORMWATER

Potential future compliance relating to stormwater quality remains the greatest risk to maintaining stormwater compliance. Halifax Water has made good progress collecting inventory data of the stormwater network, particularly of culverts, and has implemented a stormwater charge. This creates opportunities to sustainably manage stormwater assets. The Infrastructure Master Plan identifies sewer separation projects that will impact stormwater and building on the Wet Weather Management Study opportunity exists to explore low impact development (LID) applications to enhance the system. These approaches should be explored as part of ongoing climate change assessments and as an opportunity to work with HRM.

3.4.4 ASSET RENEWAL

The advancement of the Halifax Water Asset Management Plans is testament to the progress Halifax Water has made with regard to asset renewal planning. Many data improvements have been made especially to pumping stations and sewers. Water main condition assessment, particularly transmission mains continue to be a challenge. The primary challenge across all asset classes relates to estimated life versus condition-based renewal planning. As further data is collected, a decision support tool that can leverage the condition data to inform renewal decisions is a key priority and will significantly enhance the understanding of actual needs and infrastructure deficit assessments.

3.4.5 GROWTH

The completion of the Infrastructure Master Plan, for the first time, brings together all systems and serviced areas into one comprehensive long-term plan to accommodate growth. There is a clear opportunity for Halifax Water to build on this enhanced planning momentum to ensure that 5-year updates are funded and implemented and that collaborative processes with HRM regarding growth projections are developed in the interim. The projections of growth used in the Infrastructure Master Plan were derived from the best planning estimates published by HRM. The challenge is to ensure that growth is monitored and compared to the planning estimates used. This will mitigate the risk of the actual versus planned growth deviating and ultimately impacting the validity of the Infrastructure Master Plan preferred strategy.

4.0 2019 INTEGRATED RESOURCE PLAN DEVELOPMENT

The IRP was a multi-step and iterative process. The key tasks and activities are represented graphically in **Figure 10**. The main approach to the development of the plan included the completion of the following tasks:

- Build on the foundation of the 2012 IRP and the projects, studies and work completed through its recommendations.
- Complete a baseline understanding from previous studies
 - Review opportunities and constraints for the water, wastewater and stormwater systems
 - Review underlying assumptions related to project triggers and servicing requirements
 - Identify data gaps
 - Consolidate recommendations from previous studies and identify potential conflicts and uncertainties
- Complete detailed review of Supply Side Management (SSM) and Demand Side Management (DSM) options.
 - Review completed and ongoing initiatives
 - Review opportunities and constraints related to implementing public and private-side initiatives
 - Develop a range of short and long term potential initiatives
- Coordinate and align needs identified in the Infrastructure Master Plan, Compliance Plan and Asset Management Plans.
 - Consolidate full range of recommendations
 - Identify opportunities for alignment and integration
 - Identify opportunities for merging projects or programs
- Utilize data and tools to help close gaps through data linkage and apply spatial allocation, prioritization and decision-making tools to review project integration opportunities.
- Identify the projects and splits that meet the three drivers of Compliance, Asset Renewal and Growth
 - Complete a project-by-project analysis of the project triggers and objectives
- Provide the preliminary preferred long-term capital infrastructure program as an input into financial models
 - Work iteratively and collaboratively with Halifax Water team to support the development of a long-term capital infrastructure plan based on the capital investment requirements for the three drivers
- Recommend a forward-looking long-term infrastructure plan that is traceable, defendable and implementable.
- Provide recommendations for future initiatives and improvements
 - Recognizing the process for future updates, identify opportunities for additional work, data and other updates that would benefit and enhance value for the future IRP Update
- Create a foundation for ongoing capital budgeting processes
 - Provide the deliverables in a format to be easily leveraged into Halifax Water processes and other analyses for capital delivery including budgeting
- Prepare a report that documents the development of the IRP Update.

HALIFAX WATER INTEGRATED RESOURCE PLAN UPDATE PROCESS FLOW DIAGRAM




Figure 10 – 2019 Integrated Resource Plan Development, Process Flow Chart

4.1 FOUNDATIONAL STUDIES

There are three major foundational studies that served as the main inputs for the 2019 IRP Update: The Infrastructure Master Plan, Compliance Plan and Asset Management Plans (AMPs).

As mentioned in **Section 2.1.2**, since the 2012 IRP Halifax Water has been very active in implementing programs and initiatives to inform the decision-making process and the development of the foundational studies of the IRP Update. **Figure 11** presents a list of studies, frameworks and initiatives in the context of each of the foundational studies of the 2019 IRP Update.

Input No. 1 - Halifax Water Infrastructure Master Plan

Provides detailed and evaluated water and wastewater capital program to meet growth

- Halifax Water West Region Wastewater Infrastructure Plan (WRWIP) (2017)
- Halifax Centre Plan (2017)
- Integrated Mobility Plan (2017)
- Halifax Water Design Specification for Water, Wastewater & Stormwater (2017)
- Halifax Water Wet Weather Management Program Annual Report (2016/17)
- Regional Centre Local Wastewater Servicing Capacity Analysis (LoWSCA) (2016)
- Lake Major Water Supply Plant Process Optimization Study (2016)
- Regional Municipal Planning Strategy (2014)
- Halifax Water Development Charges Review (RDC) (2013)
- Bennery Lake Water Supply Plan Optimization Study (2013)
- Regional Wastewater Functional Plan (RWWFP) (2012)
- Halifax Water Integrated Resource Plan (IRP) (2012)
- Halifax Stanfield International Airport Master Plan (2011)
- J.D. Kline Water Supply Plant Improvements (2010)
- AeroTech Servicing Study Final Report (2008)
- East Region Dartmouth Water Infrastructure Plan (1999)

1

Input No. 2 - Compliance Plan

Provides direction / guidance to meet compliance

- Water Quality Master Plan Update (2016)
- WWTF ERA - Halifax, Dartmouth, Herring Cove, Mill Cove (2015)
- Lake Major Water Supply Plant Process Optimization Study (2016)
- Wastewater Compliance Plan (2014)
- Bennery Lake Water Supply Plan Optimization Study (2013)
- J.D. Kline Water Supply Plant Improvements (2010)

2

Input No. 3 – Asset Management Plans

Mainly age focused to identify 30 year capital reinvestment levels for asset replacement
Provides 5 year Asset Management Capital Program

- Water Quality Master Plan Update (2016)
- Halifax Water Integrated Resource Plan (IRP) (2012)
- Flow Monitoring Program
- Sewer Inspection Program
- Condition Assessments

3

Figure 11 – IRP Foundational Studies

4.1.1 INFRASTRUCTURE MASTER PLAN

The Infrastructure Master Plan focuses on the servicing strategies and management of infrastructure in the Halifax Region, to produce an optimal servicing strategy for the wastewater collection and water supply networks to meet growth. The Infrastructure Master Plan is built off previous completed studies such as the West Region Wastewater Infrastructure Plan (WRWIP) and Regional Centre Local Wastewater Servicing Capacity Analysis (LoWSCA). The Infrastructure Master Plan incorporates the WRWIP and provides servicing strategies for the rest of the wastewater system servicing the Central and East Regions. The Infrastructure Master Plan then follows a similar approach for the water network, by formalizing the foundational policies of regional infrastructure planning in water infrastructure and forming a servicing strategy that covers the regional water network for Halifax Water.




Figure 12 – Infrastructure Master Plan

The Infrastructure Master Plan is a key component of long-term planning, providing project costing and phasing. It included development / update of wastewater and water hydraulic models, conceptual designs for priority projects, and forms a work plan for adapting to climate change. **Figure 12** presents the total program and percentage split of water, wastewater and stormwater projects as an input into the 2019 IRP Update. The following key inputs were provided by the Infrastructure Master Plan to the 2019 IRP update:

- Planning projections and growth areas.
- Water and wastewater capital projects to 2046 including timing, cost estimates and spatial allocation.
- Wet Weather Management Study – priority areas, best areas with potential for sewer separation, Rainfall derived inflow and infiltration (RDII) reduction, low impact development (LID) and CSO discharge reduction.
- Climate Change Vulnerability Assessment Framework

Major components of the Infrastructure Master Plan include:

Wastewater

- Mill Cove WWTF Capacity Upgrade
- Dartmouth WWTF Capacity Upgrade and Flow Diversion to Eastern Passage
- Halifax WWTF Capacity Upgrade
- Fairview Cove Tunnel
- BLT Diversion to Halifax Peninsula
- Eastern Passage new Gravity Pressure Sewer upgrade
- Rainfall derived inflow and infiltration (RDII) reduction program across all regions
- Sewer Separation in Halifax and Dartmouth Areas

Water

- Pockwock Transmission Twinning (60") and (54")
- Bedford – Burnside Lake Major and Pockwock system interconnection
- Water system extension to Bennery Lake
- Robie Transmission Main

4.1.1 INFRASTRUCTURE MASTER PLAN CONTINUED

Wastewater projects make 64% of the total cost of the Infrastructure Master Plan component in the IRP Update. 73% of the projected wastewater projects cost are associated with growth, while 17% are associated with compliance and 9% with asset renewal needs.

Water projects make the remaining 36% of the total cost of the Infrastructure Master Plan component in the IRP Update. 60% of the projected water projects cost are associated with asset renewal, system optimization, redundancy and security of supply; while 40% are associated with growth.

There are no stormwater projects in the Infrastructure Master Plan.

Further detailed information can be reviewed in [Appendix B.1](#).




Figure 13 – Infrastructure Master Plan Wastewater and Water Components

4.1.2 COMPLIANCE PLAN

The Compliance Plan provides a review of the current state of compliance of Halifax Water's infrastructure with federal, provincial and municipal level compliance requirements. The main goal of the compliance plan is to document the long-term (30 years) infrastructure needs related to compliance and to ensure continued compliance requirements are met for wastewater, water and stormwater systems.

The plan discusses and examines wastewater treatment facilities, wastewater collection systems, sanitary and combined sewer overflows, water supply plants, and water distribution systems including water storage reservoirs. [Figure 14](#) presents the total program and percentage split of water, wastewater and stormwater projects from the as an input into the 2019 IRP Update.

The following key inputs were provided by the Compliance Plan to the 2019 IRP Update:

- Current and future regulatory compliance requirements.
- Detailed treatment compliance assessment for WWTFs and WSPs.
- Capital program including timing, cost estimates and location.




Figure 14 – Compliance Plan

4.1.2 COMPLIANCE PLAN CONTINUED

Major project from the Compliance Plan include:

- Halifax WWTF Upgrade to meet Wastewater Systems Effluent Regulations
- Dartmouth WWTF Upgrade to meet Wastewater Systems Effluent Regulations
- Herring Cove WWTF Upgrade to meet Wastewater Systems Effluent Regulations
- Corporate Flow Monitoring Program and Overflow Monitoring Program
- Wet Weather Management Program
- Lake Major and J.D. Kline WSP upgrades

Wastewater projects make 84% of the total cost of the Compliance Plan component in the IRP Update. 93% of the projected wastewater projects cost are compliance related, while 5% have a growth component and 2% are associated with asset renewal needs.

Water projects make the remaining 16% of the total cost of the Compliance Plan component in the IRP Update. All water projects costs are compliance related, and there are no water projects with asset renewal or growth components.

There are no stormwater projects in the Compliance Plan.

Further detailed information can be reviewed in [Appendix B.2](#).




Figure 15 – Compliance Plan Wastewater and Water Components

4.1.3 ASSET MANAGEMENT PLANS

The Asset Management Plans (AMPs) provide a summary of asset inventory and state of Halifax Water's infrastructure, level of service the assets provide to the customers, infrastructure replacement and maintenance strategies, and associated costs and expenditures.

Halifax Water currently updates the AMPs on an annual basis. The 2019 IRP Update focuses on the 2018 / 2019 AMPs which are expected to be published in Spring of 2020.

The AMPs main document structure consists of an "Overall Main Sections" component followed by individual AMPs covering 14 different asset class as listed:

Water

- Supply Plants
- Supply Dams
- Chambers & Booster Stations
- Transmission Mains
- Distribution Mains
- Service Reservoirs

Wastewater

- Treatment Facilities
- Pumping Stations
- Gravity Sewers
- Force mains



Figure 16 – Asset Management Plans

Stormwater

- Management Structures
- Gravity Sewers
- Cross Culverts
- Driveway Culverts and Ditches

The AMPs provide the following key inputs to the 2019 IRP Update:

- Asset inventory and replacement costs for each asset class.
- Asset condition based on age/estimated service life, condition assessments, site inspections, staff knowledge and discussions, depending on the available information for each asset class.
- Recommended 5-year detailed capital expenditures and a 30+ year average forecast for most asset classes.

Figure 16 presents the total program and percentage split of water, wastewater and stormwater projects from the Asset Management Plans as an input into the 2019 IRP Update.

All wastewater, stormwater and water projects from the AMPs are associated with asset renewal needs, and there are no projects within the plans with growth or compliance components.

Further detailed information can be reviewed in [Appendix B.3](#).




Figure 17 – AMPs Wastewater, Stormwater and Water Components

4.1.4 CORPORATE PROJECTS

Halifax Water Corporate Projects serve a variety of purposes such as maintaining/updating information systems, building capital improvements, improving customer experience with Halifax Water, among others. Corporate Projects can be classified into seven categories:

- Information Technology (IT)
- Geographic Information System (GIS)
- Asset Management
- Facility
- SCADA & Other Equipment
- Fleet
- Studies, Programs & Initiatives

Figure 18 presents the total program and percentage split of water, wastewater and stormwater corporate projects in the 2019 IRP Update.

The majority of the corporate projects are associated to asset renewal needs with 85%, 89% and 93% for the wastewater, stormwater and water systems respectively. The growth component of the corporate projects for the three systems varies from 6% to 15%, while the compliance component remains the lowest percentage varying from 0.3% to 1%.




Figure 18 – Corporate Projects




Figure 19 – Corporate Projects Wastewater, Stormwater and Water Components

4.2 DEMAND SIDE MANAGEMENT AND SUPPLY SIDE MANAGEMENT REVIEW

As part of the 2019 IRP Update process a review of demand side management (DSM) and supply side management (SSM) practices and measures was undertaken. The purpose of the DSM/SSM exercise was to review and evaluate DSM and SSM measures currently in place by Halifax Water, and consider additional measures implemented by other utility companies and municipalities. Through collaboration with Halifax Water staff, each identified measure was reviewed and evaluated to provide recommendations for improvements and select new measures for potential future implementation.

Demand side management (DSM) relates to the management of water, wastewater and stormwater at the point of use, that affects customer usage and education, utility rates, regulations and private property connections. DSM activities are those that occur on the customer side of the property boundary. DSM measures are guided and supported by Halifax Water (in some cases in association with HRM), however, the rate of success is determined by the level of customer involvement. Challenges for DSM are mostly related to implementation costs and inconvenience to customers.

Supply side management (SSM) relates to the management of water, wastewater and stormwater infrastructure to meet or exceed customer demands including system optimization, upgrades, and infrastructure repair and replacement. SSM activities are those that occur at Halifax Water facilities or within the public right-of-way. SSM measures are implemented by Halifax Water (in some cases in association with HRM), therefore, the rate of success is determined by the planning, design and operation of the infrastructure. Challenges for SSM are mostly related to infrastructure and energy costs.

The DSM/SSM measures review process involved the following steps:

1. Review of existing measures currently planned or implemented by Halifax Water.
2. Review of best practices from other utilities/municipalities within and outside Canada.
3. Evaluating the long list of DSM/SSM measures in collaboration with Halifax Water.
4. Identification of potential new measures and/or enhancement opportunities.

The review demonstrated that Halifax Water is currently implementing a wide range of measures across all DSM/SSM categories covering all systems (water, wastewater, stormwater) and driver type (growth, asset renewal, compliance).

Potential enhancement opportunities and recommendations to current DSM/SSM measures were discussed during the review process. The following enhancement opportunities and recommendations resulted from the DSM/SSM review and discussion:

- Development of key performance indicators (KPIs) and targets in accordance with Halifax Water's goals and objectives, drivers and level of service.
- Further enhancement of public education including tailoring initiatives for specific area needs, keeping the public informed, and promoting collaborative work with government and organizations.
- Continuing the collection of data that support DSM/SSM measures.
- Improving integration between organizations/jurisdictions, programs/initiatives, data and processes.
- Explore revisions to the Rules and Regulations to allow more flexibility to undertake private side works to meet the goals of RDII reduction.

More detailed information about the DSM/SSM review process, findings and recommendations can be found in Appendix A.2.

4.3 DATA / GIS LINKAGE AND GEOSPATIAL INTEGRATION

Early in the 2019 IRP update process, it was identified that Data / GIS linkage and Geospatial Integration presented opportunities for improvement and enhancement of the program integration process. Since the 2012 IRP, Halifax Water has taken steps to update their GIS on a continual basis as new information is available. Halifax Water updates their asset management plans on an annual basis incorporating any new data available such as asset condition based on best available information (age / estimated service life, conditions assessments, site inspections, staff knowledge and discussions). During the development of the IRP Update a Data / GIS Linkage exercise was undertaken which consisted of:

1. Compilation of GIS layers for each asset class (e.g. watermains, sewers, facilities)
2. Extraction of asset condition data from AMPs (e.g. age, condition, replacement year)
3. Pairing of condition data to each asset in GIS layers based on Asset ID or spatial location

Table 10 below provides a summary of the GIS features and data from the AMPs that was used in the Data / GIS linkage exercise. The table outlines the names of the files used, as well as the fields used in the pairing process.

Table 10 – Data / GIS Linkage Report

System	GIS Shapefiles			AMP Excel Files		
	Featureclass Name	# Records	Field used to Pair	AMP File Name	Condition Tab	Field used to Pair
Water	TranMainCond AST_water_pipe (Transmission)	566	TMCID	AMP A4 2018-19- Water Transmission Mains	TMC Data	<ul style="list-style-type: none"> • TMCID • Spatial Intersection
	AST_water_pipe (Distribution and Transmission)	15262	Pipekey	AMP A5 2018-19- Water Distribution Mains	Data for AMP	<ul style="list-style-type: none"> • Pipe Key • Spatial Intersection
	AST_water_structure_point	372	NAME	AMP A3 2018-19- Water Chambers and Booster Stations	AMP Data	NAME
			NAME	AMP A6 2018-19- Water Reservoirs	A5- Reservoirs	MASTER-ID/OBJECTID
			MASTERID	AMP A1 2018-19- Water Supply Plants	AMP Data	MASTER-ID/OBJECTID
Collection System	HWCS_pipe	82192	CS_PipeID	AMP B3 2018-19- Wastewater Gravity Sewers 20June2019	Data for AMP	Pipe ID
				AMP B4 2018-19- Forcemains_16 May	GIS data HW Pipes	
				AMP C2 2018-19- Stormwater Gravity Sewers Revised 17 May	Pipe Data	
				AMP C3 2018-19- Stormwater Cross Culverts	Merged Data	
	HWCS_storm_mgmt_structure	92	CS_SWM STRUCTURE ID	AMP C1 2018-19- Storm-water Management Structures	2018 19 AMP	Stormwater Mgmt Structure ID
	HWCS_treatment_facility	18	CS_TREATMENT FACILITYID	AMP B1 2018-19- Wastewater Treatment Facilities	-	Data for IRP

The data / GIS linkage exercise resulted in a new GIS data set of Halifax Water systems that contains information from GIS and AMPs. This new data set was used to develop a Geospatial Integration Tool to support the program integration process.

4.3.1 GEOSPATIAL INTEGRATION TOOL

The geospatial integration tool was built using QGIS to combine multiple sources of GIS layers and datasets into one GIS interface with all relevant information.

Figure 20 depicts a sample of the interface of the geospatial integration tool.

A sample of the datasets that were used in the development of the geospatial integration tool include:

- Master Plan capital projects – linear and vertical water and wastewater projects.
- RDII Reduction Areas – as outlined in the Infrastructure Master Plan.
- Existing infrastructure – asset inventory and condition resulted from the data / GIS linkage exercise.
- Areas of interest – growth areas, LoWSCA areas, WWMP areas, HRM Flood study sites, etc.
- Transportation and Transit – Location of transit and transportation features and planned projects.
- Street closures – Location of planned street closures that might affect project implementation.
- HRM Capital Projects – location of HRM capital projects (2019).
- Base layers – Base layers that provide context of the natural environment, municipal boundaries, land parcels, etc.




Figure 20 – Geospatial Integration Tool

The geospatial integration tool was used to determine areas with potential for integration. These areas were determined spatially by visually inspecting different zones in Halifax Water systems with planned capital projects and existing infrastructure in poor condition. The GIS interface allowed for easy review of projects, asset condition, extent, location, among other details; and to identify any opportunities for project bundling or coordination. **Figure 21** below provides an example of use of the geospatial integration tool to identify integration opportunities.




Figure 21 – Geospatial Integration Opportunity Example

4.4 EXPENDITURE ANALYSIS AND COSTING REVIEW

For the 2019 IRP update, the AMPs were used to determine the majority of the asset renewal expenditure needs for the existing water, wastewater and stormwater systems. A review of the level of detail of the data contained in the AMPs for each asset class was completed, particularly regarding: condition source, replacement costs and granularity of the data.

The results from the asset renewal expenditure needs analysis identified an opportunity to review, refine, update and integrate base unit costing for the three foundational studies (Infrastructure Master Plan, Compliance Plan and AMPs). Cost estimation practices have an impact on capital costing, new infrastructure costs, target reinvestments rates, RDC rates and assumptions incorporated into the capital programs. Therefore, it was considered vital that the cost estimating assumptions for asset renewal, growth and compliance driven projects were aligned.

All AMPs for each asset class were reviewed to establish confidence in the data sources. Through discussions with the Halifax Water team, the following five asset classes were identified to have low confidence in replacement costs and could benefit from further assessment: Water Supply Plants, Wastewater Treatment Facilities, Wastewater Pumping Stations, Wastewater Force mains, Stormwater Management Structures.

The goals and objectives for the costing analysis were:

- Improve the asset classes with low confidence in their replacement cost estimate;
- Check the alignment between Halifax Water Infrastructure Master Plan and Asset Management Plans costing approaches;
- Provide recommendations for unit costs and replacement cost adjustments if necessary.
- Provide confidence, transparency and traceability to support funding streams.

The costing analysis consisted of a high-level desktop exercise completed to compare multiple sources of costing data / information. The analysis approach can be summarized in the following seven steps:




Figure 22 – Costing Analysis Approach

4.4 EXPENDITURE ANALYSIS AND COSTING REVIEW CONTINUED

The following sources of information were used in the costing analysis are presented below in **Table 11**.

Table 11 – Costing Analysis Sources

Source	Description
Halifax Water AMP	Replacement costs and unit costs provided in the AMPs are described in the Expenditure Needs Analysis workbook provided in Appendix A.3
Halifax Water Infrastructure Master Plan	The MP Rates were established in the preparation of the Functional Plan and WRWIP, and further updated during the Master Plan development process.
Modeling the Cost of Infrastructure Environmental Protection Agency (EPA)	United States EPA completed an update to a previous study in 1999 to estimate the 20-year capital investment needs of public water systems by developing cost curves for various water and wastewater assets.
Water and Wastewater Asset Cost Study- Ministry of Public Infrastructure Renewal (MPIR)	The Ontario MPIR completed a study in 2005 to provide life cycle costing information to assist in determining investment needs in the water and wastewater sector.
Various Municipal Replacement Cost and Unit Cost Data	GMBP leveraged their knowledge base of information from past projects and experiences. This included Ontario municipalities of populations ranging from less than 25 thousand to over 2 million. Data sources were collected from AMPs, MP, State of Infrastructure re-ports, etc. Further descriptions were included in the IRP Cost Comparison provided in Appendix A.3 .

The costing analysis was carried out as a collaborative effort with Halifax Water's asset management team which used the information to update the 2018/2019 AMPs. In addition, the Infrastructure Master Plan also benefited from this exercise with the adjustment of cost unit rates to be aligned with the AMPs.

The AMPs expenditure analysis costing analysis ultimately resulted in the following recommendations:

- Annual review of all unit rates (linear and vertical)
- Enhance cost estimating approach for vertical facilities (e.g. pumping stations, storage facilities, treatment plants)
- Develop a more detailed approach for complex facilities that may include unit rates for subcomponents
- Continue benchmarking construction projects

More detailed information on the AMPs expenditure analysis and costing review exercise is provided in Appendix A.3.

4.5 PROGRAM INTEGRATION

The Long-Term Capital Plan (LTCP) was developed based on a six-step approach for program integration as shown below in **Figure 23**.




Figure 23 – LTCP: Program Integration Approach

Step 1: The first step was the development of the **Baseline Program** by compiling all individual projects from the study inputs into one comprehensive table including project specific information such as cost, year, drivers, driver splits, objectives.

Step 2: The second step was to **Categorize Infrastructure Master Plan Projects** based on critically and timing to identify which projects could be advanced, delayed or have a fixed timing.

Step 3: The third step was to identify **Candidates for Integration**. At this stage the objective was to identify projects that were happening at the same time and could be coordinated / bundled together, have critical timing, could align with state of good repair program, and/or require coordination with external influences. The Geospatial integration tool presented in **Section 4.3** was used in this step to identify candidate projects for integration.

Step 4: The fourth step was the **Program Integration**. This step involved workshops with Halifax Water project team to review candidate projects for integration, provide an update on the process and confirm the integration program and approach.

Step 5: The fifth step was the **Smoothing of the Program**. Once the program was reviewed and integration opportunities were confirmed, a smoothing process was completed to bring a realistic aspect to the program for implementation. This process is presented in more detail in **Section 4.5.2**.

Step 6: The last step of the program integration process was the development of the **Final Program** and recommendations. The final program was provided to Halifax Water for inclusion in their financial model for debt, rate structure and affordability analysis.

4.5.1 DECISION MAKING TREES

During the development of the 2019 IRP Update various Decision Trees were developed to guide the program integration process. The first decision tree was developed and used as part of **Step 2** to categorize each individual Infrastructure Master Plan project based on criticality of timing. The result of this process was a comprehensive list of Master Plan projects categorized based on the four project types:

Type A – Flexible Timing

Type B – Project can be delayed but not advanced

Type C – Project can be advanced but not delayed

Type D – Fixed timing as per Master Plan

Each project was individually reviewed and categorized and comments about timing, critical paths, relationship with other projects, among others; were added to inform the integration and smoothing process, but also for future use for Halifax Water in their financial modelling and analysis.




Figure 24 – Decision Making Tree (Step 2)

For each type of project (A,B,C,D) an additional decision tree was created as part of **Step 3**. The decision tree was used with support of the geospatial integration tool (**Section 4.3**) to identify potential candidate projects for integration. A sample decision tree for **Step 3** is presented further in **Figure 25**.

Sample Decision Tree




Figure 25 – Sample Decision Making Tree (Step 3)

4.5.1 DECISION MAKING TREES CONTINUED

This process aimed to:

- Identify projects that were happening at the same time in order to coordinate or bundle together
- Identify related projects that have critical path timing
- Identify projects that could align with the state of good repair programs, but that are not currently identified as individual projects
- Identify projects which timing could be moved to better align with other initiatives / projects
- Identify projects that require coordination / tracking with external influences

The Geospatial integration tool presented in **Section 4.3** was used in this step to identify candidate projects for integration.

The result of this process was a capital program that contained proposed new timing for specific projects as well as a list of new candidate projects from the state of good repair program that can be better aligned. This program was then further refined through **Steps 4 to 6** of the program integration process.

4.5.2 PROGRAM SMOOTHING

The smoothing of the IRP Capital Program is one of the last steps of the program integration process. The smoothing exercise cash flows the projects to better represent how the capital program will be delivered.

The program smoothing process consisted of flattening the cost expenditure peaks in the program by adding projects splits for multiple year expenditures to account for projects phases such as preliminary design, detailed design and construction over two years. This process was applied to projects greater than \$1 million dollars that were not already smoothed or programmed for multiple years.

The smoothing process followed a set of rules defined by Halifax Water and further refined through the development of the 2019 IRP Update. The process uses a ranking system for the application of the rules and every decision has been flagged and documented to be traceable and defendable.

Figure 26 presents the 2019 IRP program before and after the smoothing exercise was completed.



Figure 26 – IRP Capital Program Before and After Smoothing

4.5.3 2019 IRP UPDATE CONSULTATION

During the development of the 2019 IRP Update, stakeholder involvement and input was an important aspect of the consultation process. The main consultation teams involved members of Halifax Water project team, Halifax Water Directors, Halifax Water Board, and NSUARB Consultants. GM BluePlan acted as a liaison with the consultation teams to confirm key aspects in the development of the IRP update such as data gaps, regulatory requirements, study inputs content and limitations, ongoing and future planned work, among others.

As part of the consultation process, key meetings were held throughout the duration of the project to agree on key subjects such as the IRP vision and scope of the update, and also to inform parties on progress and decisions as they were made. The overall consultation process is covered in this section.

4.5.3.1 Halifax Water Staff & Directors

The GM BluePlan team worked closely with Halifax Water to ensure proper execution of this project. It was the Project team's intent to be in regular contact with Halifax Water throughout the duration of the project and ensure that other parties were consulted and updated appropriately. For this purpose, weekly meetings were set up to ensure Halifax Water team was kept informed on progress and directly involved in all decisions. In addition, to share documents between those involved in the project, Halifax Water created an IRP Update Project Site on SharePoint enabling concurrent access to key project documentation.

The Halifax Water project team has been involved in all meetings and workshops with Halifax Water Board and NSUARB Consultants. During the project meetings and workshops, it was GM BluePlan's role to present study findings and solicit technical input.

To support the communication and consultation process, GM BluePlan issued the following documents to Halifax Water:

- Project Charter – Outlining project purpose, business objectives, scope, deliverables and the governance structure.
- Project Management Plan – Outlining the project background, project management objectives, schedule budget, quality assurance, health & safety, risk management and the communication & information management approach.
- Revised Project Schedule, as required.

4.5.3.2 Halifax Water Board

As discussed in section 2.2.3, Halifax is governed by the Halifax Board of Commissioners. Several meetings with the Halifax Water Board were held during the development of the 2019 IRP update. At the outset of the project a kick-off meeting was held to introduce the project. Subsequent meetings provided updates of the process and presented the outcome of the IRP Update including the long-term capital plan and recommendations.

4.5.3.3 Nova Scotia Utility and Review Board (NSUARB)

NSUARB is an independent body with both regulatory and adjudicative jurisdiction. The NSUARB provides general supervision over all public water utilities within the Province, including involvement in rate setting, approval of large capital expenditure projects and reviewing complaints.

Consultant representatives of the NSUARB have been involved in several other Halifax Water studies and initiatives such as the Infrastructure Master Plan and Compliance Plan. In the context of the IRP Update, to keep NSUARB informed several meetings occurred throughout the project. During the meetings progress updates were presented, responses to previous questions from NSUARB were provided and recommendations from the NSUARB representatives were discussed and incorporated into the overall project.

5.0 LONG-TERM CAPITAL PLAN

5.1 2019 IRP UPDATE CAPITAL PROGRAM

The long-term capital plan generated through the completion of the 2019 IRP update amounts to a 30-year program of \$4,054 million. This represents a net present value (NPV) of \$2,691 million and a yearly average of approximately \$135 million for the next 30 years.

The timing of projected expenditures (in \$2019 dollars) is presented in **Table 12** and **Figure 27** which shows significant expenditures above the yearly average at key points in the next 30 years related to the following projects:

- Mill Cove Wastewater Treatment Plant Capacity Upgrade (2020-2022)
- Lake Major and J.D. Kline WSP upgrades (2020-2030)
- Pockwock Transmission Twinning – 60" (2028-2031)
- Future Enhanced Overflow Program (2033-2042)
- Dartmouth WWTF Upgrade to meet Wastewater Systems Effluent Regulations (2035-2038)
- Herring Cove WWTF Upgrade to meet Wastewater Systems Effluent Regulations (2036-2039)
- Halifax WWTF Upgrade to meet Wastewater Systems Effluent Regulations (2037-2040)

Table 12 – 2019 IRP Recommended Expenditure (30-Year)

System	2019-2028	2029-2038	2039-2048	Total
Wastewater	\$652 M	\$948 M	\$687 M	\$2287 M
Stormwater	\$63 M	\$134 M	\$108 M	\$306 M
Water	\$530 M	\$539 M	\$391 M	\$1461 M
Total	\$1245 M	\$1621 M	\$1187 M	\$4054 M
30-year Average	\$135 M			

The projected expenditures by driver and system are shown in **Figure 28**. Approximately 68% of the projected expenditures are associated with asset renewal and the remainder split between 14% for growth and 18% for compliance. 56% of the projected expenditures are associated with the wastewater system, while 36% are associated with the water system and 8% with the stormwater system.




Figure 27 – 2019 IRP Recommended Expenditure by Year





Figure 28 – 2019 IRP Recommended Expenditure by Driver

5.1 2019 IRP UPDATE CAPITAL PROGRAM CONTINUED

The timing of projected expenditures by driver (in \$2019 dollars) is presented in **Figure 29** which shows the fluctuation of asset renewal requirements across the 30-year period. Growth projects are more concentrated in the first 4 years mainly related to Infrastructure Master Plan projects including the Eastern Passage new gravity pressure sewer, Mill Cove WWTF capacity upgrade, Fairview Cove tunnel and BLT diversion projects. Compliance projects are mostly concentrated between 2035 and 2040, mainly related to the WWTF upgrades to WSER requirements and the Enhanced Overflow Program.




Figure 29 – 2019 IRP Recommended Expenditure by Year

The timing of projected expenditures for the wastewater, stormwater and water systems (in \$2019 dollars) is presented in **Figure 30** which shows the fluctuation of expenditures requirements across the 30-year period.

The wastewater system presents an average expenditure need of \$76 million over the 30-year period. This is the highest average among all three systems due the significant large projects such as the Mill Cove WWTF Capacity Upgrade and various WWTF upgrades to meet WSER.

The stormwater average expenditure need remains pretty steady around \$10 million with no major fluctuations across the 30-year period.

5.1 2019 IRP UPDATE CAPITAL PROGRAM CONTINUED




Figure 30 – 2019 IRP Recommended Expenditure by System

The water system presents an average expenditure need of approximately \$49 million with some high peak fluctuations around 2035-2036 related to Pockwock Transmission main twinning, Bedford-Burnside System Interconnection phases 1 & 2, and some high asset renewal requirements for water distribution and transmission mains.

5.1.1 2019 IRP UPDATE 5-YEAR EXPENDITURE NEEDS

The short-term capital plan generated through the completion of the 2019 IRP update amounts to a 5-year program of \$771 million. This represents a yearly average of approximately \$155 million for the next 5 years which is approximately \$20 million higher than the 30-year average of \$135 million identified for the total program to 2048.

The timing of projected expenditures (in \$2019 dollars) is presented in **Table 13** and **Figure 31** which shows significant expenditures above the yearly average at key points in the next 5 years.

Table 13 – 2019 IRP Recommended Expenditure (5-Year)

System	Y1 2019	Y2 2020	Y3 2021	Y4 2022	Y5 2023
Wastewater	\$31 M	\$79 M	\$158 M	\$137 M	\$55 M
Stormwater	\$10 M	\$8 M	\$5 M	\$8 M	\$9 M
Water	\$34 M	\$28 M	\$77 M	\$72 M	\$59 M
Total	\$75 M	\$114 M	\$241 M	\$218 M	\$123 M
5-year Average	\$154 M				




Figure 31 – 2019 IRP Recommended Expenditure (5-Year)

5.1.2 2019 IRP COMPARISON WITH THE 2012 IRP

Since the 2012 IRP Halifax Water has actively implemented programs and initiatives that have better informed the decision-making process and the development of the foundational studies of the 2019 IRP. The result of closing many of the gaps and assumptions made in the 2012 IRP has resulted in fundamental changes in the 2019 IRP. This makes a straight comparison of the two plans difficult. The following section summarizes a high-level fiscal comparison and then outlines the factors that have impacted the resulting differences.

In order to compare the 2012 IRP and 2019 IRP programs, the 2012 IRP program was inflated to 2019 dollars using an annual 2 percent inflation rate per year from 2012 to 2019.

Figure 32 and **Figure 33** present the comparison of the 2012 and 2019 Integrated Resource Plans in 2019 dollars.

Integrated Resource Plan (2019 \$)	2012	2019
Total Program	~ \$4,506 M	~ \$4,054 M
30-year Net Present Value	~ \$2,901 M	~ \$2,691 M
30-year Average	~ \$150 M	~ \$135 M




Figure 32 – 2012 Integrated Resource Plan




Figure 33 – 2019 Integrated Resource Plan

5.1.3 2019 IRP COMPARISON WITH THE 2012 IRP CONTINUED

The effect of comparing the 2019 IRP to the 2012 in 2019 dollars results in approximately a 10% reduction in overall expenditure. The percent split between drivers for the 2019 IRP when compared to the 2012 IRP resulted in a 13% increase related to asset renewal, 7% decrease in growth and a 6% decrease in compliance.

The main factors for differences in the two programs are:

- The 2012 IRP was predicated on broad assumptions due to the extent of data gaps at the time. The 2019 IRP's foundational studies and inputs are new, having filled many of the previous gaps of the 2012 IRP. This has generated a fundamentally different plan.
- The 2012 IRP inputs included the Regional Wastewater Functional Plan (RWFWP) and Halifax Water Capital Budget. At that time, no formal Asset Management Plans, Compliance Plan, or Water Master Plan were in place. The 2019 IRP has benefited from the work Halifax Water has completed to close data gaps identified in 2012 which translated to improved study inputs: Water and Wastewater Infrastructure Master Plan, Compliance Plan, and Asset Management Plans.
- The results of the driver allocation splits between the 2019 and 2012 programs are considerably different. This can be attributed to the detailed programs and analysis completed in the inputting studies and plans. The subsequent infrastructure strategies, programs and projects have resulted in a much more integrated program that can often benefit more than one driver. The improved level of detail available for the 2019 IRP has also enabled a more informed driver allocation compared to the 2012 IRP.
- The 2012 IRP program has significant peaks in expenditure related to WWTF and enhanced overflow program, among other projects. While the 2019 IRP Update program contains the same projects, the program has been smoothed to provide more realistic timing that accounts for project implementation phases such as preliminary design, detailed design and construction.
- Both the 2012 IRP and 2019 IRP propose long-term capital programs with 30-year horizons. However, the time period/horizon have changed and the 2019 IRP looks further than the previous IRP.
- The 2012 IRP program included Operation and Maintenance (O&M) components, while the 2019 IRP program does not include O&M components in the capital program.

The 2019 IRP demonstrates the value of master planning as a part of Halifax Water's continuous improvement and adaptive planning process. Further, these variations support the value that the efforts undertaken in the intervening years have contributed to this iteration of the IRP and creates a model for the supporting inputs to future IRP updates.

5.1.3 2019 IRP UPDATE TIMELINE OF KEY PROJECTS AND PROGRAMS

Figure 34 and **Figure 35** present a timeline to provide an overview of the total IRP program and highlights the key water, wastewater and stormwater infrastructure projects, studies and programs that are recommended for the next 30 years.

WATER INFRASTRUCTURE INTEGRATED RESOURCE PLAN TIMELINE 2019-2048




Figure 34 – Water Infrastructure IRP Timeline 2019-2048

WASTEWATER & STORMWATER INFRASTRUCTURE INTEGRATED RESOURCE PLAN TIMELINE 2019-2048




Figure 35 – Wastewater & Stormwater Infrastructure IRP Timeline 2019-2048

5.1.4 2019 IRP LONG-TERM CAPITAL PLAN TABLES

The 2019 IRP Long-Term Capital Plan is presented in detail in [Appendix C](#). The LTCP contains project descriptions, estimated total cost, proposed year in service, source of project / program, drivers, driver split allocation and objectives.

5.1.5 INTEGRATED RESOURCE PLAN STRATEGY TO ACHIEVE OBJECTIVES

The projects and studies that form the Integrated Resource Plan program evidence the intent of Halifax Water to achieve each of the 14 Integrated Resource Plan objectives ([Section 3.0](#)).

Every project and study contained in the Integrated Resource Plan program table has been assessed to identify which objective(s) the project or study helps to achieve. Where a project addresses multiple objectives, the association was ranked to identify the primary, secondary and tertiary objective to which the project applies.

The analysis was completed to support the identification of strengths and weaknesses in the program, helping to identify additional recommendations to achieve progress towards the objectives. The ring chart below ([Figure 36](#)) shows graphically the projects that address each objective. The colours show which objective group (compliance, renewal, growth) the specific objectives belong to.



Figure 36 – Projects and Studies that Address the Integrated Resource Plan Objectives.

The results of the analysis can be summarized as follows:

- The three drivers of Growth, Renewal and Compliance are all adequately addressed by the Integrated Resource Plan Program.
- Objectives 7, 10 and 13 have the most projects directly or indirectly aimed at meeting or addressing each of the three main drivers of Compliance (Objective 7), Asset Renewal (Objective 10) and Growth (Objective 13).
- Objectives 2,3 4, 5, 8 have few projects aimed at addressing them and all are related to the Compliance driver.
 - Objective 2,3,4,5 all relate to regulatory compliance which is generally achieved and successfully maintained by Halifax Water. These objectives do not require numerous projects to address them.
 - Objective 8 relates to meeting future stormwater compliance. This could be attained with a review of future compliance needs for stormwater systems which could be part of the next iteration of the compliance plan.

Table 14 outlines the approach to meet each of the 14 objectives, highlighting only the key actions required.

5.1.5 IRP STRATEGY TO ACHIEVE OBJECTIVES CONTINUED

Table 14 – Integrated Resource Plan Key Actions to Achieve Objectives

Objective		Key Integrated Resource Plan Components
1	Meet or exceed current Nova Scotia Environment WWTF Permit to Operate Requirements	<ul style="list-style-type: none"> Implement Compliance Plan and Infrastructure Master Plan Project recommendations.
2	Meet or exceed current Nova Scotia Environment WSP Permit to Operate	<ul style="list-style-type: none"> Fully compliant. Continue review through the Compliance Plan, Water Quality Master Plan and Infrastructure Master Plan updates.
3	Meet Current Overflow Compliance (Monitor and Report)	<ul style="list-style-type: none"> Fully compliant with current requirements. Maintain up to date hydraulic model with 5 year Infrastructure Master Plan updates Implement CSO flow monitoring program.
4	Meet or exceed Future WWTF Compliance	<ul style="list-style-type: none"> Implement Infrastructure Master Plan WWTF expansion projects (Dartmouth, Halifax and Mill Cove). Implement compliance plan projects to ensure compliance with future WSER requirements.
5	Meet or exceed future drinking water compliance	<ul style="list-style-type: none"> Implement Infrastructure Master Plan and Compliance Plan projects. Complete review of future scenarios.
6	Meet future overflow compliance	<ul style="list-style-type: none"> Complete Infrastructure Master Plan CSO and SSO Management Plan studies and identify discharge frequency and volume targets for CSO's. Implement Infrastructure Master Plan I/I reduction projects considering pre and post CSO discharge impact assessment.
7	Endeavour to provide existing systems that are adequately sized to meet Halifax Water Level of Service	<ul style="list-style-type: none"> Update water hydraulic model in 2020 and update/recalibrate water and wastewater models every 5 years. Complete Stormwater Capacity Evaluation.
8	Meet Future Stormwater Quality Compliance	<ul style="list-style-type: none"> Complete study to review potential future regulatory scenarios.
9	Ensure planning and sizing of infrastructure considers the impact of climate change	<ul style="list-style-type: none"> Implement Climate Change framework.
10	Implement optimal level of asset re-investment	<ul style="list-style-type: none"> Complete condition assessment of water mains, sewers, and vertical facilities to enable condition-based renewal planning.
11	Enhance the reliability, redundancy and security of the water, wastewater and stormwater systems with attention to high risk and critical areas	<ul style="list-style-type: none"> Implement Water Infrastructure Master Plan preferred strategy, specifically transmission twinning, system interconnections, safe yield and back up supply studies.
12	Reduce energy consumption, operating costs and GHG contributions	<ul style="list-style-type: none"> Update Energy Management Strategy including the assessment of current GHG generation and establish targets for reduction.
13	Provide regional water, wastewater and stormwater infrastructure needed to support planned growth	<ul style="list-style-type: none"> Implement Infrastructure Master Plan preferred servicing strategy. Ensure 5-year updates to re-align strategy with updated planning and development information.
14	Manage flow and demand to maximize capacity for growth and minimize the need for new hard infrastructure	<ul style="list-style-type: none"> Implement I/I and Sewer Separation projects from Infrastructure Master Plan preferred servicing strategy. Enhance public education campaigns on water usage and savings.

5.1.5.1 Climate Change

Climate change is a prominent consideration for Halifax Water. Through the Infrastructure Master Plan, a Climate Change Assessment Framework was developed to provide a consistent approach of assessing the threats of climate change on water, wastewater and stormwater infrastructure.

The Infrastructure Master Plan considered climate change throughout the development of the projects and studies that form the preferred servicing alternative. Every infrastructure project was assessed using a design rainfall event that makes an allowance for the predicted increased rainfall intensities.

It is important for Halifax Water to build on these initiatives and begin implementing the framework. The following provides an outline of the recommended implementation plan.

- Climate Change Infrastructure Assessments on Asset Groups – 2020-2023 (4 years)
 1. Water Supply Plants and Dams (AMP A1 and A2)
 2. Wastewater Treatment Facilities (AMP B1), Wastewater Pumping Stations (AMP B2) and Water Chambers and Booster Stations (AMP A3).
 3. Water Reservoirs (AMP A6) and Stormwater Management Structures (AMP C1)
 4. Water Transmission Mains (AMP A4), Distribution Mains (AMP A5), Wastewater Gravity Mains (AMP B3), Wastewater Force mains (AMP B4), Stormwater Gravity Sewers (AMP C2), Stormwater Cross Culverts (AMP C3)
- Develop Climate Change Action Plans following sequence above – 2024-2027 (4 years)
- Implement Action Plan on Priority Basis – 2028+

It is important to note that Halifax Water takes climate change into consideration on a project by project basis. For instance, projects submitted for funding consideration under the current Investing in Canada Infrastructure Federal Provincial Program require a formal audited review under the “Climate Lens” for Climate change adaptation and mitigation.

6.0 INTEGRATED RESOURCE PLAN IMPLEMENTATION

6.1 IMPLEMENTATION PLAN

The 2019 IRP Update has established a 30-year capital program. The total capital program is approximately \$4,054 million equating to \$135 million per year average. This substantially exceeds the five-year average of the approved capital budget of approximately \$73.6 million (**Table 15**). Similar to the 2012 IRP, this presents challenges with regard to impact on rates, the availability of other funding sources, and the availability of Halifax Water's institutional capacity to manage this increase in capital delivery volume.

Successful implementation of the 2019 IRP Update recommendations will require the following key steps:

- Elevate critical projects to ensure priorities across all three drivers are addressed
- Utilize the 2019 IRP Update capital program as the foundation for yearly capital and operating budgets for Halifax Water
- Undertake additional cash flow analysis for projects to ensure costs and effort are apportioned across the appropriate time period
- Continually increase capital project delivery year over year while at the same time continually increase the Halifax Water project team resources including staff and project management/delivery tools
- Engage the consulting and construction industry in order to support the level of construction needed to meet the infrastructure needs
- Review procurement and project delivery models to ensure allocation of resources is not delayed

The next step in implementation will be to examine the fiscal and practical impacts of the recommended 2019 IRP Update, evaluate opportunities for external infrastructure funding, and assess the capital delivery resource needs.

6.1.1 RESOURCE NEEDS

The 2019 IRP Update has identified that an average of \$135M per year is required to address all asset renewal, compliance and growth needs. The capital program requirement not only requires financial capacity, but also resource capacity from the Halifax Water staff, consulting engineering firms, and construction firms.

Table 15 summarizes the annual approved capital budget over the past 5 years and the corresponding number of Halifax Water capital delivery staff and consultant fees that have been required to deliver the program. The five-year average Capital Budget of \$73,560,240 has required an average of 39 staff and an average of \$9,952,365 of supporting consultant fees. Based on the capital program average of \$135 M per year, Halifax Water would need to significantly increase project delivery capacity through both staff increases and project delivery method improvements.

Table 15 – Historical Approved Capital Budget and Capital Delivery Resources

Year	Annual Approved Capital Budget	HW Capital Delivery Total Staff #	Consultant Fees	% of Cap Consultant Fees
2014/15	\$60,845,200	37	\$6,317,175	10%
2015/16	\$57,222,000	41	\$9,246,243	16%
2016/17	\$66,778,000	39	\$14,884,721	22%
2017/18	\$109,508,000	39	\$8,658,023	8%
2018/19	\$73,448,000	40	\$10,655,665	15%
Avg.	\$73,560,240	39	\$9,952,365	14%

The 2012 IRP recommended the evaluation of the adequacy of Halifax Water's existing institutional capacity and staffing to implement the programs and projects identified in the 2012 IRP. In 2014 an Institutional Capacity Assessment was completed by Opus International Consultants which recommended a staff increase of 24-42 full time equivalent staff. A key recommendation of the 2019 IRP Update is to update the Institutional Capacity Study to align with the preferred 2019 IRP program.

6.1.2 LONG-TERM PLANNING STUDY SCHEDULE

Halifax Water continuously undertakes initiatives and programs to maintain, operate and expand its systems while striving to provide world class service to its customers and environment. Halifax Water has taken considerable positive steps since the preparation of the 2012 IRP to the benefit of much more robust and informed 2019 IRP Update. Integral to continued success is to maintain this momentum and cycle of continuous improvement.




Figure 37 – IRP Iterative Planning Process

The iterative planning approach outlined in **Section 1.1** will ensure an ever-stronger base to prepare the next iteration of plans and programs and improve confidence in future recommendations and project delivery.

6.1.2 LONG-TERM PLANNING STUDY SCHEDULE CONTINUED

In order to ensure future updates of the Integrated Resource Plan continue in an efficient manner it is recommended that the various supporting studies be planned and coordinated so that outputs can be integrated together. **Figure 38** provides a study schedule that identifies the critical studies and outlines timing of each to ensure continuity, and efficient and timely delivery of outputs. Key components that direct the timing of the studies are as follows:

- Halifax Water commitment to update the Regional Development Charge every 5 years
- Commitment to RDC stakeholders that project need, costing, design criteria impact are periodically reviewed
- Infrastructure Master Plan Update is required to drive the Regional Development Charge update
- Population planning estimates are required to feed into hydraulic models
- Hydraulic models used in Infrastructure Master Plan updates
- Infrastructure Master Plan updates required to capture/recalibrate starting point and projections and review project need, triggers and phasing
- Key supporting studies are needed to inform the core studies
- Infrastructure planning is not static but dynamic with changing variables and requires iterative updates
- Studies provide exceptional value when they are a tool to better inform how, when and where to spend billions of dollars




Figure 38 – 5-year Studies Schedule

6.2 RECOMMENDATIONS

Based on the analysis carried out during the development of the 2019 IRP Update, the following recommendations are presented:


Table 16 – 2019 IRP Recommendations

Stakeholder Outreach and Education	
1	Continue and enhance public outreach with stakeholders and public to market Halifax Water's objectives, educate customers and target efficiencies related to water, wastewater and stormwater servicing
2	Enhanced communication with NSE to ensure current compliance and appropriate future planning of regulatory issues
Implementation Programs	
3	Implement IRP Capital Program- (Water and Wastewater Infrastructure Master Plan, Asset Management Plans and Compliance Plan)
4	Utilize IRP program and undertake financial modelling, select preferred program and implement
5	Continue implementing Wet Weather Management Program
6	Integrate private-side I/I with wet weather management program starting 2020
Data Collection and Tools	
7	Continue on-going GIS system build out and data management
8	Improve asset knowledge base and accuracy through asset management condition assessments and performance <ul style="list-style-type: none">• Expand pumping station performance assessments for the top 50 largest facilities• Use CCTV information to support the development of a sewer predicted condition model• Use condition and break history to support the development of a watermain predicted condition model
9	Maintain and update 2019 IRP integrated GIS program tool
10	Maintain and update water and wastewater hydraulic model development, calibration and build-out <ul style="list-style-type: none">• Water model calibration• Water and Wastewater model update
11	2022 Implement CSO and SSO flow monitoring program and analysis
12	Use established Level of Service and asset performance to prioritize data collection
Studies	
13	Complete CSO and SSO Management Study
14	Complete Water and Wastewater Master Plan Update within 5 years
15	Complete Asset Management Plan Data Updates annually with full written plans updated on 5 year cycle
15	Establish renewal program based on condition and performance data rather than age
15	Prepare project specific AMPs for large vertical infrastructure e.g. WWTFs
16	Complete Compliance Plan Update within 5 years
17	Complete study of potential future regulatory scenarios for water, wastewater and stormwater and feed into the Compliance Plan
18	Update the Energy Management Strategy including the assessment of current GHG generation and establish targets for reduction
19	Update Institutional Capacity Study to align with preferred 2019 IRP program

6.2 RECOMMENDATIONS CONTINUED

Table 16 – 2019 IRP Recommendations (continued)

Cost Estimation	
20	Undertake an annual review of all unit rates (linear and vertical)
21	Enhance cost estimating approach for vertical facilities (e.g. pumping stations, storage facilities, treatment plants)
22	Develop a more detailed approach for complex facilities that include unit rates for subcomponents
23	Continue benchmarking construction projects
Enhanced HW and HRM Coordination	
24	Coordinate periodic planning projection updates to establish “best planning estimates” for use in studies to support timing, phasing and allocation decisions for water, wastewater and stormwater infrastructure
25	Establish predictable timetable to update projections to enable coordinated timing of studies and tool updates
26	Enhance sharing of data and planned project information to enable updating, building and use of the GIS integration tool
27	Enhance coordinated capital project planning improve ability to align projects (ideally both within HW and with HRM)
28	Joint study to explore required steps, viability and impact of enhanced private side I/I reduction and Low Impact Development (LID)
29	Enhance joint educational/marketing to target efficiencies related to water, wastewater and stormwater servicing
Scheduling/Timing	
30	Ensure scheduled alignment of integrated studies to better inform and enable review of integrated planning opportunities (e.g. AMP prepared in advance of Master Plans)
31	Ensure Population projections, hydraulic models, Infrastructure Master Plan and Compliance Plan are updated by 2025



HALIFAX WATER
2019 INTEGRATED RESOURCE PLAN

APPENDIX A.1

BACKGROUND DATA AND LEGISLATION REVIEW



Halifax Water

2019 Integrated Resource Plan

Technical Memorandum #1:
Background Data and Legislation Review

Project No.: 718032



Prepared by: GM BluePlan Engineering
For: Halifax Water
March 2020

Document Revisions

The following is a record of the changes/updates that have been made to the final document:

Version	Changes / Updates	Author	Reviewed	Date
DRAFT	1 st Draft for Review	Sandy Naime	Chris Campbell	March 4 th , 2019
DRAFT	2 nd Draft for Review	Sandy Naime	Chris Campbell James Jorgensen	May 11 th 2019
DRAFT	3 rd Draft for Review	Sandy Naime	Chris Campbell	May 14 th 2019
FINAL DRAFT	Final Draft Report	Sandy Naime	Chris Campbell	Dec 16 th , 2019
FINAL	Final Report	Sandy Naime	Chris Campbell	March 13, 2020

Table of Contents

1	Introduction	1
1.1	Aim.....	1
1.2	Objectives	1
2	Background Information	2
2.1	The 2012 IRP	2
2.1.1	Overview and Aims.....	2
2.1.2	Drivers and Objectives	2
2.1.3	Regulations, Policy and Legislation	3
2.1.4	Available Information and Data Gaps	5
2.1.5	Study Assumptions.....	7
2.1.6	Recommendations.....	7
3	Progress since the 2012 IRP.....	9
3.1	Previous and Ongoing Studies and Initiatives	9
3.1.1	Past Studies and Initiatives.....	9
3.1.2	Ongoing Studies and Initiatives	10
3.2	Frameworks.....	11
3.2.1	Climate Change Management Framework	11
3.2.2	Cost Estimation Framework.....	11
3.2.3	Long-term Planning Framework.....	12
3.3	Initiatives to Close Data Gaps.....	12
3.3.1	Sewer Inspection and Survey Program.....	12
3.3.2	Condition Assessments by Asset Class.....	13
3.3.3	Flow Monitoring Program.....	13
3.3.4	Wet Weather Management Program and I/I Reduction Pilot Area Assessments	18
3.3.5	GIS Update	18
3.3.6	Water and Wastewater Hydraulic Models	19
3.3.7	Lead Service Replacement Program	20
3.3.8	Advanced Metering Infrastructure & Customer Connect Program.....	20
3.3.9	Update Planning Projections and Growth Allocations (completed by HRM)	20
4	The 2019 Integrated Resource Update	21
4.1	Overview	21
4.1.1	IRP Vision	22
4.1.2	Drivers and Objectives	22

4.1.3	Regulation, Policy and Legislation Review	23
4.2	2019 IRP Study Area.....	25
4.3	Existing Infrastructure	26
4.3.1	Water System.....	26
4.3.2	Wastewater System.....	27
4.3.3	Stormwater System	28
4.4	Planning Data and Population Projections	29
4.5	Design Criteria, Level of Service and Cost Estimation Review	29
4.5.1	Design Criteria.....	29
4.5.2	Level of Service.....	30
4.6	IRP Update Study Inputs	30
4.6.1	Infrastructure Master Plan	30
4.6.2	Compliance Plan	31
4.6.3	Asset Management Plan	31
5	Conclusions and Recommendations	33

Appendices

Appendix A: 2012 IRP Assumptions

1 Introduction

The Halifax Regional Water Commission (HRWC), also known as Halifax Water, was the first regulated and publicly owned water, wastewater and stormwater utility in Canada. With a long history dating back to the 1940s, Halifax Water is the water, wastewater and stormwater utility servicing residents of the Halifax Regional Municipality (HRM).

As part of its mandate and services, Halifax Water continuously undertakes initiatives and programs to maintain and operate its systems while striving to provide world class service to its customers and environment. These initiatives and programs require integration into a single capital program that identifies the long-term resource needs and financial expenditures.

Halifax Water retained GM BluePlan Engineering Limited (GM BluePlan) to complete the Integrated Resource Plan (IRP) Update. The IRP Update is a critical project that brings together various initiatives, and programs from separate studies, into a singular integrated capital and financial plan. This study applies the considerations of growth, regulatory compliance and asset renewal to ensure the integrated recommendations achieve the desired service delivery goals, as well as identify any additional gaps and programs required in the long-term plan.

The IRP Update will build on the foundation of the 2012 IRP. The 2012 IRP was developed to identify required programs and resources for a 30-year period covering each of the three drivers: growth, regulatory compliance and asset renewal. The 2012 IRP focused on capital, operation and maintenance costs to meet program and project requirements, developed a planning framework including Halifax Water's business processes, and provided recommendations including the IRP periodical update.

This technical memorandum will review key information provided in the 2012 IRP and any subsequent studies which will set out the foundation for the IRP Update. In addition, it will outline the vision and process for the IRP update, identify recent information to be included and summarize the primary IRP study inputs: Infrastructure Master Plan, Compliance Plan and Asset Management Plan.

1.1 Aim

The aim of the Background Data and Legislation Review Tech Memo is to review the background information available and form the understanding required to successfully complete the IRP Update.

1.2 Objectives

In order to meet the Aim, the following objectives were completed:

- Undertake a review and summary of the previous 2012 IRP including the purpose, drivers and objectives, applicable regulations and policies, available information and data gaps, study assumption and recommendations.
- Describe the progress since the previous IRP such as the studies that have been completed or are currently ongoing, and the frameworks and initiatives that have been implemented.
- Overview of the current scope of the IRP Update to confirm the vision, drivers and objectives, changes in regulations, study area, planning numbers, design criteria, level of service and study inputs.
- Identify key areas for review and update based on the analysis done to date and based on the scope of work for the IRP Update.

2 Background Information

2.1 The 2012 IRP

2.1.1 Overview and Aims

The Integrated Resource Plan (IRP) was developed in 2012, in collaboration with the Nova Scotia Utility and Review Board (NSUARB), to identify required programs and resources for the next thirty years (2013-2043) covering each of the three drivers: growth, compliance and asset renewal. The purpose of the IRP, as defined in the 2012 IRP, is to:

1. Provide the framework for Halifax Water to comprehensively evaluate alternative planning scenarios for its water, wastewater and stormwater services in an integrated fashion and identify the most efficient means of achieving its service goals while meeting all environmental requirements.
2. Provide long-term direction for HRWC and be a platform for comprehensively assessing alternative generic facility and programmatic investment options.
3. Serve as an umbrella under which more detailed, facility or program specific capital investment analyses can take place.
4. Explicitly identify and plan for the management of risks facing HRWC.
5. Provide the Board with the information and context it needs to make fully informed decisions about proposed future capital investments, revenue requirements and rates.

2.1.2 Drivers and Objectives

The IRP focused on three drivers: Growth, Regulatory Compliance and Asset Renewal. **Table 1** presents the three drivers and fourteen objectives that were developed as part of the 2012 IRP. The objectives were based on Halifax Water's level of service, compliance requirements (existing and future), asset renewal requirements, as well as other important considerations such as adaptation to climate change, system reliability and servicing growth.

Table 1 – 2012 IRP Drivers and Objectives

Driver	System	Objective
Compliance	Wastewater	1. Meet current Nova Scotia Environment WWTF Permit to Operate
	Water	2. Meet current Nova Scotia Environment WSP Permit to Operate
	Wastewater	3. Meet current overflow compliance
	Wastewater	4. Meet future WWTF compliance
	Water	5. Meet future drinking water compliance
	Wastewater	6. Meet future overflow compliance
	Stormwater	7. Meet future stormwater quality compliance
Asset Renewal	Water, Wastewater, Stormwater	8. Implement optimal level of asset renewal
	Water, Wastewater	9. Enhance the reliability of critical water and wastewater assets
	Stormwater	10. Ensure existing stormwater system is adequately sized for minor storm conveyance

Driver	System	Objective
	Water, Wastewater, Stormwater	11. Adapt to future climate change
	Water, Wastewater	12. Reduce energy consumption, operating costs and GHG contributions
Growth	Water, Wastewater, Stormwater	13. Provide regional water, wastewater and stormwater infrastructure needed to support planned growth
	Water, Wastewater	14. Manage flow capacity allocations

2.1.3 Regulations, Policy and Legislation

During the 2012 IRP, two provincial bodies were responsible for overseeing Halifax Water: Nova Scotia Utility and Review Board (NSUARB) and Nova Scotia Environment (NSE).

- NSUARB is responsible for approving business plans, significant projects and water/wastewater/stormwater rates.
- NSE is a provincial environmental regulator responsible for public health and environmental safety including drinking water quality and wastewater discharges and overflows.

Certain projects would require additional oversight from Federal departments including Department of Fisheries and Oceans (DFO), Environment Canada (EC) and Health Canada (HC).

The following is a review of key regulations, policies and legislation at the time of the 2012 IRP.

2.1.3.1 Water

In 2012, Nova Scotia Environment (NSE) was the department of the provincial government responsible for overseeing drinking water with emphasis on water works approvals, facility classification and operator certification, drinking water quality, as well as monitoring and reporting.

The following guidelines for water quality were identified in the 2012 IRP:

- Guidelines for Canadian Drinking Water Quality: provides guidance on the physical characteristics of drinking water (e.g. odour, taste) and the acceptable levels of microbiological, chemical and radiological contaminants in drinking water.

At the time of the 2012 IRP, Halifax Water was in accordance with the compliance requirements for all water distribution and treatment facilities.

The 2012 IRP also identified potential changes to guidelines and regulations that were expected to occur in the future:¹

- Canada's Federal-Provincial-Territorial Committee on Drinking Water undertook numerous consultations since 2010 regarding acceptable levels of Dichloromethane and N-nitrosodimethylamine (NDMA) in drinking water. In 2012, the maximum acceptable level for dichloromethane was 0.05 mg/L with a proposed change by Health Canada to 0.015 mg/L. At the time, NDMA did not have "current guidelines" but a guideline of 0.04 µg/L was proposed by Health Canada.

¹ Integrated Resource Plan (Section 4.3), Halifax Water, October 2012

- Reduction of chlorine-based and bromine-based disinfection by-products including Trihalomethanes (THMs) and Haloacetic acids (HAAs). Disinfection by-product precursor removal targets were expected to increase, following similar developments in the US.
- New parameters and lower Maximum Acceptable Concentrations (MACs) by the Federal-Provincial-Territorial Committee on Drinking Water based on new scientific information.

2.1.3.2 Wastewater

In 2012, Halifax Water's wastewater systems required to be in conformity with NSE compliance requirements. The majority (10 out of 14) of Halifax Water's Wastewater Treatment Facilities (WWTFs) were not compliant with NSE Permit to Operate, therefore required upgrades to obtain full compliance.

The 2012 IRP also recognized that WWTFs upgrades would be required to meet the recently promulgated Canadian Wastewater System Effluent Regulations (WSER). The WSER were enacted in June 2012, with the intention to phase out untreated and undertreated wastewater released to water bodies. The regulations apply to systems that treat an average daily volume of at least 100 cubic meters per day. The WSER proposed national performance standards that wastewater systems were expected to meet are shown in Table 2. These performance standards are typically achievable with secondary level of treatment at plants.

Table 2 – WSER National Performance Standards (NPS)¹

Parameter	Concentration
Carbonaceous Biochemical Oxygen Demand (CBOD)	Average \leq 25 mg/L
Suspended Solids (TSS)	Average \leq 25 mg/L
Total Residual Chlorine (TRC)	Average \leq 0.02 mg/L
Un-ionized ammonia as N at $15^{\circ}\text{C} \pm 1^{\circ}\text{C}$	Maximum < 1.25 mg/L

At the time of the development of the 2012 IRP, the WSER were not legislation. The Province of Nova Scotia indicated that it will implement WSER requirements under its jurisdiction through conditions attached to approvals issued by NSE. However, strong guidelines for the management of wastewater were available through the Canadian Council of the Ministers of the Environment (CCME) Strategy for the Management of Municipal Wastewater Effluent. These guidelines were used to inform Halifax Water's adopted level of service for planning studies at that time, in particular the Regional Wastewater Functional Plan (RWWFP).

In addition, the 2012 IRP identified the future regulations for wastewater systems such as the limit of technology (LOT) effluent limits. Advanced nitrogen and/or phosphorus removal potentially to the LOT could be required for wastewater treatment facilities that discharge to receiving waters with limited assimilative capacity. The following are the projected effluents requirements for nitrogen and phosphorous:

- Monthly Total Nitrogen (TN) limit of 5 mg/L as N, based on accepted LOT.
- Monthly Total Phosphorous (TP) limit of 0.1 mg/L as P based on the range of proposed LOT and full-scale plant performance at other WWTFs.

Advanced TN and/or TP removal potentially to the LOT effluent limits will possibly be required for the following WWTFs in the future:²

- Lockview/MacPherson (Fall River)
- Middle Musquodoboit
- North Preston
- Uplands Park
- Wellington
- Frame
- Mill Cove
- Aerotech

2.1.3.3 Wastewater Overflows

In 2012 Halifax Water was required by NSE to monitor and report on Combined Sewer Overflows (CSOs) and Sanitary Sewer Overflows (SSOs). There was no legislative requirement to limit combined or sanitary overflow discharges. However, through the RWWFP study Halifax Water adopted a key level of service to ensure that overflows would not increase in frequency or volume as a result of growth.

The IRP recommended an Enhanced Overflow Control Program to address future overflow control needs.

2.1.3.4 Stormwater

In 2012, there were no regulatory compliance issues for stormwater systems. The IRP noted that the Regional Municipal Planning Strategy commits HRM to preparing a Regional Stormwater Functional Plan (RSWFP) to set out stormwater management strategies to reduce stormwater flows, environmental impacts, groundwater contamination, sediments and contaminant discharge, and inflow/infiltration. It also looks at emerging technologies to improve stormwater management systems and establish best management practices and criteria for both quantity and quality of stormwater discharge. Through the RSWFP, existing roles and jurisdiction of Halifax Water, HRM, NSE and other regulators would also be examined in relation to stormwater management and stormwater system regulations.

It was anticipated that recommendations from the RSWFP would be incorporated into HRM's regulations, policies and programs, which would directly impact how Halifax Water's deliver stormwater services.

2.1.4 Available Information and Data Gaps

The following presents a review of available information and data gaps that were identified from the 2012 IRP.

2.1.4.1 Planning Estimates

The 2012 IRP utilized high level growth estimates that were generated by HRM in collaboration with Halifax Water during the RWWFP. The planning numbers were a key input into creation of the infrastructure requirements in the RWWFP, they were not subject to additional analysis during the 2012 IRP.

- Residential Growth to 2046 = 159,140 persons
- Employment area growth to 2046 = 698.1 ha

² Integrated Resource Plan (Section 4.3), Halifax Water, October 2012

2.1.4.2 Flow Monitoring Data

During the 2012 IRP the Corporate Flow Monitoring Program had not yet been established. At the time, it was identified that more accurate flow monitoring and observed data was required for further development and calibration of wastewater hydraulic models, to better assess sizing and capacity needs of the systems, and to inform other programs such as the inflow/infiltration (I/I) reduction pilot program.

2.1.4.3 Water and Wastewater Model

For the 2012 IRP, a skeletal model of the water distribution network was utilized to assess overall system capacity. The model included primarily the transmission watermains and facilities covering the operating regions serviced by the J.D Kline (Pockwock), Bennery Lake and Lake Major Water Supply Plants (WSP). The model was also utilized to identify the size of transmission main projects required to service future growth or for security of supply. The IRP recognized that the integrated water network model would require continuous refinement and further calibration to support future projects such as the recommended Water System Master Plan.

A skeletal wastewater collection system model was available for analysis of the wastewater system. There were limitations observed with the model, such as limited flow monitoring data for model calibration, limited representation of local infrastructure, and uncertainties regarding the operations of some facilities. As with most hydraulic models, Halifax Water's is an evolving tool, which will improve as more data becomes available. The 2012 IRP identified a series of updates to the model to better inform the analysis and effectiveness of the I/I pilot program.

2.1.4.4 Asset Information

Based on the review of available asset data undertaken in the 2012 IRP, the following asset data gaps were reported:³

- Water, wastewater and stormwater assets were missing from GIS datasets creating spatial gaps in the system. Missing assets in GIS was more significant on the water system with 50% of the watermains missing from GIS, while 18% of sewers and 24% of stormwater pipes were not digitized in GIS. In addition, there was limited stormwater culverts data available on GIS (8km recorded).
- Linear asset information such as material, diameter and age were missing at some extent for water, wastewater and stormwater linear asset classes.
- Breakdown of assets to equipment/component level was not available for pumping stations and treatment plants.
- Significant limitations on asset condition data. Water system linear assets had the most recorded information, while wastewater and stormwater linear assets had little or no recorded condition data. Condition data was not available for vertical infrastructure.
- Historical capital expenditure was not available for all asset classes.
- Limited renewal/rehabilitation data

³ Integrated Resource Plan (Section 4.4.2, Volume 3 Appendix D), Halifax Water, October 2012

2.1.5 Study Assumptions

There were certain assumptions made for the 2012 IRP due to time constraints, data availability and other analysis limitations. The 2012 IRP identified assumptions within each of the following study aspects:

- Compliance – future regulatory compliance.
- Asset Renewal Modelling – assets information such as material, diameter, age, service life estimates, asset renewal capital expenditures and discount rates, etc.
- Demand Reduction Assessment – reduction of sanitary flows and I/I flows, costs for demand reduction activities.
- End-of-Period Value Analysis – assets value, depreciation, asset renewal analysis.
- Enhanced Overflow Control Program Analysis – size of storage, pumping and treatment requirements, cost estimation.
- Financial Modelling – discount rates, project costs and incidental cost and contingency multiplier, capital expenditures, O&M costs, allocation of costs among IRP objectives, etc.

Details on the assumptions for each of the above aspects are included in **Appendix A** of this report.

2.1.6 Recommendations

The 2012 IRP proposed the following 17 recommendations:

1. Implement the IRP components and timing.
2. Finalize the overall integrated planning approach and future schedule (i.e. HRM Regional Plan updates, master plans and Asset Management Assessment, and financial planning) within the IRP framework.
3. Evaluate the adequacy of Halifax Water's existing institutional capacity and staffing to implement the programs and projects identified in the IRP.
4. Continue IRP public outreach with stakeholders and the public at large.
5. Update the IRP periodically, as needed.

Wastewater System

6. Implement I/I Pilot Program and integrate results into Wet Weather System Plan and Wastewater Master Plan.
7. Develop Wet Weather System Plan through integrating RWWFP, Enhanced Overflow, I/I Pilot program and other wet weather-related wastewater projects/programs.
8. Undertake remaining ERAs for WWTFs requiring nutrient control and confirm effluent and technology requirements.
9. Develop Wastewater Master Plan.

Water System

10. Develop Water Master Plan.
11. Apply water use trends to water and wastewater design criteria and integrate into Water and Wastewater Master Plans.

Stormwater System

12. Assess stormwater quality compliance requirements.
13. Clarify role and mandate of Halifax Water in stormwater planning and management.

All Systems

14. Assess impacts of climate change on all systems, update design standards, update operational practices, and integrate findings into Water and Wastewater Master Plans and Wet Weather System Plan.

Corporate Balanced Scorecard and Level of Service

15. Implement recommendations for LOS update/expansion and update CBS.
16. Develop monitoring, analysis and reporting framework to support the updated/expanded LOS.
17. Identify needed resources to support updated/expanded LOS program.

3 Progress since the 2012 IRP

Halifax Water has been very active in implementing recommendations from the 2012 IRP as well as other initiatives to inform the decision-making and long-term planning process. The following sections summarize the programs, studies, frameworks and initiatives that Halifax Water is currently undertaking or has completed since the 2012 IRP.

3.1 Previous and Ongoing Studies and Initiatives

Since the 2012 IRP, Halifax Water has undertaken several water, wastewater and stormwater studies and initiatives. These studies have provided Halifax Water with a much enhanced understanding of Halifax Water's existing infrastructure and better planning approaches to meet future needs.

3.1.1 Past Studies and Initiatives

3.1.1.1 Regional Development Charges Development and Application

The Regional Development Charge (RDC) Review was completed in July 2013 to provide a justifiable and transparent framework to implement a RDC. The preferred option encompassed the first 20 years of the capital program proposed by the RWWFP, as well as alternative scenarios generated to assess potential impacts of adjusting or refining the assumptions of the RDC.

3.1.1.2 Regional Centre Local Wastewater Servicing Capacity Analysis

The Regional Centre Local Wastewater Servicing Capacity Analysis (LoWSCA) was completed in 2016 with the purpose of understanding the local wastewater system capacity constraints within six target intensification areas, four in Halifax Peninsula and two in downtown Dartmouth. Each area was analyzed in detail resulting in a recommended capital plan of the preferred solutions for each area.

3.1.1.3 Water Quality Master Plan Update

The Water Quality Master Plan Update (WQMP) was completed in 2017 and approved by the Halifax Water Board. The WQMP is a key study that guides Halifax Water's work and ongoing research on water quality. The WQMP concentrates its efforts in four themes: understanding lake recovery, adapting to lake recovery, maintaining distribution system water quality, and water quality data mining.

3.1.1.4 West Region Wastewater Infrastructure Plan

The West Region Wastewater Infrastructure Plan (WRWIP) was completed in 2017 to formalize the foundation policies of regional infrastructure planning, identify the preferred servicing solution and prepare preliminary designs of the wastewater infrastructure needed to service the West Region. The WRWIP builds on the 2012 IRP, the RWWFP and the LoWSCA studies to progress Halifax Water's wastewater servicing strategy.

3.1.1.5 Wet Weather Management Program

The Wet Weather Management Program (WWMP) was initiated in 2013 following the recommendations from the RWWFP and the 2012 IRP to effectively manage wet weather flows within the sanitary wastewater system. The WWMP developed a strategy to efficiently manage the impacts of wet weather flows in the sanitary system, including monitoring and separating combined sewer systems when possible. The program outlines short and long-term objectives and is being implemented in phases. The WWMP is currently in Phase III where pilot programs are used to gather information for the cost of various wet weather management techniques and the potential benefits. This will support Phase IV in developing the most cost-effective strategies to wet weather flows.

3.1.1.6 Five-Year Business Plans

Five-year Business Plans have been developed to provide a comprehensive financial plan for Halifax Water. The Business Plan includes the Five-year Capital Plan, which defines the specific projects and programs prepared by Halifax Water and approved (first year) by the NSUARB. The Business Plan also describes challenges and opportunities moving forward, including: the impact of significant current and imminent capital projects, future capital demands to better align with rates, enhanced customer service and expectations, increasing energy and chemical costs, wastewater research to meet current regulations, the wet weather management program and lead line replacement program. The latest Business Plan for the period from 2018/19 to 2022/23 was developed to replace the previous five-year Business Plan (2015/16 to 2019/20).

For detailed information of the past studies and initiatives that support the work undertaken for the IRP Update, refer to the Infrastructure Master Plan Background Review.

3.1.2 Ongoing Studies and Initiatives

3.1.2.1 Asset Management Plans

Halifax Water prepares Asset Management Plans (AMP) on an annual basis to outline how the utility manages its assets and to provide a summary of asset inventory, state of Halifax Water's infrastructure, level of service the assets provide to the customers, infrastructure replacement and maintenance strategies, and associated costs and expenditures. The latest version of the AMPs is the 2017/18 which was prepared by the utility on October 2018. Halifax Water is currently working towards the development of the 2018/2019 AMP.

The Asset Management Plan is one of the key inputs to the IRP Update. For more information refer to section 4.6.3

3.1.2.2 Integrated Stormwater Management Policy (ongoing)

The Integrated Stormwater Management Policy is an ongoing initiative, its main objective is developing policies that guide municipal and utility operations and governance when delivering stormwater management services in a manner that meets both legislative requirements and community expectations relating to public safety and environmental stewardship. The Integrated Policy will be structured around four main issues or themes: a capital investment strategy for stormwater infrastructure, ownership and maintenance of stormwater systems, land development practices, and drainage on private properties.

3.1.2.3 Infrastructure Master Plan (ongoing)

The Infrastructure Master Plan focuses on the servicing strategies and management of infrastructure in the Halifax Region, to produce an optimal servicing strategy for the wastewater and water supply networks. The Infrastructure Master Plan is ongoing and will become a key component of long term planning for Halifax Water.

The Infrastructure Master Plan is one of the key inputs to the IRP Update. For more information please refer to section 4.6.1

3.1.2.4 Compliance Plan (ongoing)

The Compliance Plan is currently underway. It will establish the current and future (5-year and 30-year planning horizon) federal, provincial and municipal level compliance regulations related to Halifax Water's water distribution system and wastewater and stormwater collection system. The main goal of

the compliance plan is to create a path forward for Halifax Water to achieve compliance for the next 30 years.

The Compliance Plan is one of the key inputs to the IRP Update. For more information please refer to section 4.6.2

3.2 Frameworks

The following frameworks and guidelines have been completed since the 2012 IRP. These guidelines provide a consistent and transparent approach for internal and external stakeholders.

3.2.1 Climate Change Management Framework

The Climate Change Management Framework was developed in 2018 to show how infrastructure systems of individual assets progress from the stage of being assessed against the impacts of climate change to the point where a mitigation strategy is implemented. The Climate Change Management Framework has been developed based on a review of best practices and the existing body of knowledge. The Framework is presented in the flow diagram below:




Figure 1 – Climate Change Management Framework

3.2.2 Cost Estimation Framework

As part of the West Region Wastewater Infrastructure Plan (WRWIP), Halifax Water formalized a cost estimation framework (CEF) with the purpose of providing a consistent, transparent, and auditable approach to costing capital projects both internally and externally. The CEF was developed using the knowledge gained through a review of Halifax Water's existing costing practices and unique organizational structure, in addition to a thorough industry best practice review.

The CEF approach uses a classification system to categorize diverse cost estimate classes. These classes represent different phases of planning and design, and subsequently various methods of cost estimation and levels of accuracy.

The CEF is a living document that provides opportunities for updates as required. As such, subsequent work under the Infrastructure Master Plan updated the unit rates to be used with the framework. The cost estimation framework is expected to be used moving forward for all Halifax Water's capital projects, and it will be used throughout the IRP Update.

Figure 2 present key features of Halifax Water Cost Estimation Framework.




Figure 2 – Key Cost Estimation Framework Features

3.2.3 Long-term Planning Framework

The Long-Term Planning Framework (LTPF) was developed in 2017 to provide Halifax Water with direction for long-term infrastructure planning activities. The LTPF considers all drivers of infrastructure management including growth, asset renewal, regulatory compliance, and operability. The framework provides a basis to plan for infrastructure needs in a holistic approach that integrates and considers infrastructure types together.

The LTPF proposes that Halifax Water elect to complete a unified water-wastewater-stormwater master plan, which is common within industry best practice for master planning. This approach is consistent with Halifax Water's 2012 IRP and allows for project coordination and improved long-term planning across all systems.

3.3 Initiatives to Close Data Gaps

Several programs and assessments were initiated by Halifax Water to close data gaps identified in the 2012 IRP. Some of these programs include the following:

3.3.1 Sewer Inspection and Survey Program

The sewer inspection and survey program is an annual program for determining condition information about the sewer systems. The program involves both manhole inspection using zoom camera technology, and conventional CCTV inspection for the mainline sewers and laterals. The advantage of using the zoom technology is that it allows an initial look at the pipes connected to each manhole with sufficient information to determine if mainline cleaning is needed or if full CCTV inspection is warranted. Additionally, zoom inspection is considerably less expensive than CCTV inspection. However, while zoom camera technology provides excellent information of the structures, it cannot capture detail on locations of defects in the mainline sewers.

The sewer inspections and survey program provide Halifax Water with information regarding the condition and performance of the sewers and can identify defects requiring rehabilitation or repair. These inspections are critical for decision making related to near term integrated project priorities and the wet weather program. As part of this program, Halifax Water staff has placed emphasis on the usability and accessibility of the information collected using available tools to make results simpler to view. Figure 3 below presents a snapshot of the Zoom Inspection Dashboard that shows an interface with inspection data and results.



Figure 3 – Zoom Inspection Dashboard

3.3.2 Condition Assessments by Asset Class

Halifax Water's Asset Management team have directed significant efforts on gathering data on asset attributes (size, material, age, and condition information as a minimum), and preparing the Asset Management Plans for all asset classes. Data refinements benefited from the completion of the following projects:

- Wastewater Treatment Facility Condition Assessment
- Wastewater Pumping Station Condition Assessment
- Stormwater Culvert Inventory and Condition Assessment
- Sewer Condition Assessments (Sewer Inspection and Survey Program)

The formal condition assessments provided data needed to inform the development of the AMPs for those asset classes. For the remaining asset classes, Halifax Water staff relied on best available information with the understanding that future AMPs will be refined as better information is collected.

3.3.3 Flow Monitoring Program

In 2016, Halifax Water initiated a corporate flow monitoring program, which was implemented in three phases; Spring 2016, Fall 2016 and Spring 2018. In addition to flow monitors, permanent rain gauges were installed to inform wet weather analysis. The program is comprised of three types of monitoring:


- Permanent flow monitors, referred to as the Flow Monitoring Zones (FMZ);
- Short-term flow monitors, used for the Wet Weather Management Program (WWMP); and,
- Temporary flow monitors, used to inform capital projects such as facility upgrades, sewer separation, etc.

3.3.3.1 Permanent Flow Monitors


The objectives of the FMZ monitors are:

- Provide continuous monitoring of sufficiently sized catchments (not too big, not too small) to provide the most valuable information. Areas of interest include upstream of CSOs, pumping stations, at major flow splits, and other key areas of the systems.
- Provide insight on system inputs and how they change over time, including changes in sanitary flow rates (e.g. growth, water conservation), wet weather response (inflow, infiltration), and impacts of climate change (e.g. sea level rise, storm intensity).
- Provide readily available data for hydraulic model updates and capital project studies.
- Use the data to supplement the WWMP flow monitors to meet the Wet Weather Management Program objectives.

The flow monitoring program currently includes 81 active FMZ flow monitors installed throughout the West, Central, and East Regions of HRM. **Figure 4**, **Figure 5** and **Figure 6** are overview maps of the FMZ monitors.







3.3.3.2 Short-term Flow and Temporary Monitors

The following lists the various uses for the short-term and temporary flow monitors:

- **Wet Weather Management Program (WWMP):** identify and quantify sources of inflow and infiltration. The WWMP currently has 19 active flow monitors. The Program is based on a three-phase approach: monitor the identified priority area, perform remediation works to alleviate identified issues, and continue monitoring to identify the beneficial impact (e.g. cost-benefit analysis).
- **Regional Development Charges (RDC):** assess the performance of new development.
- **Capital Projects (CP):** used by Halifax Water staff to gain better understanding of existing infrastructure in specific areas.
- **Hydraulic Models:** these monitors are used to fill in the system coverage gaps in preparation for model development and calibration.

3.3.4 Wet Weather Management Program and I/I Reduction Pilot Area Assessments

As part of the WWMP, Halifax Water has five pilot projects in areas identified as having high inflow and infiltration. These areas include Stuart Harris Sewershed, Cow Bay Rd, Leiblin Park, North Preston, and Crescent Ave. These pilot areas were chosen strategically to enable Halifax Water to validate what Rainfall Derived Inflow and Infiltration (RDII) reduction can be accomplished via various I/I reduction strategies on both the private and public side. Using flow monitoring data for the pilot areas, Halifax Water expects to validate the notion that comprehensive rehabilitation will be required to significantly reduce I/I.

Additionally, as mentioned in section 3.1.1.5, the WWMP is currently in Phase III where the pilot projects are used to gather information for the cost of various wet weather management techniques and potential benefits. This will support Phase IV of the WWMP in developing cost-effective strategies to manage wet weather flows throughout the entire service boundary.

3.3.5 GIS Update

In 2017, Halifax Water developed an Information Technology Strategic Plan to provide a structured program approach for implementing technological investment strategies, including Geographic Information Systems (GIS). Halifax Water has been using GIS for a number of years and has taken steps to update their GIS on an annual basis or when new information is available. Through the Strategic Plan, new ways of integrating GIS into Halifax Water operations will be developed. The Plan includes the following future strategic milestones related to GIS:

Theme – Information Integration with Location	Fiscal Year
GIS core system upgraded	2018/2019
All assets linked to GIS	2019/2020
GIS linked to customer records, asset records and work activity	2022/2023
Key GIS data is up to date and maintained	2022/2023

3.3.6 Water and Wastewater Hydraulic Models

3.3.6.1 Wastewater Model

The West Region Wastewater Infrastructure Plan (WRWIP) involved the wastewater model update for Halifax Water's existing west region sanitary and combined collection system models. The process produced two model scenarios: existing and growth.

The Infrastructure Master Plan is currently underway and involves new build and calibration of all-pipe wastewater models for Halifax's three main sewersheds: Central Region (Mill Cove WWTF and Springfield Lake WWTF), East Region (Eastern Passage WWTF and Dartmouth WWTF), and West Region (Halifax WWTF, Herring Cove WWTF, and Timberlea WWTF).

The new Infrastructure Master Plan wastewater models were developed using InfoWorks ICM and built primarily using a combination of data from corporate GIS geodatabases, as-built drawings, and field surveys. Calibration was completed in accordance with the CIWEM Urban Drainage Group Code of Practice using flow and precipitation data recorded at monitoring locations across all catchment areas.

Combined sewer overflow (CSO) and sanitary sewer overflow (SSO) discharges are of particular interest to the Infrastructure Master Plan; the model is used as a predictive tool to evaluate the impacts of population growth and climate change on the volume and frequency of CSO and SSO discharges. The current level of service for CSO and regional SSO evaluation is to ensure that there are no net increases to overflow volumes or frequencies as a result of growth.

3.3.6.2 Water Model

The water distribution hydraulic model, based in Bentley's WaterCAD software, was built, calibrated, and is currently maintained by Halifax Water. It is used to assess the distribution system in terms of operational strategies and to inform capital project needs.

The model is currently a steady-state model representative of trunk infrastructure, with pockets of local watermains. Originally, there were four separate models that represented the different systems and regions, including:

- Central (Bedford and Sackville)
- East (Dartmouth and Eastern Passage)
- West (Peninsula, BLT, Herring Cove)
- Bennery (Airport)

A water model update was completed as part of the Infrastructure Master Plan project so that it could be used to assess system opportunities and constraints, and to inform the development of the overall distribution system servicing strategy. The objective of the model update was to create a single integrated WaterCAD model of the Halifax Regional Municipality.

The individual models were reviewed to identify data gaps and prepare for the integration process. Once integrated, the water network was updated to include all facilities and watermains $\geq 300\text{mm}$, to provide a skeletal model for master planning objectives. System demands were updated, using 2016 billing data, facility production data, and SCADA data at pressure zone boundaries. The roughness coefficients assigned to the pipes were not updated, Halifax Water staff deemed them appropriate and valid at the time of the Infrastructure Master Plan. The intention of the modelling exercise was to ensure that the state of the hydraulic model was sufficient to assess the trunk infrastructure, including:

- Source of supply,
- Storage and pumping facilities, and
- System transmission.

Following the model build and update, the baseline scenario simulation was used to complete an audit and validation.

3.3.7 Lead Service Replacement Program

One of Halifax Water top priorities is to remove lead service laterals from the water system. Prolonged exposure to lead can cause adverse effects on human's health, specially for infants, young children, pregnant women and breastfeeding children. For homes with lead service lines, the potential for high levels of lead in drinking water is a significant concern.

In 2016, Halifax Water Board approved a comprehensive plan for the lead service line replacement program. In 2017, the program was approved in an effort to replace all lead that comes in contact with drinking water, including service lines. The same year, the NSUARB approved a rebate program proposed by Halifax Water to provide financial assistance to encourage residents to remove lead service lines located on private property.

The lead service replacement program intends to remove all lead service lines by 2050, consistent with the recommendation made to the US Environmental Protection Agency (USEPA) by the National Drinking Water Advisory Council (NDWAC). The program has the following five pillars:

1. Replace all lead service lines by 2050
2. Inventory
3. Customer communication
4. Continuation of customer sampling programs
5. Corrosion control

3.3.8 Advanced Metering Infrastructure & Customer Connect Program

The customer connect program was launched in 2017 to replace all water meters with Advanced Metering Infrastructure (AMI) technology. This will allow two-way digital communication between Halifax Water and its customers. Some of the features of the implementation of the AMI includes:

- Ability to offer monthly billing to residential and small commercial customers thus making it easier for customers to manage cash flows and automated payments.
- Billing errors will be reduced, and estimated meter readings will be eliminated.
- Halifax water will be able to alert customers to high consumption due to things like plumbing leaks, almost as they happen, reducing billing disputes and high bill amounts.
- Customers will have the ability, through a web link, to mange their water consumption, and see the effect of any conservation measures they take.

The AMI and Customer Connect Program will give customers the ability to manage their usage more effectively and reduce Halifax Water's environmental footprint by reducing fuel costs and site visits currently required for meter reading. It would also provide Halifax Water with better information on water consumption that would inform the decision-making process for short and long-term planning of infrastructure.

3.3.9 Update Planning Projections and Growth Allocations (completed by HRM)

The planning projections and growth allocation have been updated as part of the current Infrastructure Master Plan and are provided in **Section 4.2**.

4 The 2019 Integrated Resource Update

The 2019 Integrated Resource Plan will be the main outcome of the IRP update process which was initiated in September 2018. At the outset of the project, key meetings were held with members of the Halifax Water project team, Halifax Water Directors, Halifax Water Board, and NSUARB Consultants. The following sections summarize the material presented at these meetings. The purpose of these meetings was to introduce the project and agree on key subjects such as the IRP vision, scope of the IRP Update, study inputs and next steps.

4.1 Overview

The IRP is a key component of Halifax Water's iterative planning process. The process was initiated in 2012 with the first IRP and continued with the development and further understanding of the infrastructure systems. Elements such as flow monitoring, hydraulic models and conditions assessments are developed at this stage to better understand and inform the decision-making process. In the same vein, studies and frameworks such as Master Plans and Climate Change Framework are implemented to determine the best servicing strategies for Halifax Water's systems. The results of these strategies are then transformed into capital and implementation plans that feed into Halifax Water capital budgets, regional development charges and rate updates. The process repeats itself in a typical 5-year cycle with the development of the Integrated Resource Plan Update which provides a path for the next 5 years.




Figure 7 – IRP Iterative Planning Process

The main purpose of the 2019 IRP is to develop an integrated 30-year capital infrastructure plan covering all systems (water, wastewater, stormwater) and drivers (growth, compliance, asset renewal). In order to do so, the following objectives were defined:

- Compile, organize and summarize best available information
- Identify and assess current Halifax Water and industry leading demand and supply side management measures (DSM/SSM)
- Recommend preferred integration opportunities
- Inform Halifax Water's long-term financial model to understand the financial requirements for the infrastructure needs
- Develop a forward looking long-term infrastructure plan that is traceable, defendable and implementable

4.1.1 IRP Vision

The 2019 IRP vision is to be an integrated forward-looking document based on the following principles:

- Build on the foundation and structure of the 2012 IRP
- Layer multiple infrastructure inputs and recommendations to establish an integrated long-term capital plan
- Strategic planning for the long-term
- Real steps in the short-term
- Tactical level document
- Integrated capital program and strategy
- Supported collectively

4.1.2 Drivers and Objectives

The 2019 IRP drivers and objectives remain unchanged from the 2012 IRP as shown in section 2.1.2 and Table 1. The 2019 IRP focuses on the three drivers: Growth, Regulatory Compliance and Asset Renewal; and fourteen objectives based on Halifax Water's level of service, compliance requirements (existing and future), asset renewal requirements, as well as other important considerations such as adaptation to climate change, system reliability and servicing growth.




Figure 8 – 2019 IRP Drivers

4.1.3 Regulation, Policy and Legislation Review

Review of applicable new and future regulation not included in the 2012 IRP.

4.1.3.1 Water System

One of the overall objectives of the Water Quality Master Plan is full compliance with “Guidelines for Canadian Drinking Water Quality”. These guidelines provide the acceptable levels of microbiological, chemical and radiological contaminants in drinking water. It also provides acceptable physical characteristics including taste and odour. The guidelines can be published as either Maximum Acceptable Concentrations (MAC’s) which are health related parameters; Aesthetic Objectives (AO’s) and Operational Objectives. Drinking Water Approvals in Nova Scotia require that all MAC’s must be achieved.

Table 3 summarizes the changes made to the guidelines after 2012. These Guidelines are established and updated based on published scientific research on the health and aesthetic effects associated with a contaminant.

Table 3 – Changes to the Guidelines for Canadian Drinking Water Quality

Parameter (approval, reaffirmation)	MAC (mg/L)
Ammonia (2013)	None required
Benzo[a]pyrene (2016)	0.000 04
1,2-Dichloroethane (2014)	0.005
Ethylbenzene (2014)	0.14
Nitrate (2013)	45 as nitrate; 10 as nitrate-nitrogen
Nitrite (2013)	3 as nitrite; 1 as nitrite-nitrogen
pH (2015)	None
Selenium (2014)	0.05
Tetrachloroethylene (2015)	0.01
Toluene (2014)	0.06
Vinyl chloride (2013)	0.002 ALARA
Xylenes (total) (2014)	0.09

The Federal-Provincial-Territorial Committee on Drinking Water is continuously reviewing Maximum Acceptable Concentrations (MACs) due to new scientific information and studies on adverse effects of certain substances. Most recently, the Federal-Provincial-Territorial Committee on Drinking Water has established a MAC of 0.005 mg/L (5 µg/L) for total lead in drinking water, based on a sample of water taken at the consumer's tap, using the appropriate protocol for the type of building being sampled. As this value exceeds the drinking water concentration associated with neurodevelopmental effects in children, every effort should be made to maintain lead levels in drinking water as low as reasonably achievable (or ALARA). Additionally, Health Canada has announced an expected change in the MAC for manganese in April 2019. The expected MAC for manganese will be 0.12 mg/L.

The Federal-Provincial-Territorial Committee has released additional guidance documents since 2012 including:

- Issuing and Rescinding Boil Water Advisories in Canadian Drinking Water Supplies (2015): Summary of factors for responsible authorities to consider when a boil water advisory is issued or rescinded.
- Use of Microbiological Drinking Water Guidelines (2013): Overview of considerations for microbiological parameters to ensure drinking water quality.
- Waterborne Bacterial Pathogens (2013): Information on pathogens that originate from human or animal faeces or naturally occurring in the environment and their treatment options.

In addition to the “Guidelines for Canadian Drinking Water Quality”, there is also the Atlantic Canada Guidelines for the Supply, Treatment, Storage, Distribution and Operation of Drinking Water Supply System. These guidelines provide guidance for the development of water supply projects in Atlantic Canada.

Through the Compliance Plan, water and wastewater facilities will be reviewed to achieve compliance with regulations, and the recommendations will be incorporated into the IRP Update.

4.1.3.2 Wastewater System

The Wastewater System Effluent Regulations (WSER), were enacted in June 2012 and amended January 2015. The WSER were implemented by the federal government and became both provincial and federal wastewater standards for compliance.

The WSER define the following as deleterious substances, and set national standards for their discharge:

- Carbonaceous Biochemical Oxygen Demand (CBOD): 25 mg/L
- Suspended Solids (TSS): 25 mg/L
- Total Residual Chlorine (TRC) for facilities using chlorine disinfection: 0.02 mg/L
- Un-ionized Ammonia as N at $15^{\circ}\text{C} \pm 1^{\circ}\text{C}$: 1.25 mg/L

WWTFs are authorized to discharge these substances at levels below the defined limits, provided that the effluent is not acutely lethal to trout as determined by standard toxicity testing. Facilities not in compliance must apply for a Transitional Authorization (TA) to deposit effluent exceeding those limits. The Authorization will be valid for a period of 10, 20 or 30 years, depending on the risk level associated with the effluent, as determined by a defined risk-ranking system in the WSER.

4.1.3.3 Wastewater Overflows

Completed in 2012, the Level of Service (LOS) targets, developed as part of the RWWFP, were based on the draft Canada-wide Strategy for the Management of Municipal Wastewater Effluent guidelines developed by the Canadian Council of Ministers of Environment (CCME). An anticipated component of the guidelines was to target no increase in frequency and/or volume of combined sewer overflows (CSOs) and/or sanitary sewer overflows (SSOs) as a result of new development.

In 2017, The WRWIP level of service review was undertaken to inform strategic planning of Halifax Water's wastewater systems. The recommended LOS of no increase in spill frequency or volume for combined sewer overflows (CSOs) and separated sewer overflows (SSOs) from the RWWFP were recommended to remain as is; the recommendation was adopted in the ongoing Infrastructure Master Plan.

4.1.3.4 Stormwater

HRM is currently developing a Stormwater Management and Erosion Control By-law to control lot grading and therefore address stormwater quality issues.

4.2 2019 IRP Study Area

HRM is comprised of 18 community planning areas, spanning 5,500 km², with an approximate population of 411,014 people (2016 census estimate). The boundary of the 2019 IRP Update includes the existing and planned Central, East and West service areas for water and wastewater in HRM, as well as the stormwater service boundary.

The study area of the IRP is provided in Figure 9 below.




Figure 9 – Study Area

Halifax Water owns and operates the water distribution system and the wastewater collection system. It also owns and operates the stormwater collection system within the right-of-way inside the Halifax Water stormwater service boundary.

The following section, details Halifax Water's existing water, wastewater and stormwater infrastructure.

4.3 Existing Infrastructure

4.3.1 Water System

Halifax Water provides drinking water and fire protection services to approximately 370,000 people. The water distribution system is made up of 1,558 km of watermains (including transmission and distribution mains), eight water supply plants (WSP), two back-up water supplies, six water supply dams, 21 booster stations and 143 chambers.

Halifax has three main water supply plants; J.D Kline WSP, Lake Major WSP and Bennery Lake WSP. In addition, Halifax Water services five smaller community supply plants that service rural/suburban areas. Each WSP has a water withdrawal permits and meets the Canadian Drinking Water Standards.

J.D. Kline WSP services the West and Central Region including the greater urban core of Halifax, Bedford, Sackville, Fall River, Waverley and Timberlea. The plant uses a direct dual media filtration process to treat water from the Pockwock Lake.

Lake Major WSP services the East Region including Dartmouth, Eastern Passage, Shearwater and Forrest Hills/Colby Village. The plant uses a sedimentation and multi-media filtration process to treat water from Lake Major.

Bennery Lake WSP services the Halifax Stanfield International Airport and Aerotech Business Park. The plant uses a direct filtration process to treat water from Bennery Lake.

An overview of the water supply system is illustrated in Figure 10. Showing the location of the WSPs, the pumping stations and reservoirs.




Figure 10 – Overview of the Existing Water System

4.3.2 Wastewater System

The wastewater collection system is made up of 1,424 km of sewers (including forcemains and gravity sewers), 14 treatment plants, one biosolids processing facility and 166 pumping stations. Halifax Water currently owns and operates five major wastewater treatment facilities (WWTF), Halifax, Dartmouth, Herring Cove, Mill Cove and Eastern Passage and nine smaller WWTF that service rural/suburban areas providing a level of treatment from primary to tertiary. Five of the WWTFs discharge to salt water bodies and nine discharge to small freshwater bodies.

The major wastewater collection system for each of the regions is as follows:

The West Region is comprised of the urban areas of the Halifax Peninsula and mainland serviced by the Halifax WWTF, and outlying suburbs including Beechville, Lakeside and Timberlea are serviced by the BLT WWTF and the trunk sewer which conveys flow to Halifax sewershed, while the outer regions of Spryfield and Herring Cove drain to the Herring Cove WWTF.

The East Region is comprised of the Dartmouth area which includes combined and separated sewers tributary to the Dartmouth WWTF. The Dartmouth catchment is particularly complex with separated networks entering combined networks, high I&I levels and a number of cross connections making defining catchments and flows more complex. The outlying suburbs of Cole Harbour, Shearwater and Eastern Passage are tributary to the Eastern Passage WWTF.

The Central Region comprises of Bedford and Sackville which are tributary to the Mill Cove WWTF. A large portion of the Central Region is not serviced by the municipal wastewater system, relying on on-site sewage disposal.

Figure 11 provides an overview of the wastewater network. It illustrates the location of the WWTFs, pumping stations and sanitary and combined sewer network.




Figure 11 – Overview of the Existing Wastewater System

4.3.3 Stormwater System

The stormwater collection system is made up of 878 km of storm sewers, 2,337 cross culverts, approximately 16,000 driveway culverts, and 40 stormwater management structures. The stormwater system is multi-jurisdictional, with the provincial and municipal governments, Halifax Water and private owners having distinct roles and responsibilities within the stormwater cycle. Table 4 presents the stormwater system jurisdiction and roles and responsibilities for each entity.

Table 4 – Stormwater System Jurisdiction

Entity	Roles and Responsibilities
Province of Nova Scotia	<ul style="list-style-type: none"> • Protection of water resources including natural watercourses (stream, rivers, lakes) • Issues a Permit to Construct for the installation of a public stormwater system
Halifax Water	<ul style="list-style-type: none"> • Municipal water, wastewater and stormwater utility serving HRM residents • Authority to own and operate stormwater systems within a defined service boundary which comprises of catch basins, pipes, manholes, roadside, ditches, swales, culverts, stormwater holding tanks, ponds, and dams
Halifax Regional Municipality	<ul style="list-style-type: none"> • Regulation of land development activities including siting of buildings, grading of land, and assessment of impacts of overland flow resulting from development of land and stormwater systems • Owns and maintains minor drainage system elements including pipes, ditches, culverts, etc.) that fall outside of Halifax Water's service boundary • Owns and maintains public street system
Private Property Owners	<ul style="list-style-type: none"> • Stormwater flow across individual properties, across adjacent property boundaries and stormwater management systems located on individual property • Private stormwater systems include rainwater leads, footing drains, private community systems, and slope protection within privately-owned property • Maintain drainage corridors and privately-owned drainage infrastructure free of vegetation and debris

Figure 1 provides an overview of Halifax Water's stormwater service boundary.




Figure 12 – Halifax Water Stormwater Service Boundary

4.4 Planning Data and Population Projections

As part of the Infrastructure Master Plan process, Halifax Water project teams including HRM staff collaborated to define the planning projection dataset, required to develop the Infrastructure Master Plan. HRM confirmed the starting baseline populations, the ultimate planning projection approach and growth rate over a 30-year horizon, from 2016 to 2046. The resulting planning estimates were the basis for the water demand and wastewater flow projections for the Master Plan. Table 5 summarizes the HRM planning estimates as developed in the Infrastructure Master Plan.

Table 5 – Halifax Regional Municipality Planning Estimates

Sub-boundary	Employment Growth (2016-2046)	Population Growth (2016-2046)	Total Growth (2016-2046)
Regional Centre	42,123	53,507	95,630
Suburban	36,963	77,706	114,669
Rural	6,877	17,000	23,877
Total	85,963	148,213	234,176
Service Area*	79,086	131,213	210,299

*Excludes rural planning projections.

4.5 Design Criteria, Level of Service and Cost Estimation Review

4.5.1 Design Criteria

A comprehensive review of Halifax Water's existing design criteria for water supply and wastewater collection systems was completed as part of the WRWIP and Infrastructure Master Plan. In addition to the review, trend analyses and a summary of industry best practice were used to validate the appropriateness of the criteria.

Key design criteria for wastewater collection system:

- Per capita sanitary flow = 300 L/cap/day
- I/I allowance rate = 0.28 L/s/ha

Key design criteria for water supply system:

- Per capita average day demand = 375 L/cap/day
- Peaking factors summarized in Table 6.

Table 6 – Peaking Factors for Infrastructure Planning

Category	MDD	PHD
System Supply	1.40	2.10
Storage	1.90	2.85
Pumping and PRVs (Zones > 10,000 people)	1.90	2.85
Pumping and PRVs (Zones < 10,000 people)	2.20	3.30

4.5.2 Level of Service

A comprehensive review of Halifax Water's level of service for water supply and wastewater collection systems was completed as part of the Infrastructure Master Plan. The level of service recommended as part of the Infrastructure Master Plan includes:

Wastewater collection systems

- A 1 in 5-year design event is to be used to assess peak flows and infrastructure capacity.
- Ensure that new development does not increase the frequency and/or volume of CSOs or SSOs, or impact on the water quality.
- In recognition of the high amenity value of the Northwest Arm, a more stringent limit of 10 overflow events per year is to be applied at each individual CSO along the Northwest Arm.

Water supply systems

- Pressures between 40-100 psi under Minimum Hour Demand (MHD) and Peak Hour Demand (PHD) scenarios.
- Pressures above 22 psi during a fire under a Maximum Day Demand (MDD) scenario.
- Available storage capacity in accordance with the Atlantic Canada Guidelines.

4.6 IRP Update Study Inputs

There are three documents that will serve as the main study inputs for IRP Update:

- Infrastructure Master Plan (ongoing)
- Compliance Plan (ongoing)
- Asset Management Plan (ongoing)

4.6.1 Infrastructure Master Plan

The Infrastructure Master Plan focuses on the servicing strategies and management of infrastructure in the Halifax Region, to produce an optimal servicing strategy for the wastewater and water supply networks. The Infrastructure Master Plan is ongoing and builds off previous completed studies such as the WRWIP and LoWSCA. The strategic plan of the Master Plan is intended to accommodate growth, regulatory compliance, asset renewal and optimization of assets for the next 30 years. The Master Plan will become a key component of long term planning, providing costing and timeframes. It includes development of wastewater and water hydraulic models, conceptual designs for projects in the first 10 years, and forms a work plan for adapting to climate change, similar to the WRWIP.

Through the Master Plan, the following have been completed and/or used in the development of the servicing strategies:

- Climate Change Framework
- Wet Weather Management Study
- Cost Estimation Framework
- Design Criteria and Level of Service Review
- Planning Data and Population Analysis
- Water Model Build and Calibration
- Wastewater Model Build and Calibration

The Infrastructure Master Plan will provide key inputs to the IRP Update, including:

- Growth Areas – Halifax's projected growth areas covering extents and timing.
- Capital Program – water and wastewater capital projects to 2041 including timing, cost estimates and spatial allocation.
- Wet Weather Management Study – priority areas, best areas with potential for sewer separation, I/I reduction, low impact development (LID) and CSO discharge reduction.

4.6.2 Compliance Plan

Halifax Water's Compliance Plan is currently underway. It will establish the current and future (5-year and 30-year planning horizon) federal, provincial and municipal level compliance requirements related to Halifax Water's water distribution system and wastewater and stormwater collection systems. The Compliance Plan will provide a path for Halifax Water moving forward to achieve full compliance in all its systems.

Compliance requirements for the following infrastructure will be included:

- Wastewater treatment facilities and effluent, as well as wastewater compliance within the collection system (SSOs and CSOs).
- Water supply plants, transmission and distribution system, water chambers, booster stations, water supply dams and reservoirs.

The Compliance Plan will provide key inputs to the IRP Update, including:

- Current and future regulatory compliance requirements.
- Detailed treatment compliance assessment for WWTFs and WSPs.
- Capital program including timing, cost estimates and location.

4.6.3 Asset Management Plan

The Asset Management Plan (AMP) is last of three key inputs to the IRP Update. The AMP provides a summary of asset inventory and state of Halifax Water's infrastructure, level of service the assets provide to the customers, infrastructure replacement and maintenance strategies, and associated costs and expenditures. Halifax Water currently updates the AMP on an annual basis. The latest version of the AMP is the 2017/18 which was prepared by the utility on October 2018. Halifax Water is currently working towards the development of the 2018/2019 AMP.

The AMP document structure consists of an "Overall Main Sections" component followed by individuals AMPs covering 14 different asset class as follow:

<u>Water</u>	<u>Wastewater</u>	<u>Stormwater</u>
<ul style="list-style-type: none"> • Supply Plants • Supply Dams • Chambers & Booster Stations • Transmission Mains • Distribution Mains • Service Reservoirs 	<ul style="list-style-type: none"> • Treatment Facilities • Pumping Stations • Gravity Sewers • Force mains 	<ul style="list-style-type: none"> • Management Structures • Gravity Sewers • Cross Culverts • Driveway Culverts and Ditches

For each of the asset class AMPs, background documentation (spreadsheet, shapefiles, etc.) has been provided with the purpose to inform the IRP Update and support the integration process.

The AMP provides the following key inputs to the IRP Update:

- Asset inventory and replacement costs for each asset class.
- Asset condition based on age/estimated service life, conditions assessments, site inspections, staff knowledge and discussions, depending on the available information for each asset class.
- Recommended 5-year detailed capital expenditures and a 30+ year average forecast for most asset classes.

It is expected that the Master Plan will contain projects and initiatives that will present an overlap with some of the recommendations from the Compliance Plan and Asset Management Plan. The IRP will navigate through all the recommendations from the plans to find areas for integration in order to develop Halifax Water's Long-Term Infrastructure Planning Capital Plan.

5 Conclusions and Recommendations

Halifax Water is responsible for the operation and management of the water and wastewater systems, and the operation and maintenance of the existing stormwater infrastructure located within the road right-of-way or easements owned by the utility. As part of its mandate and services, Halifax Water continuously undertakes initiatives and programs to maintain, operate and expand its systems while providing an appropriate level of service to its customers.

The Integrated Resource Plan Update is a critical project that brings together Halifax Water's various initiatives and programs into a singular integrated capital and financial plan. This study applies the considerations of growth, regulatory compliance and asset renewal to ensure the integrated recommendations achieve the desired service delivery goals as well as identify any additional gaps and programs required in the long-term plan.

The 2019 IRP Update will be built on the foundation of the 2012 IRP, as well as other studies and initiatives completed since, or that are currently underway. The main inputs to the IRP Update include the Infrastructure Master Plan, the Compliance Plan and Asset Management Plans.

As part of the IRP Update, a background data and legislation review was undertaken. The purpose of the review was to go through the background information available and form the understanding required to successfully complete the IRP Update.

The background data and legislation review provide the following recommendations for areas of improvement and next steps:

- Understand Halifax Water's current DSM/SSM measures, document what strategies are being planned and recommended through the study inputs, identify industry leading DSM/SSM strategies, and provide recommendations for potential implementation of new measures.
- Review AMPs inventory, replacement costs and projected asset renewal expenditures. A Costing Review analysis will be carried out to undergo an industry review and cross-reference of sources of unit rates, replacement values, costing methodology and assumptions for water, wastewater and stormwater infrastructure.
- Assess potential integration opportunities for projects and programs recommended in the study inputs for the water, wastewater and stormwater systems. The integration process purpose is to ensure that projects and programs are aligned in terms of geography and spatial allocation, drivers (growth, compliance, asset renewal), priorities, timing and phasing, life cycle cost, resources and financial sustainability.
- Ensure consistency among deliverables and outputs of the IRP Update with the study inputs and other published documents including appropriate sourcing of information.

Appendix A - 2012 IRP Assumptions

Appendix A: 2012 IRP Assumptions

Study Aspect	Assumption
Compliance ¹	<ul style="list-style-type: none"> For purposes of the IRP, development of a conservative assumption was made that each wastewater facility except BLT, which is already being upgraded, would need to meet limit of technology (LOT) effluent limits. The term “limit of technology” has been used to describe the lowest, consistently achievable effluent concentration for total phosphorus (TP) and total nitrogen (TN) utilizing existing technology. In Chesapeake Bay, a program has been in place since 1992, which implemented the concept of LOT utilizing biological nutrient removal (BNR) technologies.
Asset Renewal Modelling ²	<ul style="list-style-type: none"> Due to GIS data gaps, asset information for the water distribution and wastewater collection systems were assumed including material, diameter, and age profile The asset service life estimates were based on best industry practice. For complex assets like pump stations and treatment facilities separate service life estimates were made for various system components. Civil (structural) elements had a 50-year life, mechanical-electrical (M&E) components had a 20-year life and instrumentation and control (IC) had a 10-year life. A fraction of the total asset value was assigned to each component e.g. structural represents 60% of total asset value. The asset life data and fractional values are contained in the costing procedures technical memorandum, which is presented in Volume 3 Appendix C of the IRP final report. For purposes of the asset renewal modelling the civil-structural components of complex assets such as pump stations and treatment plants were considered to be presently in new condition. Considering the 50-year life of the components they did not figure in the asset renewal requirements over the 30-year IRP planning period. Halifax Water staff reviewed the status of the M&E and IC systems of major water and wastewater treatment facilities and provided specific estimates of current asset age. These were used as the starting point for the modelling of these assets. A discount rate of 3% was applied to all asset renewal capital expenditures. The discount rates were calculated as the difference between the current municipal borrowing rate of 5% and an inflation rate of 2% for capital projects estimated from an analysis of ENRCCI index changes for municipal construction projects. The current annual expenditure as a percentage of the asset value was based on the asset renewal expenditures provided in the Five-Year Capital for 2012 to 2017. It was assumed that the budgeted amounts are indicative of current asset renewal expenditures. Some special assets with significant site-specific conditions affecting renewal costs such as reservoirs or dams were not modelled but rather subjected to individual analysis to estimate required renewal over the 30-year period. These were high-level estimates. Specific detailed evaluations should be made for each of these structures to establish current condition and replacement requirements.

¹ Integrated Resource Plan (Section 4.3.2), Halifax Water, October 2012

² Integrated Resource Plan (Volume 1, Appendix F), Halifax Water, October 2012

Study Aspect	Assumption
Demand Reduction Assessment ³	<p>For the purpose of the demand reduction assessment the following assumptions have been made:</p> <ul style="list-style-type: none"> • A conservative reduction of 10% in existing sanitary flows through water demand reduction. This reduction is based on retrofit of existing homes and purchase of new water efficient appliances. • A 30% reduction in sanitary flows through future water demand reduction. • A 30% I/I reduction in existing I/I flows, consistent with the targets set for King County Washington • Current design allowance for future I/I <p>In order to assess the potential benefit to cost relationship associated with the demand reduction activity the following assumptions were made:</p> <ul style="list-style-type: none"> • The bulk of the cost of the 30% future water/wastewater demand reduction would be incorporated into the cost of the new dwellings and buildings (through low-flow appliances and fixtures) and would not impact on the IRP capital requirements. • Low cost for the demand reduction for existing water/wastewater usage, largely achieved through existing public education programs • The cost of the I/I program could not be determined precisely due to the absence of Halifax data. Instead a high-level analysis approach was based on the large scale, well resourced, multi-year program in King County, Washington.
End-of-period Value Analysis ⁴	<ul style="list-style-type: none"> • The starting value of the assets was determined from their replacement value, age profile (i.e. year of installation), and nominal service life. Straight-line depreciation was then used to estimate the current asset value. • The 30-year asset renewal analysis was carried out for four cases: A, B, C and composite levels and includes the renewal of assets added through the IRP capital program over the 30-year period. • The capital expenditures over the 30-year period were based on the Recommended IRP. • Straight-line depreciation was used throughout.
Enhanced Overflow Control Program Analysis ⁵	<ul style="list-style-type: none"> • Additional overflow control used a technology based on storage coupled to pumping and secondary treatment for purposes of estimating capital costs. • Storage was sized to capture all but 25, 15 and 5 overflow events per average year • Pumping and secondary treatment requirements were sized to empty full storage in 48 hours • Costs were estimated using the same procedures as throughout the IRP

³ Integrated Resource Plan (Section 6.3.2), Halifax Water, October 2012

⁴ Integrated Resource Plan (Section 6.3.3), Halifax Water, October 2012

⁵ Integrated Resource Plan (Volume 1, Appendix F), Halifax Water, October 2012

Study Aspect	Assumption
Financial Modelling ⁶	<ul style="list-style-type: none"> A discount rate of 3% was applied to all capital expenditures and a discount rate of 1% was applied for all additional O&M costs. The discount rates were calculated as the difference between the current municipal borrowing rate of 5% and an inflation rate of 2% for capital projects estimated from an analysis of ENRCC index changes for municipal construction projects and 4% inflation rate for O&M Only years 2-5 of the Halifax Water Five-Year Capital Plan were incorporated in the financial models. The initial year 2012-2013 was considered already in process and was not included. Year 1 of the IRP financial analysis is 2013-2014. The expenditures associated with projects identified in the years beyond the Five-year Capital Plan were distributed through the financial model through discussions with Halifax Water staff on priorities and programming All capital projects where variations were considered in timing were allocated to the single year indicated in the variation. All capital expenditures developed during the IRP are stated as project costs and include a 1.6 multiplier to account for engineering, construction management, other incidental costs and a 25% estimating contingency. The details of the unit rates (e.g. cost per meter of pipe) and other aspects of the project costing procedures are presented in Volume 3 Appendix C. All capital costs presented for the RWWFP have been harmonized with regard to costing procedure used by the IRP. All capital costs are presented in \$2012 using an ENRCC Index value of 9200. Additional (change in) O&M costs were developed using the procedures described in Volume 3 Appendices B and C. The costs account for labour, energy, and chemicals as well as such consumables as UV bulbs and membrane filter cartridges. Additional O&M costs for upgrade/expansion projects were started the year after the project was implemented All programs/projects and O&M costs were allocated to one or more IRP objectives. The cost split among objectives was based on best professional judgment. The splits are recorded in the financial models presented in Volume 3 Appendix F. The Enhanced Overflow Control Program was allocated in total to Objective 6. The asset renewal costs arising from the asset renewal modeling were allocated to Objective 8. These program costs incorporated the Halifax Water Five-Year Capital Plan specific asset renewal projects. The RWWFP costs were allocated primarily to Objective 13 reflecting the need to offset the impacts of growth on the existing wastewater system. Some RWWFP costs were however allocated to Objectives 6 and 14.

⁶ Integrated Resource Plan (Section 5.6), Halifax Water, October 2012



A

HALIFAX WATER
2019 INTEGRATED RESOURCE PLAN

APPENDIX A.2

DSM / SSM MEASURES



Halifax Water

2019 Integrated Resource Plan

Technical Memorandum #2:
*Demand Side Management &
Supply Side Management
Measures*

Project No.: 718032



Prepared by: GM BluePlan Engineering
For: Halifax Water
March 2020

Document Revisions

The following is a record of the changes/updates that have been made to the final document:

Version	Changes / Updates	Author	Reviewed	Date
DRAFT	1 st Draft for Review	Sandy Naime	James Jorgensen	Dec 6 th 2019
DRAFT	2 nd Draft for Review	Sandy Naime	Chris Campbell	Dec 12 th 2019
FINAL DRAFT	Final Draft Report	Sandy Naime	James Jorgensen	March 9 th , 2020
FINAL	Final Report	Sandy Naime	James Jorgensen	March 27 th , 2020

Table of Contents

1	Introduction	1
1.1	Aim	1
1.2	Objectives	1
2	DSM/SSM Definitions and Review Process.....	2
2.1	Definitions	2
2.2	DSM/SSM Review Process	2
2.3	DSM/SSM Categories	2
2.4	DSM/SSM Measures Evaluation.....	3
3	Halifax Water's DSM/SSM Measures	5
4	Additional DSM/SSM Measures	8
5	Halifax Water Collaboration.....	10
5.1	Collaboration Process	10
5.2	Summary of Discussions with Halifax Water and NSUARB Consultants.....	10
6	Analysis Discussion	11
6.1	Enhancement Opportunities and Recommendations	11
7	Summary and Conclusions	16

Appendices

Appendix A Long Lists of DSM/SSM measures

1 Introduction

The Halifax Regional Water Commission (HRWC), also known as Halifax Water, was the first regulated and publicly owned water, wastewater and stormwater utility in Canada. With a long history dating back to the 1940s, Halifax Water is the water, wastewater and stormwater utility servicing residents of the Halifax Regional Municipality (HRM).

As part of its mandate, Halifax Water continuously undertakes initiatives and programs to maintain and operate its systems while striving to provide world class service to its customers and environment. These initiatives and programs require integration into a single capital program that identifies the long-term resource needs and financial expenditures.

The long-term program is consolidated into a comprehensive document: the Integrated Resource Plan (IRP) for Halifax Water. As part of the IRP approach, it is intended to complete IRP updates at regular intervals to ensure the consolidated long-term program is current. This IRP update is a critical project that brings together projects, initiatives and programs from separate studies, into a singular integrated capital plan. This study applies the drivers of compliance, asset renewal and growth, to ensure the integrated recommendations achieve the desired service delivery goals, as well as identify any additional gaps and programs required in the long-term plan.

The IRP approach is a key component of Halifax Water's iterative planning process. The process was initiated in 2012 with the first IRP and continued with further understanding of the infrastructure systems and development of studies and frameworks, capital delivery and financial planning. The 2019 IRP Update is built on the foundation of the 2012 IRP and provides Halifax Water with the required programs and resources for a 30-year period covering each of the three drivers: Compliance, Asset Renewal and Growth.

As part of the 2019 IRP Update process, a review of Demand Side Management (DSM) and Supply Side Management (SSM) practices and measures was undertaken. The review included identifying and reviewing all the activities that Halifax Water currently employ as well as an evaluation of those implemented throughout the water industry. Through collaboration with Halifax Water staff, each identified measure was reviewed and evaluated to provide recommendations for improvements and select new measures for potential future implementation.

This technical memorandum summarizes the review of industry trends, reviews measures currently in place at Halifax Water, evaluates effectiveness of different measures and considers potential additional measures that could be implemented.

1.1 Aim

The aim of the DSM/SSM Measures Technical Memo is to provide guidance on which existing and new activities and measures are likely most effective for Halifax Water.

1.2 Objectives

In order to meet the Aim, the following objectives were completed:

- Identify and review DSM/SSM measures currently being planned or already implemented by Halifax Water.
- Identify and review DSM/SSM best practices from other utility companies or municipalities within and outside Canada.
- Evaluate DSM/SSM measures and provide recommendations for improvements or potential new measures for future implementation.

2 DSM/SSM Definitions and Review Process

2.1 Definitions

Demand Side Management (DSM) - relates to the management of water, wastewater and stormwater at the point of use. Demand Side Management effects customer usage and education, utility rates, regulations and private property connections.

Demand Side Management activities are those that occur on the customers side of the property boundary.

DSM measures are guided and supported by Halifax Water (in some cases in association with HRM) however, the rate of success is determined by the level of customer involvement. Challenges for DSM are mostly related to implementation costs and inconvenience to customers.

Supply Side Management (SSM) - relates to the management of water, wastewater and stormwater infrastructure to meet or exceed customer demands including system optimization, upgrades, and infrastructure repair and replacement.

Supply Side Management activities are those that occur at Halifax Water facilities or within the public right-of-way.

SSM measures are implemented by Halifax Water (in some cases in association with HRM), therefore, the rate of success is determined by the planning, design and operation of the infrastructure. Challenges for SSM are mostly related to infrastructure and energy costs.

2.2 DSM/SSM Review Process

The DSM/SSM measures review process involved the following steps:

1. Review of existing measures currently planned or implemented by Halifax Water.
2. Review of best practices from other utilities/municipalities within and outside Canada.
3. Evaluating the long list of DSM/SSM measures in collaboration with Halifax Water.
4. Identification of potential new measures and/or enhancement opportunities for Halifax Water.

2.3 DSM/SSM Categories

As detailed above, the review process started with forming a long list of DSM/SSM measures by reviewing existing measures currently planned or implemented by Halifax Water and undertaking a best practice review of other utilities/municipalities within and outside Canada.

After the long list of measures was formed, the DSM/SSM measures were first categorized based on system (water, wastewater, stormwater) and driver type (growth, compliance, asset renewal). Each measure was then further classified by DSM and SSM categories shown in **Table 1**. These categories were chosen based on their overall impact on the customer (DSM) and impact on the planning and/or design of infrastructure (SSM).

Table 1 - DSM/SSM Categories

DSM Categories	SSM Categories
Customer Education	Design Criteria
Customer Usage	Financial Incentives
Financial Incentives	Infrastructure Management
Regulation	Infrastructure Replacement / Repair
Utility Rates	System Optimization
Water Loss Control	System Extension / Upgrades

2.4 DSM/SSM Measures Evaluation

To compare and assess the long list of DSM/SSM measures a range of factors were applied and ranked. The main goals of the DSM/SSM long list evaluation process were:

For the DSM/SSM planned or implemented measures:

- Assess the measures of success and benefits to Halifax Water, the public and the environment.
- Identify challenges and issues Halifax Water is facing.
- Provide recommendations for improvements, if applicable.

For the additional/new DSM/SSM measures:

- Compile a comprehensive list of industry best practice DSM/SSM measures.
- Identify opportunities and challenges in the context of Halifax Water.
- Assess which additional measures could be further considered for future implementation.

The factors included in the evaluation process and the indicators are detailed in **Table 2**.

Table 2 – Long List Evaluation Criteria

Factor	Indicator
Strategy Control	The entity who has control of the strategy
Technical Feasibility	Includes compatibility with existing and future infrastructure, capacity for future growth, system security, technical viability, traffic management, existing utilities and operation & maintenance
Financial / Cost / Affordability	Includes capital cost, lifecycle cost, net present value and institutional capacity (budget availability)
Legal / Jurisdictional	Includes property acquisition, permitting requirements, board approvals, compliance with applicable planning policies, by-law changes, jurisdiction
Environmental	Includes long term effects on environmentally sensitive features, soil/land contamination, water features/resources/source water, geology, hydrogeology and air quality

Factor	Indicator
Social / Cultural	Includes community impacts, effects on existing road infrastructure, noise, vibration, dust and odour impacts, cultural heritage/archaeology impacts, agricultural impacts, financial impact to customer
Probability of Success	By implementing the strategy, what is the probability of successfully - reducing flows/increasing capacity and sustaining that impact
Implementation / Timing	Includes phasing, schedule/timing risk, resource availability
Project Integration	Can the strategy be integrated with current and/or future projects?
Cost-Benefit Analysis	Comparison of the success of the strategy versus the cost of the project - considerations include the ability to monitor the results of the strategy to determine its success

GM BluePlan, in collaboration with Halifax Water, developed a ranking system to classify each measure from least suitable to most suitable. Using the evaluation criteria provided in **Table 2**, a score of either 1 (low benefit - red), 2 (medium benefit – yellow) or 3 (high benefit - green) was given to each factor in the evaluation criteria, to provide an overall score for each measure in the long list. The overall score allowed the measures to be ranked from most suitable strategies to least.

3 Halifax Water's DSM/SSM Measures

A review was conducted to gather information on DSM/SSM measures Halifax Water is currently implementing or is planning to implement in the future. This information included: data collection process and use, issues/challenges, potential enhancements to existing initiatives/programs, and integration opportunities, among others. Discussions with Halifax Water were conducted throughout the process to ensure sufficient detail was gathered on these measures.

A total of 40 DSM/SSM measures were identified through this process. The DSM/SSM measures currently being undertaken by Halifax Water are provided in **Figure 1**.



Figure 1 – Halifax Water's Existing DSM/SSM Measures

Halifax Water's current DSM/SSM measures were evaluated against the evaluation criteria presented in **Table 2**. The DSM/SSM review and evaluation process demonstrated that Halifax Water is currently implementing a wide range of measures across all DSM/SSM categories covering all systems and drivers. The long lists of DSM/SSM measures are provided in **Appendix A**.

The following is a summary of the findings:

- Water measures scored high in the DSM/SSM measures evaluation due to the innovative work Halifax Water is currently doing on their water system. An example of this work is the Infrastructure Leakage Index (ILI). Halifax Water is a leader in North America for actively using ILI to help reduce water loss in the system. Other measures that target water leak identification and control include: night time flow analysis, active leak detection using sonic detection, leak notification program, corrosion control, and pressure management, among others.
- Some of the challenges identified for water DSM/SSM measures were for financial incentives such as rebate/retrofit programs which might require significant amount of funding and/or loss of revenue, and local improvement charges which are currently administered by HRM.

- Similar to the water DSM/SSM measures, Halifax Water has invested significant resources and effort on DSM/SSM measures that target the wastewater and combined systems. Some measures, such as the corporate flow monitoring program, support the implementation and performance indicators of other initiatives such as the inflow and infiltration reduction program, design criteria review and sewer separation.
- Some of the challenges identified for wastewater DSM/SSM measures, were related to the data collection, capital and O&M costs required to support the implementation of these measures. For instance, RDII reduction measures require great amount of data collection to support implementation. Any measure related to implementation of new infrastructure requires capital cost and O&M costs, such as the implementation of a new pumping station.
- Private side RDII reduction is currently being addressed by Halifax Water with a dedicated team. The work focusses on known issue areas and provides enforcement to ensure illegal connections etc. are rectified. There are several challenges with Private side works, such as foundation drain disconnections, may be challenging in areas where existing stormwater sewers are too shallow or do not exist. Downspout and foundation drain disconnections also involve residents, which often requires significant collaboration with HRM and public consultation, and/or incentive programs. Halifax Water has been progressing their Wet Weather Management Program, which includes detailed cost-benefit analyses of different RDII reduction strategies and actively seek effective private side RDII reduction.
- Private-side RDII reduction require significant increased coordination with HRM, the public, and other stakeholders. Halifax Water promotes and ensures private side RDII reduction through educational and enforcement activities. The implementation of these measures is challenging due to multiple jurisdictions, governing and funding sources. It is likely that to be effective new by-laws and approval from the Nova Scotia Utility and Review Board will be required to allow Halifax Water to subsidize or fund work on private property.
- Another outcome of the DSM/SSM review and evaluation was the need for measuring the performance and cost benefit of implementing DSM/SSM measures. Some activities are currently measured though the corporate balance scorecard, such as the water loss control reduction and I/I reduction program. However, further refinement of measurement approach should focus on relating the program to cost to benefit. Performance management of DSM/SSM measures will further support Halifax Water in aligning their resources and systems to meet their strategic objectives. It also has the potential to provide early warning of potential issues or problems that can be mitigated or resolved in a timely manner.
- The current Halifax Water DSM/SSM measures, as listed in **Figure 1**, have an impact on the long-term planning of infrastructure and therefore on the current 2019 IRP Update. **Table 3** provides a list of potential impacts that DSM/SSM measures could have on the IRP Update depending if the measures are related to data collection, education and standards, or hard infrastructure.

Table 3 – Halifax Water DSM/SSM Measures Impact on IRP Update

Type of DSM/SSM Measure	Potential Impact on the 2019 Integrated Resource Plan Update
Data Collection	<ul style="list-style-type: none"> • Informs operations • Prioritizes areas for RDII reduction • Informs Design & Construction Standard Specifications revisions • Provides evidence of effectiveness of initiatives and programs • Informs the decision-making process
Education and Standards	<ul style="list-style-type: none"> • Affects how flow and demands are projected in the future • Aims to reduce demand on the systems • Intent to change user's behaviour • Influences public perception on Halifax Water, services and their role as stewardship of the environment and natural resources
Infrastructure	<ul style="list-style-type: none"> • Sizing of new infrastructure or capacity upgrades • Timing and allocation of resources • Add or free up capacity in the systems • Manage existing and projected demands • Aim to extend lifecycle of assets and better use of resources • Support growth and future developments • Improve overall system performance and reliability

4 Additional DSM/SSM Measures

After identifying the DSM/SSM measures from the long list that are already implemented by Halifax Water, there remained a list of DSM/SSM measures identified during the best practice review, that are not currently implemented by Halifax Water.

The purpose of this step of the DSM/SSM study was to understand what other utility companies and municipalities were currently implementing that are not already in place at Halifax Water. Then to determine if those measures should be considered for future implementation by Halifax Water.

The desktop review of DSM/SSM measures included: information provided on municipality and relevant association websites, infrastructure planning and design guidelines and reports, industry leading standards, published articles and university studies, among others. In addition, GM BluePlan leveraged the knowledge obtained through various projects to further refine the information contained in the DSM/SSM measures review.

Figure 2 presents a summary of the additional measures identified through this process. Additional information can be found in **Appendix A**.




Figure 2 – Additional DSM/SSM Measures

The additional DSM/SSM measures were evaluated against the same evaluation criteria as the current Halifax Water's measures, as presented in **Table 2**. The following is a summary of the findings:

- Financial incentives and utility rates are popular measures in other utilities/municipalities. The purpose of these incentives is to encourage users to implement measures that promote water conservation and protection. Both financial incentives and utility rates may require a significant amount of funding and/or loss of revenue and require a strong business case to gain approval and support for their implementation. It is difficult to measure the direct effectiveness of incentives and also to prioritize spatially where such measures would be most effective in relation to specific infrastructure needs.
- Customer usage measures are intended to change user behaviour. The probability of success for these measures are in the low range since it depends entirely on the users but has the potential to increase when they are combined with financial incentives or regulation restrictions. Halifax's

climate may not support water reduction measures for irrigation as the area receives a lot of precipitation. This would have to be considered prior to pursuing some of these measures.

- Regulation measures can be challenging to implement as they may have legal and jurisdictional implications, such as requiring approvals from Nova Scotia Utility and Review Board (NSUARB) and HRM.
- System upgrades involve the implementation of new infrastructure and/or the use of new technology. These measures can be difficult to get approval or implement due to their technical feasibility and associated high cost, among other factors.
- Halifax Water has a comprehensive approach to water loss and has made many improvements and water loss reduction. As a result, additional measures that target water loss may see diminishing return on investments as the most cost-effective measures have already been implemented.

Additional DSM/SSM measures have shown to be successful in other municipalities and jurisdictions, but due to the above reasons, they were not carried forward as specific standalone solutions for implementation by Halifax Water at this time. However, it is recognized that a combination of existing and new DSM/SSM measures targeting RDII reduction will be required for the successful implementation of the Infrastructure Master Plan wastewater servicing strategy.

5 Halifax Water Collaboration

5.1 Collaboration Process

Throughout the DSM/SSM measures review and evaluation process, Halifax Water have been a key contributor. Halifax Water reviewed and confirmed information provided is correct and up to date and identified any measures that did not adhere to Halifax Water's current objectives and level of service.

Once the long list of measures was developed, Halifax Water reviewed the list and added comments for consideration in the evaluation process. Halifax Water staff input included, but was not limited to:

- Measures currently implemented
- Measures currently planned for implementation
- Issues, barriers or constraints in the planning, funding or implementation process
- Cost/benefit insights on some of the current measures
- Organizational challenges, cost and resources availability
- Legal and jurisdictional considerations

5.2 Summary of Discussions with Halifax Water and NSUARB Consultants

As part of the IRP Update process, several points of contact were held for discussion, feedback and input with Halifax Water's project team and Directors, as well as the consultants retained by the NSUARB to oversee the IRP Update process.

The following presents a summary of some of the discussions throughout the IRP Update in regard to DSM/SSM measures:

October 16th, 2018 – Kick-off Meeting

At the outset of the project, the first kick-off meeting was held with Halifax Water's project team and NSUARB consultants to formally initialize the IRP Update. Following the kick-off meeting, additional meetings have covered the programs and studies that were currently dealing with or impacting DSM/SSM measures, as well as a brief introduction of the IRP study approach for DSM/SSM.

December 12th, 2018 - NSUARB Consultants Workshop

The workshop was held with Halifax Water's project team and the NSUARB consultants to discuss: the DSM/SSM IRP study approach, achieve consensus on key principles heading into the IRP detailed workplan and outline next steps.

March 5th, 2019 – Steering Group Meeting

The meeting was held with Halifax Water's Executive Team and Operations Directors to discuss the DSM/SSM measures, evaluation process and outcomes.

6 Analysis Discussion

Throughout the IRP Update process, it was recognized that DSM and SSM are key aspects for sustainable long-term planning of infrastructure and system optimization, to meet customer demands and maintain an appropriate level of service. In collaboration with Halifax Water's staff, a review of DSM/SSM measures was undertaken to identify what is working for Halifax Water, what could be done to improve or enhance existing measures, and identify from an industry best practice review if other measures could be further considered for future implementation.

The review demonstrated that Halifax Water is currently implementing a wide range of measures across all DSM/SSM categories covering all systems (water, wastewater, stormwater) and drivers (growth, asset renewal, compliance). The review also provided an opportunity to identify recommendations and enhancement opportunities to current DSM/SSM measures. In general, the recommendations resulting from the discussions are centered on continuing the collection of data that support DSM/SS measures, improving integration between programs/initiatives, data and processes. Specific recommendations relate to key performance indicators, public and organizational education and awareness and legislative review to enable private side I/I work in the future.

The review of additional DSM/SSM measures resulted in a list of measures implemented by other utilities/municipalities that are not currently in place by Halifax Water. Most of the additional measures target water demands and water conservation. As discussed in previous sections, Halifax Water currently implements water measures that have proven effective in reducing water demands, promoting water conservation and reducing water loss in the system. Therefore, additional water measures were not recommended.

In regard to wastewater, some of the additional measures that were identified target changes in regulation or financial incentives aimed to reduce rainfall derived inflow and infiltration (RDII) into the wastewater system by for instance implementing new construction practices, downspout disconnection, basement flooding protection practices, among others. While specific measures related to RDII reduction are not directly recommended through this analysis, the IRP recognizes the importance of RDII reduction as an overarching DSM/SSM measure for the management of the wastewater system and for the successful implementation of the Infrastructure Master Plan wastewater servicing strategy.

6.1 Enhancement Opportunities and Recommendations

The following enhancement opportunities and recommendations resulted from the DSM/SSM review and discussion:

Performance Indicators

Through the DSM/SSM review, it became evident that most initiatives/programs would benefit from performance measurement to evaluate their success and effectiveness. The simple principle of "what gets measured, gets done" can be applied to most DSM/SSM measures implemented by Halifax Water. In order to do so, key performance indicators (KPIs) and targets should be developed in accordance with Halifax Water's goals and objectives, drivers and level of service.

Table 4 provide a sample of suggested key performance indicators and targets that can be used to assess the effectiveness of existing DSM/SSM measures. If considered for implementation, these indicators should be reconciled with Halifax Water existing KPI to ensure consistency.

Table 4 – Sample Key Performance Indicators for Existing DSM/SSM Measures

Measure Type	System	Measure	KPI
SSM	Water	Active Leak Detection: % of leaks proactively detected (prior to reported customer issue or billing enquiry) versus total leakage incidents	>95%
SSM	Water	Infrastructure Leakage Index and total losses per service connection. Total leakage measures the sum of distribution losses and supply pipe losses in megalitres per day (Ml/d). It includes any uncontrolled losses between the treatment works and the customer's stop tap.	Leakage index Target <3.0 Losses <200 litres/connection
SSM	Water Wastewater	Per Capita Water & Wastewater Allocation derived from water billing and wastewater flow monitor and treatment flow analysis. Measure actual water usage and wastewater generation	Water: (70% of Design Criteria) < 260 Litres per person per day (L/p/d) Wastewater: (80% of water usage) 210 Litres per person per day (L/p/d)
SSM	Water	Night Flow Analysis to assess possible leakage or unwanted customer internal plumbing losses: Average Nighttime Litres per residential service connection (L/service).	<50 litres/service connection
SSM	Water Wastewater Stormwater	Design Criteria Manual Updates: Complete annual review	Yes/No
SSM	Stormwater	Culvert Replacement Metres replaced/year (m/yr) % of culverts in poor condition	<15% in poor condition
SSM	Water	Transmission Main Upgrades Metres replaced/year (m/yr) % of mains in poor condition	<5% in poor condition
SSM	Wastewater	Flow Monitoring: % of system monitored	>90% system monitored
SSM	Water	Pressure Management for leakage control Megalitres per year saved (Ml/yr)	Implement Measure to inform savings KPI definition
SSM	Water	Corrosion Control: % of at risk metallic pipe protected	Implement Measure to inform KPI definition
DSM	Water	Watermain Lining Programs Metres lined/year (m/yr) % of unlined metallic watermains	Implement Measure to inform KPI definition
DSM	Water	Water Efficiency Program 5 year rolling average of per capita residential consumption reduction	2% per year reduction in 5 year rolling average of actual water consumption
SSM	Wastewater	Optimize Power Requirements Kwh per customer service connection	Implement Measure to inform reduction KPI definition
SSM	Wastewater Stormwater	Sewer Separation: % reduction of combined system. # of sewer separation projects completed per year	>1%/year >1 project per year
DSM	Wastewater	Lateral Repairs Number of customers using lateral loan	Implement Measure to inform KPI definition

Measure Type	System	Measure	KPI
DSM	Water	AMI (Advanced Metering Infrastructure) / Smart Metering % of leaks proactively detected (prior to reported customer issue or billing enquiry) versus total leakage incidents	>95%
DSM	Water Wastewater Stormwater	Public and Customer Education Programs Temporal measurement of number # of website visits	>4x increase in visits following campaign
SSM	Water Wastewater Stormwater	Infrastructure Replacement / Repair. # of pipe failures per 100km	<2 failures/100km
DSM	Wastewater	Sewer Surcharge Rebate Program Volume diverted from sewer	Implement Measure to inform KPI definition
DSM	Water	Water Usage Data % of customers accessing water usage data	>10%
DSM	Water	Leak Notification Program. Number of notices issued	Implement Measure to inform KPI definition
SSM	Wastewater Stormwater	CSO / SSO management Frequency and volume of CSO/SSO discharges	All CSOs: <30/year CSOs on NWA: <10/year All SSOs <10/year
DSM	Water	Rebate & Retrofit Programs # of participants	Implement Measure to inform KPI definition
SSM	Water Wastewater Stormwater	Vulnerability to Climate Change Management Framework Number of assets and asset classes assessed	1 asset class/year
SSM	Wastewater	Optimize Number & Configuration of Pumping Stations Number of pumping station per person	<2500 people/pumping station
DSM	Stormwater	Flood Reduction Program Number of customers flooded by stormwater	Implement Measure to inform KPI definition

Public Education and Organizational Awareness

Public education offers a great opportunity to enhance existing DSM/SSM measures. Public education efforts that are coordinated and integrated with other programs/initiatives have the potential to improve the relationship between Halifax Water and the public and increase customer engagement and participation. This is particularly important for measures such as private RDII reduction or lateral repair programs, where public participation is required for successful implementation. It is also important to ensure that there is a consistent organizational understanding. This relates to Halifax Water, HRM and the NSUARB. The level of understanding required for each organization and the public is different and thus the format and detail of materials should be customized appropriately.

Of paramount importance for public education programs is to ensure that there is prior assessment of approaches to understand costs, benefits and returns on investments. It is recommended that this take the form of a best practice review and organizational and public survey with results used to define appropriate approaches to public education and organizational awareness approaches. Public education approaches should be designed with a general understanding of the DSM/SSM measures that will likely be implemented.

Halifax Water's current public education program includes various distribution forms such as website, pamphlets, surveys and twitter, among others. It also includes some mobile and creative initiatives such

as the “The Shed” which is usually present at popular events and locations throughout the community, so people can stop in and learn more about Halifax Water and what they do.

Halifax Water’s public education can be further enhanced by tailoring some initiatives to the unique needs of specific areas. For instance, in areas identified as high priority for RDII reduction, public engagement can be tailored to not only inform the public about the problem and solutions provided by Halifax Water, but also to inform the customers about how they can participate, what are the benefits of measures such as downspout disconnection, available incentives or rebates programs, as well as by-law enforcement or mandatory participation if applicable. The goal is to keep the public informed and promote collaborative work with government and organizations, in implementing solutions to their issues.

A suggested task list approach to implement this recommendation is as follows:

- Approach to public education best practice review
- Organizational and public survey to baseline current understanding
- Identification of key subject areas in relation to infrastructure needs and future programs
- Evaluation of approaches and selection of preferred
- Creation of materials and implementation of preferred educational programs

It is recommended that a pilot study approach be adopted to test various methods and be able to assess the effectiveness of various approaches. Different methods could be implemented in various locations of similar characteristics with the intent to measure the effectiveness.

Data Collection

Data collection is a critical step in supporting the development and implementation of DSM/SSM measures. For this reason, it is recommended that Halifax Water continue collecting data about their systems through programs such as the Flow Monitoring and Advance Metering Infrastructure (AMI) programs.

For instance, the information collected through the flow monitoring program is valuable for better understanding Halifax Water’s sanitary and combined systems, to identify RDII issues, and is particularly important for future hydraulic model updates and validations. The flow monitoring program supports other initiatives including the Wet Weather Management Program and several Capital Projects, and the data collected can provide evidence of the efficiency of the implementation of RDII reduction strategies.

In addition, the AMI program which is currently in the implementation phase, is expected to increase public education and engagement, and in turn public education programs need to spread awareness of the customer benefits of the AMI program. The data collected has the potential to serve multiple purposes such as advanced rate options, enhanced leak detection, enhance usage analysis feeding into design criteria review, model calibration and water demand projections, among others.

GIS Integration

Management and use of the data collected also plays an important role in long-term planning of infrastructure. As such, it is recommended to improve the linkage and integration between GIS datasets and other programs such as the Asset Management Plans, Conditions Assessments, Capital Budget, Wet Weather Management Program, among others. GIS integration will help to better understand the geographical context of Halifax Water’s assets and systems and to bring efficiencies across the organization while supporting the decision-making process.

Enhanced HRM Integration

It is recommended to continue DSM/SSM coordination with HRM to support finding efficiencies and better ways to integrate projects and programs between the two organizations. Due the nature of the existing shared jurisdiction of the stormwater system, involvement of both Halifax Water and HRM is key for implementation of DSM/SSM measures that require changes in policies, by-laws, and/or the implementation and maintenance of infrastructure such as Low Impact Developments (LID) facilities.

Another area of integration is the coordination between HRM's Roads Program and Halifax Water's linear projects. The main goal is to align projects that have common factors such as location, alignment, timing and resources; and identify potential conflict and/or limitations that could impact project implementation.

It is also recommended that Halifax Water continue to work with HRM in the development and update of population projections, including: baseline population, growth rate and distribution, as they form the foundation of many studies and initiatives including the future updates of the Infrastructure Master Plan and Integrated Resource Plan.

Private-side RDII Reduction

Considering the importance of RDII reduction for Halifax Water's wastewater servicing strategy, it is recommended that Halifax Water and HRM progress work to establish a policy and process to be able to undertake private side RDII works. This will require collaboration with HRM as they update their stormwater/lot grading bylaws and approval for the NSUARB to establish a policy, by-law and revisions to the Rules and Regulations whereby Halifax Water would have more flexibility to undertake works required on private property to meet the goals of RDII reduction in cases where the benefit of the private side work is not directly realized by the property owner (e.g. improvements to system capacity providing for growth). This could leverage the approach taken by Halifax Water on the lead pipe replacement program, where work can now be performed on the privately-owned pipe sections to support the removal of lead from drinking water.

It is important to identify the general preferred approach to private side I/I reduction so that new policy and legislation is supportive and complementary. There are several key areas to decide on an approach to private side I/I reduction, as shown below (**Figure 3**).

WHO?			HOW?				WHAT?
Government Lead	Program Mgr.	Field Work	Approach	Scope	Funding	Public Education	Property Type
Halifax Water	Halifax Water	Halifax Water	Mandatory	Region wide	No Funding	None	ICI
Municipality	Contractor	Contractor	Voluntary	Focused	Part <100%	Community Outreach	Residential
Partnership	Consultant	Consultant		Area based	100%	Mail Only	All

Figure 3 - Considerations for Private Side I/I Program Reduction

The following approach is suggested to progress this important precursory step prior to being able to effectively establish a proactive private side I/I reduction program.

- Best practice review of Private side I/I reduction programs and associated legislative and enforcement approaches.
- High level evaluation and identification of preferred private side I/I reduction approach
- Review of existing legislation and policies
- Identification of legislative opportunities and constraints
- Detailed evaluation and identification of preferred policy and legislative framework approach
- Implementation of policy and legislation with HRM and NSUARB

7 Summary and Conclusions

As part of the 2019 IRP Update process a review of demand side management (DSM) and supply side management (SSM) practices and measures was undertaken. The purpose of the DSM/SSM exercise was to review and evaluate DSM and SSM measures currently in place by Halifax Water, and consider additional measures implemented by other utility companies and municipalities. Through collaboration with Halifax Water staff, each identified measure was reviewed and evaluated to provide recommendations for improvements and select new measures for potential future implementation.

The review demonstrated that Halifax Water is currently implementing a wide range of measures across all DSM/SSM categories covering all systems (water, wastewater, stormwater) and driver type (growth, asset renewal, compliance).

- Potential enhancement opportunities and recommendations to current DSM/SSM measures were discussed during the review process. The following enhancement opportunities and recommendations resulted from the DSM/SSM review and discussion:
- Development of key performance indicators (KPIs) and targets in accordance with Halifax Water's goals and objectives, drivers and level of service.
- Further enhancement of public education including tailoring initiatives for specific area needs, keeping the public informed, and promoting collaborative work with government and organizations.
- Continuing the collection of data that support DSM/SSM measures.
- Improving integration between organizations/jurisdictions, programs/initiatives, data and processes.
- Explore revisions to the Rules and Regulations to allow more flexibility to undertake private side works to meet the goals of RDII reduction.

Appendix A - Long Lists of DSM/SSM measures

Long Lists of DSM/SSM measures - Initiatives currently in place by Halifax Water

Measure Type	Strategy Type	System	IRP Driver	Measure	Description	Who has strategy control?	Technical Feasibility	Cost / Affordability	Legal / Jurisdiction	Environmental	Social / Cultural	Probability of Success	Implementation Timing	Integration Potential	Cost-Benefit Analysis	Overall Score
SSM	Infrastructure Management	Water	Asset Renewal	Infrastructure Leakage Index	Infrastructure leakage index is a ratio between the current annual real losses and unavoidable annual real losses in a system. The lower the infrastructure leakage index value, the closer the system is to its unavoidable annual real losses value, i.e., there is less water loss in the system.	3	3	3	3	3	3	3	3	3	3	3
SSM	Design Criteria	Water Wastewater	Growth	Per Capita Water and Wastewater Allocation Adjustment to Optimal Levels in New Designs	Review and update (if necessary) of HW's water and wastewater design criteria for projecting demands/flows in the systems. Usually undertaken during regular master planning cycle.	3	3	3	3	3	3	3	3	3	3	30
SSM	Infrastructure Management	Water	Asset Renewal	Flow Monitoring - Night Flow Analysis	Night time flow analysis involves calculating leakage based on the measured flow of water into the DMA at night and subtracting the legitimate consumption of water within the DMA during that time. The result provides the real losses in the system at night	3	3	3	3	3	3	3	3	3	3	3
SSM	Design Criteria	Water Wastewater Stormwater	Growth	Design Criteria Manual	Design and construction specifications for water, wastewater and stormwater systems to provide consistency and standardize materials, design criteria and method of construction among developers, consultants and contractors throughout the municipality	3	3	3	3	3	3	2	3	3	3	29
SSM	Infrastructure Replacement / Repair	Stormwater	Asset Renewal Growth	Culvert Replacement	Replacement of culverts due to deterioration causing obstructions in flow	3	3	2	3	3	3	3	3	3	3	29
SSM	System Upgrades	Water	Asset Renewal Growth	Transmission main upgrades	Upgrades to increase capacity to meet water demands	3	3	2	3	3	3	3	3	3	3	28
SSM	Infrastructure Management	Wastewater	Asset Renewal	Flow Monitoring	Monitoring wastewater sewers for inflow/infiltration issues, model calibration, etc.	3	3	2	3	3	3	3	3	3	3	28
SSM	Infrastructure Management	Water	Asset Renewal	Pressure Management	Decreasing pressure within water mains using pressure reducing valves and monitoring points within the distribution system	3	3	3	3	3	3	2	3	3	2	28
SSM	Infrastructure Management	Water	Asset Renewal Compliance	Corrosion control	Using materials such as cathodic protection of metallic pipes or addition of minerals in water to reduce corrosion	3	3	2	3	3	3	3	3	3	2	28
DSM	Water Loss Control	Water	Asset Renewal	Watermain Lining Programs	Watermain re-lining, replacing valves, hydrants, appurtenances	3	3	2	3	3	3	3	2	3	3	28
DSM	Customer Education	Water	Asset Renewal Growth	Water Efficiency Program	Water efficiency and conservation efforts—by residents, businesses, HW and the municipality to protect water sources (lake, groundwater, etc.)	3	3	3	3	3	3	2	3	3	2	28
SSM	System Optimization	Wastewater	Asset Renewal	Optimize power requirements	Pump timing, configuration pumps, optimize operation	3	2	2	3	3	3	3	2	3	3	27
SSM	System Optimization	Wastewater Stormwater	Asset Renewal Growth	Sewer Separation	Separation of combined sewers has the objective of reducing wet weather flows in the sewage system and to Wastewater Treatment Plants. Constructing new storm sewers so that the combined sewer can be converted to sanitary. Full Sewer Separation or Partial Sewer Separation	3	2	2	3	3	2	3	3	3	3	27
SSM	Infrastructure Management	Water	Asset Renewal	Active Leak Detection	Using sonic detection to locate leaks in the water distribution system based on sound propagation	3	3	2	3	3	3	2	3	3	2	27
DSM	Water Loss Control	Wastewater	Asset Renewal	Lateral Repairs	Laterals can become damaged and cause sewer back up and basement flooding	3	3	2	2	3	3	2	2	3	3	26
DSM	Water Loss Control	Water	Asset Renewal	AMI (Advanced Metering Infrastructure) / Smart Metering	Provides "real time" information on water use activities and conservation efforts, and helps customers detect leaks more immediately. Able to notify customers when demand patterns are indicative of potential leakage	3	3	2	3	3	3	2	2	3	2	26

Long Lists of DSM/SSM measures - Initiatives currently in place by Halifax Water

Measure Type	Strategy Type	System	IRP Driver	Measure	Description	Who has strategy control?	Technical Feasibility	Cost / Affordability	Legal / Jurisdiction	Environmental	Social / Cultural	Probability of Success	Implementation Timing	Integration Potential	Cost-Benefit Analysis	Overall Score
DSM	Customer Education	Water Wastewater Stormwater	Asset Renewal Growth Compliance	Public and Customer Education Programs	Improved awareness of efficient water use and its effect on billing in communities through door to door visits, mailed newsletters, information on the municipality's website, school education programs, social marketing campaigns	3	3	2	3	3	2	1	3	3	2	25
SSM	Infrastructure Replacement / Repair	Water Wastewater Stormwater	Asset Renewal	Main replacement / infrastructure repairs / infrastructure renewal	Replacement of old infrastructure mains to avoid breaks and leaks. E.g. replacement of old watermains to avoid watermain breaks and water loss	3	2	1	3	3	3	3	2	3	2	25
DSM	Financial Incentives	Wastewater	Asset Renewal Growth	Sewer Surcharge Rebate Program	Open to industrial, commercial and institutional water customers, the Program offers a rebate on water not discharged into the sanitary sewer system.	3	3	2	2	3	3	2	2	3	2	25
DSM	Customer Usage	Water	Asset Renewal Growth	Water Usage Data	Customers have the ability to login to view their water usage per day. This can help customers find ways of reducing the amount of water they use to save money	3	3	2	3	3	2	2	2	3	2	25
DSM	Water Loss Control	Water	Asset Renewal	Leak Notification Program	Municipality alerts customers if there are spikes in water usage for a certain number of consecutive days. This program is currently being undertaken by New York City	3	2	3	3	3	2	2	2	3	2	25
SSM	System Extension	Water Wastewater Stormwater	Growth	Design/ construction of Greenfield water, wastewater and stormwater infrastructure.	New greenfield infrastructure to service new growth areas. For example, dams, transfer schemes and associated infrastructure, as solutions to meet growing water requirements.	3	3	2	2	2	2	3	3	3	2	25
SSM	Infrastructure Management	Wastewater	Asset Renewal	Inflow/Infiltration Identification and Reduction Program (public side)	I/I identification and reduction program. Might include some of the following: Flow Monitoring , Sanitary Sewer Condition Assessment, Cross Connection Identification	3	2	2	3	3	3	3	2	3	2	26
DSM	Regulation	Stormwater	Compliance	Grading Requirements	Provides erosion protection during construction phase (water quality issues). Grading requirements are needed to improve drainage design and compliance with approved plans	1	2	3	2	3	3	3	2	3	3	25
DSM	Regulation	Wastewater	Compliance	Source Control / Protection	Reducing the amount of contaminants being sent via the sanitary sewer system to WWTF	1	2	2	2	3	2	3	3	3	3	24
SSM	Infrastructure Management	Wastewater Stormwater	Asset Renewal Growth Compliance	CSO/SSO management	Implementation of effective preventive maintenance programs to significantly reduce the frequency and volume of untreated sewage discharges. Management can ensure SSO treatment is prioritized due to the higher concentrations of raw sewage	3	2	3	2	3	3	2	2	2	2	24
DSM	Financial Incentives	Water	Asset Renewal Growth	Rebate & Retrofit Programs	Transitioning to high-efficiency fixtures and appliance (e.g. toilet rebate programs, solar hot water incentive programs, showerhead and washing machine rebate programs) Fixture/Appliance Replacement Programs (e.g. showerheads, washing machines, dishwashers)	3	3	1	2	3	3	2	2	3	2	24
SSM	Infrastructure Management	Water Wastewater Stormwater	Asset Renewal	Vulnerability to Climate Change Management Framework	Takes into account the effects of the changing climate on infrastructure (e.g. capacity, demand, etc.)	3	2	3	2	3	3	2	2	2	2	24
SSM	System Optimization	Water	Asset Renewal Growth	Enhanced redundancy and optimization/routing	Construct new infrastructure to meet demands - supply security	3	3	2	2	2	2	3	2	3	2	24
SSM	System Upgrades	Wastewater	Asset Renewal Growth	Over-sizing pipes / storage	Increase capacity of pipes and storage to meet system demands	3	2	2	3	3	2	2	2	3	2	24
DSM	Utility Rates	Stormwater	Growth	Stormwater rate structure	A fixed rate structure to applicable properties	3	3	3	2	3	2	1	2	3	2	24
SSM	System Optimization	Water	Asset Renewal Growth	Bulk Water Strategy	Involves restricting hydrant use by introducing bulk water stations with swipe card system	3	2	3	2	3	3	2	2	2	2	24
SSM	System Upgrades	Water Wastewater	Asset Renewal Growth	Additional treatment capacity or upgrades	New treatment processes, new treatment plant, new technology (same footprint), rehabilitation of existing facility	3	2	2	3	3	2	3	2	2	2	24

Long Lists of DSM/SSM measures - Initiatives currently in place by Halifax Water

Measure Type	Strategy Type	System	IRP Driver	Measure	Description	Who has strategy control?	Technical Feasibility	Cost / Affordability	Legal / Jurisdiction	Environmental	Social / Cultural	Probability of Success	Implementation Timing	Integration Potential	Cost-Benefit Analysis	Overall Score
SSM	System Optimization	Wastewater	Asset Renewal Growth	Optimize number and configuration of pumping stations	Decrease the need for pumping stations	3	1	1	3	3	3	2	2	3	2	23
SSM	System Upgrades	Stormwater	Asset Renewal Growth	Stormwater Management Ponds	Surface water management is the process of collecting, monitoring and treating surface water to help prevent flooding and pollution.	1	2	2	2	3	2	3	2	3	2	22
DSM	Infrastructure Management	Wastewater	Asset Renewal	Inflow/Infiltration Identification and Reduction Program (Private Side)	I/I reduce the capacity of the sewage system leaving less for existing residents and future growth. It also makes sewage treatment less efficient as the sewage is diluted by water. Increase the cost to residents because sewage treatment plants are required to treat a higher volume of flow. May cause sewage	1	2	2	1	3	3	3	2	3	2	22
SSM	Financial Incentives	Water Stormwater	Asset Renewal Growth	Local Improvement Charges	Fees imposed by the municipality on those property owners in the specific vicinity that benefit from the local improvement	1	2	2	2	3	2	2	2	3	2	21
DSM	Regulation	Stormwater	Compliance	Sediment / Erosion Management	Sediment and erosion control policies and procedures aimed at preventing contamination of watercourses	2	2	3	2	3	2	2	1	2	2	21
DSM	Customer Education	Stormwater	Asset Renewal	Flood Reduction Program	Steps to reduce flooding damage within the municipality and outlines the short term activities required	1	2	2	2	3	2	2	2	2	2	20
DSM	Regulation	Stormwater	Compliance	Comprehensive Controlled Drainage Management	Controlled drainage management to prevent water damage to foundations and basements. Houses, streets and buildings in urban areas depend heavily on surface and subsurface drainage systems for protection. These generally are a combination of plastic or metal gutters, concrete curb and gutter, and concrete pipes or channels.	1	2	2	2	3	2	1	1	1	2	17

Long Lists of DSM/SSM measures - Additional measures for consideration

Measure Type	Strategy Type	System	IRP Driver	Measure	Description	Who has strategy control?	Technical Feasibility	Cost / Affordability	Legal / Jurisdiction	Environmental	Social / Cultural	Probability of Success	Implementation Timing	Integration Potential	Cost-Benefit Analysis	Overall Score
DSM	Regulation	Water / Wastewater / Stormwater	Compliance	New Construction Practices	Water efficiency requirements and standards for new construction projects. Emphasis also needs to be on construction standards, construction inspection certification, and enforcement of non-compliance to HW standards	3	3	3	2	3	2	2	3	3	3	27
DSM	Water Loss Control	Water	Asset Renewal	Pipe Freezing Prevention Plan	Information available to the public to prevent the water pipes from freezing during the winter months	3	3	3	3	2	3	2	3	3	2	27
DSM	Customer Usage	Water	Asset Renewal Growth	Water Efficient Irrigation	Rain and moisture sensors to adjust irrigation schedules based on the local weather (e.g. Low Pressure Center Pivot Sprinkler Irrigation Systems)	3	3	3	3	3	2	1	3	3	2	26
DSM	Customer Usage	Water	Asset Renewal Growth	Drip/Micro-Irrigation System	Small diameter tubing with regular openings, immediately above or below ground level to minimize traveling time to rooting zone. This increases water efficiency and reduced energy costs	3	3	3	3	3	2	1	3	3	2	26
DSM	Customer Usage	Water	Asset Renewal Growth	Water Efficient Landscaping	Water-efficient landscape to reduce customer demands (e.g. native vegetation suited to the area's climate)	3	2	3	3	3	2	1	3	3	2	25
DSM	Utility Rates	Water	Growth	Seasonal Rates	The higher rates promote water conservation during these high peak periods. E.g. water use during the summer months has a higher rate due to the higher demand in water supply.	3	3	3	2	3	2	2	2	3	2	25
DSM	Regulation	Wastewater	Compliance	Downspout Disconnection Program	Residents who have downspout disconnection can apply for the City to subsidize the disconnection. This will reduce the amount of rainwater entering the wastewater system.	3	2	2	2	3	2	3	2	3	3	25
DSM	Regulation	Water / Wastewater	Compliance	Optional Water and Sanitary Sewer Protection Plan	Help educate residential property owners about their responsibilities for the maintaining, repairing and replacing of their private side (from inside their homes to the property line) water and sanitary sewer pipes. Help reduce expenses to property owners and the utility because the plans encourage residents to report water and sewer leaks in a timely manner. Timely water pipe repairs conserve water and reduce water loss for the utility. Timely sewer pipe repairs minimize wastewater pollution helping the environment.	2	3	3	1	3	2	2	3	3	2	24
DSM	Financial Incentives	Wastewater / Stormwater	Asset Renewal Growth	Basement Flooding Protection Subsidy Program	Offering residents a financial subsidy to install a sump pump with sump pump overflow and/or backwater valve(s) and/or disconnect foundation drains from the floor drain.	3	2	2	2	3	3	2	2	3	2	24
DSM	Financial Incentives	Water	Asset Renewal Growth	Water Savings and Protection Incentives for Business	Financial incentives for businesses participating in water protection/conservation	3	3	2	2	3	2	2	2	3	2	24
DSM	Customer Usage	Water	Asset Renewal Growth	Industrial Water Rate Program	Open to industrial water customers, the Industrial Water Rate offers a discounted water rate to manufacturers that implement a water conservation plan.	3	2	2	2	3	3	2	2	3	2	24
DSM	Water Loss Control	Water	Asset Renewal	Water Audits	Helps municipalities and utilities companies detect water loss within their system. Water audit methodology developed by the AWWA and International Water Association	3	3	2	3	3	3	1	2	3	1	24

Long Lists of DSM/SSM measures - Additional measures for consideration

Measure Type	Strategy Type	System	IRP Driver	Measure	Description	Who has strategy control?	Technical Feasibility	Cost / Affordability	Legal / Jurisdiction	Environmental	Social / Cultural	Probability of Success	Implementation Timing	Integration Potential	Cost-Benefit Analysis	Overall Score
DSM	Customer Usage	Water	Asset Renewal Growth	Water Reuse / Reclaimed Water / Greywater Systems	Reclamation of rainwater for irrigation purposes - may have some cost and health & safety concerns. Reclaimed water is wastewater that has gone through various treatment processes to meet specific water quality criteria with the intent of being used again in a beneficial manner (i.e. irrigation and industrial uses).	3	2	3	3	2	1	1	3	3	2	23
DSM	Regulation	Water	Asset Renewal Growth	Indoor/Outdoor Water Use Restrictions	Outdoor Water use restrictions dependent on season and time of day (more expensive during peak periods). Indoor use restriction by issuing plumbing or building permits on new development/renovation projects.	2	3	3	2	3	2	1	2	3	2	23
DSM	Utility Rates	Water	Growth	Water Budget-Based Rates	Rate structure based on anticipated needs of household by number of people or property size. If customer go over their "budget", higher water rate applies	3	2	2	2	3	2	1	2	3	2	22
DSM	Utility Rates	Water	Growth	Increasing Block Rate	Unit price of each succeeding block of usage is charged at a higher unit rate than the previous block	3	3	3	1	3	1	1	2	3	2	22
DSM	Financial Incentives	Water	Asset Renewal Growth	Capacity Buyback Program/ Rebate Program	Open to commercial and institutional organizations, the program offers a free water audit and one-time cash rebate.	3	3	1	1	3	2	2	2	3	1	21
DSM	Regulation	Wastewater	Compliance	Topsoil Bylaw for Residential Lots	Landscaped area to have a minimum of 12-inch topsoil to ensure greater water retention	1	2	3	1	3	2	2	2	3	2	21
SSM	System Upgrades	Wastewater	Asset Renewal	Equipping an existing facility with alternative systems, such as an engineered wetland	Federation of Canadian Municipalities provides funding for wastewater system projects that demonstrate new solutions or approaches to wastewater systems	3	1	3	2	3	3	1	1	2	2	21
DSM	Financial Incentives	Water	Asset Renewal Growth	Tax Incentives	Tax incentive to help mitigate the difference in costs between a non water-efficient fixture vs. a water-efficient fixture - for existing and new construction	1	2	2	2	3	3	2	2	2	1	20
DSM	Financial Incentives	Water / Wastewater / Stormwater	Asset Renewal Growth	Development Incentive Programs	Incentive for new developments for water conservation	1	2	2	2	3	3	2	2	2	1	20
DSM	Financial Incentives	Stormwater	Asset Renewal Growth	Eco-roof Incentive Program / Green roof bylaw	Green roofs support the growth of vegetation and consists of a waterproofing membrane, drainage layer, organic growing medium (soil), and vegetation.	1	2	2	2	3	2	1	2	3	2	20
SSM	System Upgrades	Stormwater	Asset Renewal Growth	Low Impact Development / Source Controls	The design of land to manage stormwater runoff as part of green infrastructure. LID emphasizes conservation and use of on-site natural features.	1	2	2	1	3	3	2	2	2	2	20
SSM	System Upgrades	Wastewater	Asset Renewal Growth	Composting System in WWTF	Wastewater treatment facility with a composting system that eliminates sludge from the treatment process and returns high quality effluent to water body	3	1	1	2	3	2	2	1	2	2	19



HALIFAX WATER
2019 INTEGRATED RESOURCE PLAN

APPENDIX A.3

COSTING AND EXPENDITURE ANALYSIS



Halifax Water

2019 Integrated Resource Plan

Technical Memorandum #3:
Expenditure Summary and Costing Review

Project No.: 718032



Prepared by: GM BluePlan Engineering
For: Halifax Water
March 2020

Document Revisions

The following is a record of the changes/updates that have been made to the final document:

Version	Changes / Updates	Author	Reviewed	Date
DRAFT	1 st Draft for Review	Sandy Naime	Chris Campbell James Jorgensen	Jan 31 st 2020
FINAL	Final Report	Sandy Naime	Chris Campbell	March 13, 2020

Table of Contents

1	Introduction	4
1.1	Aim.....	4
1.2	Objectives	4
2	Expenditure Summary.....	5
2.1	Infrastructure Master Plan	5
2.2	Compliance Plan	6
2.3	Asset Management Plans (AMPs)	6
2.4	Corporate Projects.....	8
3	Costing Analysis.....	9
3.1	Analysis Approach.....	9
3.2	Assumptions and Considerations	10
4	Cost Estimating Approach.....	16
4.1	Unit Costing Template	16
4.2	RDII Reduction Cost Estimation	17
5	Conclusions and Recommendations	18

Appendices

- Appendix A – Infrastructure Master Plan Program
- Appendix B – Compliance Plan Program
- Appendix C – Asset Management Plan Program
- Appendix D – AMPs Expenditure Needs Analysis
- Appendix E – Cost Comparison
- Appendix F – Unit Cost Tables
- Appendix G – Sample Costing Sheet
- Appendix H – Sample RDII Costing Sheet

1 Introduction

The Halifax Regional Water Commission (HRWC), also known as Halifax Water, was the first regulated and publicly owned water, wastewater and stormwater utility in Canada. With a long history dating back to the 1940s, Halifax Water is the water, wastewater and stormwater utility servicing residents of the Halifax Regional Municipality (HRM).

As part of its mandate and services, Halifax Water continuously undertakes initiatives and programs to maintain and operate its systems while striving to provide world class service to its customers and environment. These initiatives and programs require integration into a single capital program that identifies the long-term resource needs and financial expenditures.

Halifax Water retained GM BluePlan Engineering Limited (GM BluePlan) to complete the Integrated Resource Plan (IRP) Update. The IRP Update is a study to consolidate various initiatives and programs from separate studies into a singular integrated capital and financial plan. This study applies the considerations of growth, regulatory compliance, and asset renewal to ensure the integrated recommendations achieve the desired service delivery goals, as well as identify any additional gaps and programs required in the long-term plan.

The IRP Update will build on the foundation of the 2012 IRP. The 2012 IRP focused on capital program and project requirements, developed a planning framework including Halifax Water's business processes, and provided recommendations including the periodical update of the IRP.

1.1 Aim

The aim of the Expenditure Summary and Costing Review is to first outline and summarize Halifax Water's projected expenditures prior to program and project integration and then summarize the costing review exercise undertaken as part of the 2019 IRP Update.

1.2 Objectives

The goals and objectives for the expenditure summary and costing review are:

- Gain understanding of projected expenditures from the corporate projects and the three foundational studies: Asset Management Plans, Infrastructure Master Plan and Compliance Plan.
- Review all asset categories/classes covered in the Asset Management Plans and improve the replacement cost estimates for asset classes with low confidence.
- Review the alignment between Halifax Water Infrastructure Master Plan, Compliance Plan and Asset Management Plans costing approaches.
- Provide recommendations for unit costs and replacement cost adjustments to update into foundational studies if necessary.
- Describe Halifax Water's cost estimating approach and unit rates for linear and vertical infrastructure, as well as RDII reduction projects.

Completing these objectives will provide confidence, transparency and traceability to support the funding streams.

2 Expenditure Summary

The approach taken in the expenditure summary identifies the magnitude of the total and average annual expenditures required to meet level of service objectives in each of the foundational studies and corporate projects:

1. Infrastructure Master Plan
2. Compliance Plan
3. Asset Management Plans (AMPs)
4. Corporate Projects

The expenditure summary below presents projected expenditure needs prior to any project/program integration as part of the 2019 IRP Update. The objective of the expenditure summary is to provide a high-level overview of the input capital programs that served as the starting point for the 2019 IRP Long-Term Capital Plan.

2.1 Infrastructure Master Plan

The Infrastructure Master Plan focuses on the servicing strategies and management of infrastructure in the Halifax Region, to produce an optimal servicing strategy for the wastewater collection and water supply networks to meet growth. The Infrastructure Master Plan provided key inputs to the 2019 IRP Update including planning projections and growth areas, and water and wastewater capital projects to 2046 including timing, cost estimates and spatial allocation.

Expenditure needs as identified through the Infrastructure Master Plan until the end of the planning horizon in 2046 are summarised in Table 1 below. The full capital program is presented in more detail in Appendix A.

Table 1 – Infrastructure Master Plan Projected Expenditure Need

System	Project Category	Total Capital Cost (2019\$M)
Water	Pockwock - Peninsula	\$39.4
	Pockwock - Other	\$61.7
	Lake Major	\$32.8
	System Interconnections	\$150.1
	Studies	\$0.7
Wastewater	Dartmouth Servicing	\$104.4
	Eastern Passage	\$49.5
	Mill Cove	\$163.5
	West Region	\$186.3
Total*		\$788.3
Infrastructure Master Plan Average Annual Expenditure Need (2019-2046)		29.2

*Projected expenditure needs as per the Infrastructure Master Plan prior to program integration for the IRP Update.

2.2 Compliance Plan

The Compliance Plan provides a review of the current state of Halifax Water's infrastructure compliance requirements. The main goal of the compliance plan is to document the long term (30 years) infrastructure needs related to compliance and to ensure continued compliance requirements are met for Halifax Water's wastewater, water and stormwater systems. The plan examines Wastewater Treatment Facilities (WWTF), wastewater collection systems, sanitary and combined sewer overflows, Water Supply Plants (WSP), and water distribution systems including water storage reservoirs.

The Compliance Plan provided key inputs to the 2019 IRP Update including detailed treatment compliance assessment for WWTFs and WSPs, and capital program including timing, cost estimates and location.

Major projects from the Compliance Plan include:

- Lake Major and J.D. Kline WSP upgrades
- WWTFs upgrades to meet Wastewater Systems Effluent Regulations
- Corporate Flow Monitoring Program
- Wet Weather Management Program

A summary of the Compliance Plan capital program is presented in Table 2 below. The Compliance Plan capital program is presented in more detail in Appendix B.

Table 2 – Compliance Plan Projected Expenditure Need

System	Project Category	Total Capital Cost (2019\$M)
Water	Water Treatment	\$109.2
	Water Distribution	\$0.6
Wastewater	Wastewater Treatment	\$388.1
	Wastewater Collection	\$272.9
Total*		\$770.8
Compliance Plan Average Annual Expenditure Need (2019-2048)		\$25.7

*Projected expenditure needs as per the Compliance Plan prior to program integration for the IRP Update.

2.3 Asset Management Plans (AMPs)

The Asset Management Plans (AMPs) provide a summary of asset inventory and state of Halifax Water's infrastructure, level of service the assets provide to the customers, infrastructure replacement and maintenance strategies, and associated costs and expenditures. Halifax Water currently updates the AMPs on an annual basis.

The AMPs structure consists of individual AMPs covering 14 different asset class as follows:

- | <u>Water</u> | <u>Wastewater</u> | <u>Stormwater</u> |
|---|---|--|
| <ul style="list-style-type: none"> • Supply Plants • Supply Dams • Chambers & Booster Stations • Transmission Mains • Distribution Mains • Service Reservoirs | <ul style="list-style-type: none"> • Treatment Facilities • Pumping Stations • Gravity Sewers • Force mains | <ul style="list-style-type: none"> • Management Structures • Gravity Sewers • Cross Culverts • Driveway Culverts and Ditches |

The 2017-2018 Asset Management Plan was used to determine the asset renewal needs for the existing water, wastewater and stormwater system. A review of the level of detail of the data for each asset class was completed, particularly regarding: condition source, replacement costs and granularity of the data. A reassessment of replacement costs was also completed and discussed in Section 3 of this report.

The expenditure needs determined for the different asset classes are provided in The Asset Management Plans are presented in more detail in Appendix C.

Table 3. The Asset Management Plans are presented in more detail in Appendix C.

Table 3 – 2017/2018 AMPs Projected Expenditure Need

System	Asset Group	AMP 30-year Average Annual Expenditure Need (2019\$M)	2017-2018 AMP Replacement Cost (2019\$M)	Annual Reinvestment Rate
Water	Supply Plant	\$11.2	\$312	3.6%
	Supply Dam	\$0.2	\$44	0.4%
	Booster Station	\$0.2	\$18	1.0%
	Reservoir	\$1.0	\$96	1.0%
	Chambers	\$0.3	\$16	2.1%
	Transmission Main	\$6.6	\$660	1.0%
	Distribution Main	\$12.0	\$1,619	0.7%
Wastewater	Treatment Facility	\$12.5	\$652	1.9%
	Pumping Station	\$12.5	\$305	4.1%
	Gravity Sewer	\$4.9	\$1,728	0.3%
	Force Main	\$4.0	\$300	1.3%
Stormwater	Management Structure	\$0.0	\$0	0.0%
	Gravity Sewer	\$7.0	\$1,677	0.4%
	Cross Culvert	\$2.2	\$293	0.8%
	Driveway Culvert	\$0.7	\$66	1.1%
	Ditches	\$0.0	\$0	0.0%
Total*		\$75	\$7,785	1.0%

*Projected expenditure needs as per the 2017-2018 AMPs prior to replacement costs update for the 2018-2019 AMPs and subsequent program integration for the IRP Update.

A more detailed review of the 2017-2018 AMPs was documented in the Expenditure Needs workbook is provided in Appendix D.

2.4 Corporate Projects

Halifax Water Corporate Projects serve a variety of purposes such as maintaining/updating information systems, building capital improvements, improving customer experience with Halifax Water, among others. Corporate Projects can be classified into seven categories:

- Information Technology (IT)
- Geographic Information System (GIS)
- Asset Management
- Facility
- SCADA & Other Equipment
- Fleet
- Studies, Programs & Initiatives

A summary of the Corporate Projects is presented in Table 2 below.

Table 4 – Corporate Projects Projected Expenditure Need

System	Total Capital Cost (2019\$M)
Water	\$199
Wastewater	\$186
Stormwater	\$42
Total*	\$427
Corporate Projects Average Annual Expenditure Need (2019-2048)	\$14.2

*Projected expenditure needs for Corporate Projects prior to program integration for the IRP Update.

3 Costing Analysis

The results from the expenditure needs summary identified an opportunity to review, refine, update and integrate base unit costing for the three foundational studies (Infrastructure Master Plan, Compliance Plan and AMPs). Cost estimation practices have an impact on capital costing, new infrastructure costs, target reinvestments rates, RDC rates and assumptions incorporated into the capital programs. Therefore, it was considered vital that the base cost estimating assumptions for asset renewal, growth and compliance driven projects were aligned.

All AMPs for each asset class were reviewed to establish confidence in the data sources. Through discussions with the Halifax Water team, the following 5 asset classes were identified to have low confidence in replacement costs and could benefit from further assessment: Water Supply Plants, Wastewater Treatment Facilities, Wastewater Pumping Stations, Wastewater Force mains, Stormwater Management Structures.

The goals and objectives for the costing analysis were:

- Improve the replacement cost estimates for asset classes with low confidence;
- Review the alignment between Halifax Water Infrastructure Master Plan and Asset Management Plans costing approaches;
- Provide recommendations for unit costs and replacement cost adjustments if necessary.
- Provide confidence, transparency and traceability to support funding streams.

3.1 Analysis Approach

The costing analysis consisted of a desktop exercise completed to compare multiple sources of costing data/information. The analysis approach can be summarized in the following seven steps:




Figure 1 – Costing Analysis Approach

3.2 Assumptions and Considerations

It was important that the replacement costs and unit costs were compared on a like-for-like basis, therefore the following assumptions and considerations were used in the analysis:

- For vertical assets, all-in replacement costs were analyzed and compared. All-in replacement costs are inclusive of project design and construction costs.
- For linear assets, there were varying levels of uncertainty which resulted in different assumptions to all-in replacement costs. Therefore, the base unit rates for all linear assets were used in the analysis. Base unit rates do not account for other costs such as engineering and design, contingency, etc.
- When required, costs were inflated to 2019 dollars using an inflation rate of 2%, informed through a forecast of Non-Residential Buildings Construction Price Index collected by Statistics Canada.

Step 1 - Gather benchmark costs for different asset classes

Benchmark replacement costs from various data sources were compiled for most asset classes. The main sources of information for this analysis are described in Table 5 below.

Table 5 – Replacement Cost Analysis Sources

Source	Description
Halifax Water AMP (2017-2018)	Replacement costs and unit costs provided in the AMP are described the Expenditure Needs Analysis workbook provided in Appendix D.
Halifax Water Infrastructure Master Plan (2019)	The Infrastructure Master Plan rates were established in the preparation of the Functional Plan and WRWIP, and further updated during the Master Plan development process.
Modelling the Cost of Infrastructure Environmental Protection Agency (EPA) (2003)	United States EPA completed an update to a previous study in 1999 to estimate the 20-year capital investment needs of public water systems by developing cost curves for various water and wastewater assets.
Water and Wastewater Asset Cost Study Ministry of Public Infrastructure Renewal (MPIR) (2005)	The Ontario MPIR completed a study in 2005 to provide life cycle costing information to assist in determining investment needs in the water and wastewater sector.
Various Municipal Replacement Cost and Unit Cost Data	GMBP leveraged their knowledge base of information from past projects and experiences. This included Ontario municipalities of populations ranging from less than 25 thousand to over 2 million. Data sources were collected from AMPs, Infrastructure Master Plan, State of Infrastructure reports, etc. Further descriptions are included in the Cost Comparison provided in Appendix E.

Step 2 - Compare AMPs cost estimates to benchmark using cost curves analysis

As part of the costing analysis, cost comparison charts were developed for each asset class as follow:

- For vertical infrastructure, the capacity of the facilities was plotted against the total facility replacement cost.
- For linear infrastructure, base unit costs were plotted against the size/diameter of the linear assets (e.g. watermains, sewers, forcemains).

The figures below present a sample of the cost comparison charts for the asset classes identified with low confidence in their replacement cost. It should be noted that out of the five asset classes identified, stormwater management structures did not have enough available information to develop a comparison chart. The remaining asset classes are provided in the Cost Comparison workbook in Appendix E.




Figure 2 – Water Supply Plant (<20,000 m3/day) Comparison Chart




Figure 3 – Water Supply Plant (>=20,000 m3/day) Comparison Chart




Figure 4 – Primary Wastewater Treatment Facility Comparison Chart




Figure 5 – Secondary Wastewater Treatment Facility Comparison Chart



Figure 6 – Tertiary Wastewater Treatment Facility Comparison Chart




Figure 7 – Wastewater Pumping Station Comparison Chart




Figure 8 – Wastewater Forcemain Comparison Chart

Step 3 - Compare confidence in existing costs versus benchmark

The confidence of the data sources was assigned using Table 4.

Table 6 – Confidence Scale

Letter Rating	Description
A	High confidence; no major assumptions; reliable source; completed for asset management purposes; no data gaps.
B	Moderate confidence; no major assumptions; data moderately reliable; no data gaps; may be out of date.
C	Low confidence; lack of details around values; some data gaps; major assumption used (out of date inventory or study, anecdotal, etc.)
D	Very low confidence; uncertainty on how values were determined; significant data gaps; unsure of assets included; unsure of what is included in the cost.

Step 4 - Agree use of cost estimates for AMPs updates

Step 5 - Review need to align AMP/Infrastructure Master Plan Cost Unit Rates

Steps 4 & 5 were completed simultaneously. Several meetings were held with Halifax Water's Asset Management team to discuss the results of the benchmark cost comparison and provide recommendations for replacement adjustment and alignment among the plans.

The following recommendations were carried forward for inclusion in the 2018-2019 AMPs update:

- Adjust Replacement Cost for Vertical Infrastructure:
 - Water Supply Plants – except for backup plans
 - Water Booster Stations
 - Water Reservoirs
 - Wastewater Pumping Stations

- Adjust Base Unit Cost for Linear Infrastructure:
 - Transmission and Distribution Mains
 - Wastewater Gravity Sewers
 - Force mains
 - Stormwater Gravity Sewers

The following recommendations were carried forward for inclusion in the Infrastructure Master Plan:

- Adjust Base Unit Cost for:
 - Water Supply Plants
 - Water Booster Stations
 - Water Reservoirs

Step 6 - Feed new cost estimates into AMP and Infrastructure Master Plan (if applicable)

Replacement and base unit cost recommendations were incorporated into the 2018-2019 AMPs and the final capital program of the Infrastructure Master Plan.

Step 7 - Revise AMPs and provide for inclusion into IRP Update

Revised 2018-2019 AMPs were provided for inclusion in the 2019 IRP update prior to the beginning of integration process. The following table presents the update AMPs projected expenditure needs.

Table 7 – 2018-2019 AMPs Projected Expenditure Need

System	Asset Group	AMP 30-year Average Annual Expenditure Need (2019\$M)	2017-2018 AMP Replacement Cost (2019\$M)	Annual Reinvestment Rate
Water	Supply Plant	\$10.3	\$306	3.4%
	Supply Dam	\$0.3	\$44	0.6%
	Booster Station	\$0.2	\$17	1.0%
	Reservoir	\$1.1	\$95	1.2%
	Chambers	\$0.4	\$51	0.7%
	Transmission Main	\$9.1	\$691	1.3%
	Distribution Main	\$10.3	\$1,384	0.7%
Wastewater	Treatment Facility	\$13.2	\$652	2.0%
	Pumping Station	\$11.6	\$573	2.0%
	Gravity Sewer	\$5.5	\$1,714	0.3%
	Force Main	\$1.6	\$275	0.6%
Stormwater	Management Structure	\$0.4	\$42	0.8%
	Gravity Sewer	\$5.4	\$1,369	0.4%
	Cross Culvert	\$2.2	\$268	0.8%
	Driveway Culvert	\$0.7	\$66	1.1%
	Ditches	\$0.9	\$56	1.5%
Total*		\$73	\$7,602	1.0%

*Projected expenditure needs as per the 2018-2019 AMPS prior to program integration for the IRP Update.

4 Cost Estimating Approach

This section outlines Halifax Water's established approach to cost estimation of capital projects through the application of the Cost Estimation Framework (CEF). Halifax Water's CEF was developed as part of the West Region Wastewater Infrastructure Plan (WRWIP) and most recently updated through the Infrastructure Master Plan with knowledge gained through an industry best practice review. This framework has been tailored to Halifax Water's needs and provides a uniform and consistent approach to estimating project costs, ultimately narrowing the gap between cost estimates and final project budgets.

4.1 Unit Costing Template

The unit costing template was originally developed as part of the WRWIP and was updated in 2019 during the completion of the Infrastructure Master Plan. Updates included revised unit rates based on new information, new costing components especially for water infrastructure, and overall adjustments for inflation.

The key unit rate categories that form the basis of the master planning costing template are as follows:

- Linear infrastructure is costed per metre of pipe based on type (sewer, forcemain, watermain, tunnel), diameter, and depth. Additional unit costs are applied as required for creek, road, and utility crossings. An uplift is used for construction in certain areas known to have higher costs, such as on the urban peninsula.
- Vertical infrastructure costing varies depending on the facility type; pumping stations are costed per litre capacity and storage costed per cubic metre useable volume.
- A range of unit costs for water and wastewater treatment capacity were developed based on previous Integrated Resource Plan 2012 study and discussions with Halifax Water.

Other Construction Costs

Construction costs associated with Engineering and Design, Geotechnical, Hydrogeological, and Professional Fees, Construction Management and Contract Administration, and Property Requirements are assigned as percentage rates.

Contingency Costs

The accuracy of capital project cost estimates varies depending on a given phase of planning and design. The Cost Estimation Framework contains a classification system to categorize these different phases, each with a varying level of costing accuracy depending on the current stage of project development:

- **Class 4: Planning Cost Estimate**
 - High-level concept screening
 - Justification for project funding
 - Lowest accuracy, highest contingency
- **Class 3: Concept Design Cost Estimate**
 - Basis for budgeting and approvals
- **Class 2: Preliminary Design Cost Estimate**
 - Basis for project cost control during detailed design
 - Initial detailed cost estimate

- **Class 1: Detailed Design Cost Estimate**
 - Final cost review before construction
 - Ready for tender
 - Highest accuracy, lowest contingency

An contingency rate is applied to the construction costs depending on the Class Estimate Type (e.g. 10% contingency for Class 1 up to 30% contingency for Class 4). It should be noted that due the preliminary nature of the study, all capital projects identified in the Infrastructure Master Plan are categorized as Class 4, with 30% contingency costs.

Peer Review

The unit costing tables developed for the Infrastructure Master Plan were peer-reviewed by DesignPoint Engineering & Surveying Limited and Halifax Water staff, who provided valuable local expertise and insight on material, construction, and contingency costs. DesignPoint assisted in identifying uncommon pipe sizes for omission from the costing template, classifying the most common material choice for pipes based on diameter, and revising individual unit rates for watermains and forcemains based on pipe depth, material, and installation date.

The unit cost tables used to develop the capital programs for the preferred infrastructure servicing strategies are provided in Appendix F. An example of a detailed costing sheet developed for a key wastewater capital project through the Infrastructure Master Plan is provided in Appendix G.

4.2 RDII Reduction Cost Estimation

Rainfall-derived inflow and infiltration (RDII) reduction was an integral component of the overall Infrastructure Master Plan wastewater strategies. A RDII Costing Template was developed to provide consistency for these difficult to estimate capital needs. This template incorporates a costing methodology that takes into consideration specific catchment parameters such as area, land use, number of manholes, and length of sewer pipe. Preliminary unit costing rates were based on GM BluePlan's previous project experience and cross referenced with multiple case studies from the USA and Canada.

As part of the development of the RDII Costing Template, an industry review was undertaken on case studies from several United States municipalities. The industry review provided historic information for different RDII reduction programs including total program cost as well as a range of unit costs including cost per manhole, cost per unit length of sewer, cost per individual property connection, and cost per unit area. Age and condition of infrastructure, physical catchment characteristics, and presence of direct stormwater network connections like downspouts and foundation drains can vary substantially depending on location, often within the same municipality. It is important to note that depending on the scale and success of each program, the final program cost may differ significantly from an original cost estimate. As a result, program costs were highly variable for case study. The unit rates used in the RDII Costing Template generally agreed with the unit rates derived from the industry review.

An example of a RDII reduction costing sheet used to estimate the cost for extraneous flow removal in a targeted area is provided in Appendix H.

5 Conclusions and Recommendations

As part of the 2019 IPR Update process, an expenditure analysis was undertaken to identify the magnitude of annual expenditures required to meet the drivers of growth, compliance and asset renewal. The results from the expenditure needs analysis identified an opportunity to review, refine, update and integrate base unit costing for the three foundational studies through a high-level desktop costing analysis. The costing analysis compared multiple sources of costing data/information and resulted in the following recommendations:

- Annual review of all unit rates (linear and vertical).
- Enhance cost estimating approach for vertical facilities (e.g. pumping stations, storage facilities, treatment plants).
 - By updating the cost estimation approach on an ongoing basis for vertical infrastructure, their unit rates can be broken down into sub-categories, like different sizing costs for linear infrastructure.
 - For example, costing for new pumping stations would not be limited to a unit cost per litre of pumped sewage; this cost could also account for approximate land requirements, wet/dry well depth, number of pumps, etc.
- Develop a more detailed approach for complex facilities that may include unit rates for subcomponents.
- Continue benchmarking construction projects.

Additional recommendations with respect to the Infrastructure Master Plan and RDII reduction are:

- Enhance RDII reduction unit costing methodology in future Infrastructure Master Plan updates by expanding the industry review for more recent program costing in other North American municipalities.
- Future updates to RDII reduction costing should account for pre-implementation program cost estimates in Halifax Water's target areas and compare with actual post-implementation costs and success rates. This data will be used to provide additional justification for future RDII reduction and improve the accuracy of cost estimation based not only on other North American municipalities' RDII reduction programs, but from efforts within the Halifax area itself.
- Track separate implementation costs and efficacy of both public and private side RDII reduction, as these metrics may vary significantly between different areas within the same sewershed.

Appendix A – Infrastructure Master Plan Program

Executive Summary Table 3: Wastewater Capital Program Summary

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)
West Region: Halifax	WR1	WRWIP: Spring Garden Area Sewer Separation	<i>Full separation of Spring Garden LoWSCA pocket - 5 individual projects</i>	2018-2023	2016-2021	\$ 7,281,000
	WR2	WRWIP: Young Street Area Sewer Separation	<i>Full separation of Young Street LoWSCA pocket - 18 individual projects</i>	2018-2023	2016-2021	\$ 21,879,000
	WR3	WRWIP: Sewer Separation Upstream of Kempt CSO	<i>Full separation of a portion of the Kempt CSO sewershed - 17 individual projects</i>	2018-2025	2016-2021	\$ 14,752,000
	WR4	WRWIP: Linear Upsize - Quinpool Road	<i>525mm ø combined sewer upsize along Quinpool Road (from Preston to Oxford)</i>	2020	2016-2021	\$ 437,000
	WR5	WRWIP: Linear Upsize - Gottingen & Cogswell Area	<i>750mm ø combined sewer upsize along Portland Place (from Saunders to Brunswick) + 900mm ø combined sewer upsize along Brunswick Street</i>	2020	2016-2021	\$ 221,000
	WR6	WRWIP: Gottingen Street and North Street Intersection Flow Split	<i>Lower the invert of the combined sewer along Gottingen, on the south side of North Street</i>	2020	2016-2021	\$ 500,000
	WR7	WRWIP: Young Pumping Station Upgrade	<i>New 300mm diameter alignment + Installation of new pumps to increase the station capacity from 114L/s to 250L/s</i>	2027	2026-2031	\$ 2,169,000
	WR8	WRWIP: New Fairfield Holding Tank	<i>New 3,700 cubic metre holding tank at the existing Fairfield Holding Tank site</i>	2046	2041-2046	\$ 12,403,000
	WR9	WRWIP: Replace Armdale Pumping Station Force mains	<i>Upsize the existing 300mm ø Armdale Pumping Station force mains with new twinned 400mm ø force mains</i>	2020	2016-2021	\$ 3,850,000
Halifax Inflow and Infiltration	WR13	WRWIP: RDII Reduction Program	<i>Implement an Inflow and Infiltration Reduction Program within the Fairview, Clayton Park, and Bridgeview areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)</i>	2020	2016-2021	\$ 15,491,589
Halifax Fairview Cove Tunnel	WR19	WRWIP: Fairview Cove Linear Upsize	<i>Upsize existing 1050mm ø tunnel to 1800mm ø</i>	2019	2016-2021	\$ 19,781,000
Wastewater Treatment Facility	WR20	WRWIP: Halifax Treatment Plant Capacity Upgrade	<i>Increase the rated capacity of Halifax WWTF from 134 MLD to 140 MLD</i>	2041	2036-2041	\$ 25,142,000
Halifax Greenfield	WR21	WRWIP: Linear Upgrades within the Kearney Lake Road Area	<i>Sanitary sewer upgrades downstream of the Kearney Lake Road Pumping Station</i>	2033	2031-2036	\$ 2,997,000
Halifax Flow Optimization	WR22	Infrastructure Master Plan: CSO Management Study	<i>Monitor and assess CSO facilities to mitigate discharges (16 facilities). Costed at \$14,000/monitor and \$15,000/CSO for assessment.</i>	2026	2016-2021	\$ 965,000
	WR23	Infrastructure Master Plan: SSO Management Study	<i>Monitor and assess SSO facilities to mitigate discharges (6 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.</i>	2021	2016-2021	\$ 415,000
HALIFAX Total Wastewater Servicing Strategy Cost						\$ 128,283,589



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)
West Region: BLT	BLT WWTF Decommission	WR10	WRWIP: BLT WWTF Decommission - New Timberlea PS	2020	2016-2021	\$ 5,928,000
		WR11	WRWIP: BLT WWTF Decommission - New Timberlea Force main			\$ 19,436,000
		WR12	WRWIP: BLT WWTF Decommission			\$ 500,000
	BLT Diversion to Herring Cove	WR14	WRWIP: BLT Flow Diversion to Herring Cove - New Crown Drive Pumping Station	2033	2031-2036	\$ 8,063,000
		WR15	WRWIP: BLT Flow Diversion to Herring Cove - New Crown Drive Force main			\$ 9,026,000
		WR16	WRWIP: BLT Flow Diversion to Herring Cove - New Gravity Sewer			\$ 4,319,000
		WR17	WRWIP: BLT Flow Diversion to Herring Cove - New Gravity Sewer			\$ 3,266,000
BLT Total Wastewater Servicing Strategy Cost						\$ 50,538,000
Herring Cove	Herring Cove Linear Upsizing	WR18	WRWIP: Herring Cove Road - Gravity Sewer Upsize	2033	2031-2036	\$ 7,439,000
HERRING COVE Total Wastewater Servicing Strategy Cost						\$ 7,439,000
WEST REGION Total Wastewater Servicing Strategy Cost						\$ 186,260,589



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)	
Central Region: Mill Cove and Springfield Lake	Trunk Upgrades	MC1	Trunk Sewer Upgrades	<i>Sackville Trunk Upgrades to 1200mm diameter</i>	2036	2036-2041	\$ 5,101,000
		MC2	Trunk Sewer Upgrades	<i>Sackville Trunk Upgrades to 1050mm diameter</i>	2036	2036-2041	\$ 8,246,000
		MC3	Trunk Sewer Upgrades	<i>Sackville Trunk Upgrades to 1500mm diameter</i>	2036	2036-2041	\$ 144,000
	Storage tank Upgrades	MC4	Storage Tank	<i>Offline storage tank near Sackville Goodlife Fitness Centre (5ML)</i>	2031	2031-2036	\$ 17,469,000
	Upgrades to Pumping Stations	MC5	Fish Hatchery Park Pumping Station Upgrade	<i>Upsize existing 450mm forcemain from Fish Hatchery Park PS to 675mm diameter and increase pumping capacity to 1500 L/s with an addition of 100 L/s capacity</i>	2036	2031-2036	\$ 10,529,000
		MC6	Pumping Station (Beaver Bank #3 PS and Majestic Avenue PS)	<i>Increase pumping capacity at Beaver Bank #3 PS from 55 L/s to 100 L/s, and increase pumping capacity of Majestic Avenue PS from 82 L/s to 165 L/s to eliminate growth-impacted SSO discharge</i>	2036	2036-2041	\$ 1,090,000
	Wastewater Treatment Facility	MC7	Mill Cove Wastewater Treatment Plant Capacity Upgrade	<i>WWTF Upgrade</i>	2021	2021-2026	\$ 89,256,000
	Inflow and Infiltration	MC8	RDII Reduction Program FMZ07, FMZ10, & FMZ40	<i>Implement an Inflow and Infiltration Reduction Program within the Lower Sackville areas FMZ07, FMZ10, & FMZ40 (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)</i>	2020	2016-2021	\$ 9,288,248
		MC9	RDII Reduction Program FMZ02 & FMZ03	<i>Implement an Inflow and Infiltration Reduction Program within Bedford areas FMZ02 & FMZ03 (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)</i>	2031	2031-2036	\$ 8,023,065
	Local New Networks and Upgrades	MC10	Local network upgrades on Beaver Bank Rd. North of Glendale Dr.	<i>Upsize from 200mm to 450mm diameter gravity sewer along Beaver Bank Rd.</i>	2021	2021-2026	\$ 2,086,000
		MC11	Local network upgrades on Beaver Bank Rd. at Galloway Dr.	<i>Upsize from 300mm to 450mm diameter gravity sewer along Beaver Bank Rd.</i>	2021	2021-2026	\$ 1,490,000
		MC12	Local network upgrades on Beaver Bank Rd by Windgate Drive	<i>Upsize from 300mm to 375mm diameter gravity sewer along Beaver Bank Rd.</i>	2021	2021-2026	\$ 1,667,000
		MC13	Local network upgrades on Old Sackville Road south of Harvest Hwy	<i>Upsize from 200mm to 375mm diameter gravity sewer along Old Sackville Road</i>	2036	2036-2041	\$ 845,000
		MC14	Local network upgrades on Hallmark Ave.	<i>Upsize from 200mm to 375mm diameter gravity sewer on Hallmark Ave.</i>	2036	2036-2041	\$ 437,000
		MC15	Local Sewer Upgrades on Waterfront Drive	<i>375 mm Sewer Upgrade on Waterfront Drive</i>	2036	2036-2041	\$ 500,000
	Springfield Lake	MC16	Springfield Lake Connection to Sackville	<i>Decommission Springfield Lake WWTF, divert all flow to Mill Cove WWTF via new pumping station and gravity sewer to connect at top of Sackville trunk sewer.</i>	2043	2041-2046	\$ 6,226,000
	Flow Optimization	MC17	SSO Management Study	<i>Monitor and assess SSO facilities to mitigate discharges (18 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.</i>	2021	2021-2026	\$ 1,086,000
CENTRAL REGION Total Wastewater Servicing Strategy Cost						\$ 163,483,313	



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)	
East Region Eastern Passage	Gravity Pressure Sewer	EP1	Install new Gravity Pressure Sewer	<i>Install new 450 and 825mm Ø gravity pressure sewer</i>	2021	2021-2026	\$ 23,372,000
		EP2	Connect Beaver Crescent and Caldwell Force mains to new 450mm gravity pressure sewer	<i>Connect Beaver Crescent and Caldwell Force mains to new gravity pressure sewer</i>	2026	2026-2031	\$ 78,000
		EP3	Install new pump out stations	<i>Install 4 new pump out stations in the low point of the gravity pressure sewer</i>	2026	2026-2031	\$ 1,676,000
		EP4	Install gate valves at surge tank	<i>Optimize flows at the surge tank through gate valves</i>	2026	2026-2031	\$ 420,000
		EP5	Decommission existing 450mm gravity pressure sewer	<i>Grout fill the 450mm Ø asbestos gravity pressure sewer</i>	2043	2041-2046	\$ 559,000
	Upgrades to Pumping Stations	EP6	Upgrade Quigley Corner Pumping Station	<i>Increase pumping capacity at Quigley to 570l/s with an addition of 343l/s</i>	2021	2021-2026	\$ 2,875,000
		EP7	Optimize Quigley's Corner PS	<i>Force main optimization and SLR assessment</i>	2021	2021-2026	\$ 336,000
		EP8	Upgrade Memorial Drive Pumping Station	<i>Increase pumping capacity at Memorial Drive PS with an addition of 65l/s. Install new dual 300mm Ø force main</i>	2031	2031-2036	\$ 2,633,000
		EP9	Upgrade Beaver Crescent Pumping Station	<i>Increase pumping capacity at Beaver Crescent PS with an addition of 20l/s</i>	2036	2036-2041	\$ 168,000
		EP10	Upgrade Bissett Lake Pumping Station	<i>Increase pumping capacity at Bissett Lake PS with an addition of 350l/s</i>	2041	2036-2041	\$ 2,934,000
		EP11	Upgrade Caldwell Road Pumping Station	<i>Increase pumping capacity at Caldwell Road PS with an addition of 70l/s. Install new dual 200mm Ø force mains</i>	2039	2036-2041	\$ 631,000
Inflow and Infiltration	EP12	RDII Reduction Program FMZ23	<i>Implement an Inflow and Infiltration Reduction Program within the Cole Harbour areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining) - FMZ23</i>	2031	2031-2036	\$ 3,204,580	
	EP13	RDII Reduction Program FMZ24	<i>Implement an Inflow and Infiltration Reduction Program within the Loon Lake areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining) - FMZ24</i>	2020	2016-2021	\$ 1,570,040	
	EP14	RDII Reduction Program FMZ37	<i>Implement an Inflow and Infiltration Reduction Program within the Eastern Passage areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining) - FMZ37</i>	2020	2016-2021	\$ 2,479,704	
Local New Networks and Upgrades	EP15	Local network upgrades on Caldwell Road	<i>Upsize from 200 to 300mm Ø gravity sewer along Caldwell Road</i>	2036	2036-2041	\$ 607,000	
	EP16	Local network upgrades on Colby Drive	<i>Upsize from 200 to 300mm Ø gravity sewer along Colby Drive</i>	2031	2031-2036	\$ 1,176,000	
	EP17	Local network upgrades on Forest Hill Parkway	<i>Construct new 450mm Ø gravity sewer along Forest Hill Parkway connect to pipeline on Nestor Crescent</i>	2041	2041-2046	\$ 4,275,000	
Flow Optimization	EP18	SSO Management Study	<i>Monitor and assess SSO facilities to mitigate discharges (8 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.</i>	2021	2021-2026	\$ 484,000	
EASTERN PASSAGE Total Wastewater Servicing Strategy Cost						\$ 49,478,324	

Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)
East Region : Dartmouth	D1	LoWSCA: Canal Street Separation	Full separation of Canal Street LoWSCA pocket - 1 individual project. Install new stormwater pipelines, separate 35 properties and reconnect 8 catchbasins.	2020	2016-2021	\$ 1,842,000
	D2	LoWSCA: Wyse Road Separation	Full separation of Wyse Road LoWSCA pocket - 3 individual project, two phases. Phase 1 - Install new stormwater pipelines along Albro Lake Road and Windmill Road, separate 43 properties and reconnect 18 catchbasins (Area A). Phase 2 - Install new stormwater pipelines along Wyse Road, connecting to Albro Lake stormwater pipe, separate 111 properties and reconnect 4 catchbasins (Area B). Install new sewer diversion from Lyle St Catchment to Jamieson(Area C).	2020	2016-2021	\$ 3,860,000
	D3	Additional Stormwater Separation on Wyse Street	450mm Ø stormwater pipe connecting to Park Ave CSO, separate 6 properties and reconnect 1 catchbasin.	2031	2026-2031	\$ 1,912,000
	D5	Albro Lakes Watershed Separation	Full separation of Albro Lakes Watershed, install new stormwater trunk line, connecting to Jamieson Street CSO outfall.	2021	2021-2026	\$ 8,111,000
	D6	Maynard Lake and Clement Street Wetland Separation	Full separation of Maynard Lake and the Clement Street Wetland - 4 phases Phase 1 - Install 1050mm pipeline in Old Ferry Rd, connection to CSO outfall, connect stormwater pipeline from Hazlehurst Street and catchbasins en route Phase 2 - Install 750mm pipeline working upstream to the Wetland, continue to connect to catchbasin en route Phase 3 - Install 600mm pipeline connecting Maynard Lake to the pipeline Phase 4 - Connect to stormwater network for DSM and Fenwick Drive properties and separate North Woodside - Southdale Elementary and surrounding businesses	2031	2026-2031	\$ 642,000
				2031	2031-2036	\$ 4,540,000
				2033	2031-2036	\$ 1,155,000
				2036	2031-2036	\$ 453,000
	D7	New Valleyford Pumping Station	Install new pumping station by the Valleyford Holding Tank to a capacity of 300/l/s. Install new forcemain down Raymond Street and Maple Drive, to connect to the trunk sewer	2041	2036-2041	\$ 10,446,000
	D8	390 Waverley Road Upgrades	Install new dual 500mm Ø forcemain following existing path with a diversion to the North Dartmouth Trunk Sewer, by Highway 118	2021	2021-2026	\$ 11,361,000
	D9	Anderson Pumping Station Upgrades	Install new 300mm Ø forcemain following existing path. Alter flow path from holding tank to PS by adjusting pipe grades between infrastructure	2031	2031-2036	\$ 340,000
Dartmouth WWTF Upgrades	D10	Upgrades to Dartmouth WWTF	Upgrade Dartmouth WWTF to meet demand at end of Project Horizon	2043	2036-2041	\$ 12,572,000
Inflow and Infiltration	D11	RDII Reduction Program	Implement an Inflow and Infiltration Reduction Program within the Ellenvale areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)	2021	2021-2026	\$ 5,941,076
	D12	RDII Reduction Program	Implement an Inflow and Infiltration Reduction Program within the Woodside areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)	2031	2031-2036	\$ 1,120,232
	D13	Additional flow monitoring	Flow monitoring through the catchment to assess areas in model showing flooding	2020	2016-2021	\$ 252,000



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)
East Region : Dartmouth	D15	Green St Upsize	Common project - Upsize from 375 to 750mm ø gravity sewer along Green Street	2041	2041-2046	\$ 513,000
	D16	Pinecrest Dr Upgrade	Common project - Upsize from 200 to 375mm ø gravity sewer along Pinecrest Drive	2031	2031-2036	\$ 1,013,000
	D17	Peddars Way Upgrade	Common project - Upsize from 300 to 375mm ø gravity sewer along Peddars Way	2031	2031-2036	\$ 555,000
	D18	Atlantic Street Upgrade	Common project - Upsize from 250 to 450mm ø gravity sewer along Atlantic St	2021	2021-2026	\$ 3,831,000
	D19	Akerley Blvd and Railway Alignment Upgrade	Strategy project - Upsize from 250 to 600mm ø gravity sewer along Akerley Blvd and Railway easement towards Ferguson Road CSO	2041	2036-2041	\$ 4,814,000
	D20	Pleasant Street Upgrade	Strategy project - Upsize from 200 to 450mm ø gravity sewer along Pleasant St, and towards Cuisack Street CSO	2021	2021-2026	\$ 767,000
	D21	Princess Margaret Blvd. Upgrade	Strategy project - Upsize from 450 to 600mm ø gravity sewer along Princess Margaret Blvd.	2031	2031-2036	\$ 3,106,000
	D22	Anderson Lake Development Connection	Strategy project - Construct new 450mm ø gravity sewer to connect Anderson Lake development to Akerley Blvd	2036	2036-2041	\$ 7,609,000
	D23	Marvin Connection	Strategy project - Construct new 450mm ø gravity sewer in Marvin Street and connect to connect Cuisack Street CSO	2026	2026-2031	\$ 1,380,000
	D24	King Street Diversion	Common Project - 450mm ø sewer diversion to NDTs	2026	2026-2031	\$ 78,000
Flow Diversion	D25	Diversion to Eastern Passage	Install new pumping station at Melva St CSO. Install new dual 600mm ø forcemain following Pleasant Street and connecting to existing gravity pipe in Eastern Passage network. Upgrade existing gravity pipe from a 200 to 600mm ø.	2036	2036-2041	\$ 12,113,000
	D14	CSO Flow Management Study	Monitor and assess CSO facilities to mitigate discharges (11 facilities). Costed at \$14,000/monitor and \$15,000/CSO for assessment.	2036	2036-2041	\$ 675,000
Flow Optimization	D26	SSO Flow Management Study	Monitor and assess SSO facilities to mitigate discharges (9 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.	2021	2016-2021	\$ 555,000
	DARTMOUTH Total Wastewater Servicing Strategy Cost					\$ 104,358,308
EAST REGION Total Wastewater Servicing Strategy Cost					\$ 153,836,631	
ALL REGIONS Total Wastewater Servicing Strategy Cost					\$ 563,082,533	



Executive Summary Table 4: Water Capital Program Summary

Project Category	Project Name	Project ID	Project Task	Start Year	Planning Period	Total Capital Cost (2019\$)
Pockwock - Peninsula	Peninsula Transmission Upgrades (Chain Control)	W06.1	Chain Control Transmission - Existing Peninsula Low Upsize	2021	2021-2026	\$ 3,841,000
		W06.2	Chain Control Transmission - Existing Peninsula Intermediate Upsize	2021	2021-2026	\$ 2,650,000
		W06.3	Pepperell Transmission	2036	2036-2041	\$ 2,702,000
		W06.4	Chain Control Transmission - Existing Peninsula Low Lining	2036	2036-2041	\$ 2,916,000
		W06.5	Chain Control Transmission - Valve Chambers	2036	2036-2041	\$ 1,258,000
	Twinning of Peninsula Transmission (Robie)	W07	Replace High Risk Peninsula Transmission (Robie)	2026	2026-2031	\$ 17,312,000
	Quinpool to Young Connection	W08	Peninsula Intermediate Looping - Quinpool Rd to Young St	2021	2021-2026	\$ 4,319,000
	Young Street Pocket Upgrades	W10.1	Young St Upsize	2026	2026-2031	\$ 1,315,000
		W10.2	Robie St Upsize	2026	2026-2031	\$ 956,000
		W10.3	Almon St Upsize	2026	2026-2031	\$ 1,168,000
		W10.4	Windsor St Upsize	2026	2026-2031	\$ 1,004,000
Pockwock - Other	Lakeside Projects	W01.1	Geizer 158 to Lakeside High Looping	2021	2021-2026	\$ 2,249,000
		W01.2	Gravity Supply to Brunello	2041	2041-2046	\$ 2,328,000
		W01.3	Dominion Cres Upsize	2041	2041-2046	\$ 447,000
		W01.4	Brunello Booster Pump Upgrades	2021	2021-2026	\$ 236,000
	Lively, Geizer Hill, and Leiblin Booster Pump Upgrades	W03	Geizer Hill Booster Pump Upgrades	2021	2021-2026	\$ 277,000
		W04	Leiblin Booster Fire Pump	2019	2016-2021	\$ 395,000
		W15	Lively Booster Pump Upgrades	2036	2036-2041	\$ 38,000
	Herring Cover Upgrades	W05.1	Herring Cove Rd Twinning	2020	2016-2021	\$ 3,585,000
		W05.2	St Michaels Ave Upsize	2041	2041-2046	\$ 502,000
		W05.3	Herring Cove Rd Looping - McIntosh St	2021	2021-2026	\$ 2,272,000
	Lucasville Road Twinning	W12.1	Lucasville Rd Twinning (Phase 1)	2019	2016-2021	\$ 8,117,000
		W12.2	Lucasville Rd Twinning (Phase 2)	2026	2026-2031	\$ 8,956,000
	New Primary Sackville High and Beaver Bank Supply	W13.1	New Primary Feed to Sackville High	2026	2026-2031	\$ 4,953,000
		W13.2	New Sackville Beaver Bank Valve Chamber	2026	2026-2031	\$ 839,000
		W13.3	Reconfiguration of Beaver Bank Booster	2026	2026-2031	\$ 100,000
		W13.4	New Sackville High PRV	2026	2026-2031	\$ 420,000
	Second Supply to Windsor Junction	W14.1	Cobequid High Looping	2026	2026-2031	\$ 2,233,000
		W14.2	Windgate Dr Upsize	2026	2026-2031	\$ 882,000
	New Hemlock Tank	W16	New Hemlock Elevated Tank	2020	2016-2021	\$ 6,209,000
	Pockwock Transmission Looping	W17	Pockwock Transmission Loop through Bedford	2021	2021-2026	\$ 5,069,000
	Second Geizer 158 Feed and Lacewood Drive Loop	W02	Geizer 158 Looping - Lacewood Dr	2041	2041-2046	\$ 2,002,000
		W20	Second Geizer 158 Feed	2041	2041-2046	\$ 9,612,000



Executive Summary Table 4: Water Capital Program Summary (continued)

Project Category	Project Name	Project ID	Project Task	Start Year	Planning Period	Total Capital Cost (2019\$)
Lake Major	New Transmission from Topsail to Burnside	W22.1	New Main Street to Caledonia Road Connection	2021	2021-2026	\$ 3,072,000
		W22.2	Caledonia Rd Twinning	2021	2021-2026	\$ 3,429,000
		W22.3	New Breeze Dr Watermain	2021	2021-2026	\$ 5,801,000
		W28	Tacoma PRV Chamber	2021	2021-2026	\$ 420,000
	Highway 118 Crossing	W23	Highway 118 Crossing - Shubie Park to Dartmouth Crossing	2021	2021-2026	\$ 6,063,000
	Windmill Road Upgrade	W24	Windmill Rd Upsize	2026	2026-2031	\$ 6,104,000
	New Woodside Industrial Park Feed	W25	New Woodside Industrial Park Feed	2021	2021-2026	\$ 1,649,000
	Willowdale-Eastern Passage Connection	W26	Willowdale to Eastern Passage Connection	2036	2036-2041	\$ 6,290,000
System Interconnections Pockwock Transmission WTP Decommissioning	Pockwock Transmission Twinning	W19.1	Pockwock Transmission Twinning - 60in	2031	2031-2036	\$ 65,516,000
		W19.2	Pockwock Transmission Twinning - 54in	2036	2036-2041	\$ 16,228,000
	Extension to Springfield Lake	W21	Extension to Springfield Lake	2041	2041-2046	\$ 3,043,000
	Bedford-Burnside Interconnection	W29.1	Bedford-Burnside System Interconnection (Phase 1)	2036	2036-2041	\$ 24,499,000
		W29.2	Bedford-Burnside System Interconnection (Phase 2)	2036	2036-2041	\$ 11,779,000
	Dartmouth-Peninsula Interconnection	W30.1	Lyle Emergency Booster	2026	2026-2031	\$ 1,045,000
		W30.2	Valving for Central Intermediate Boundary Change	2026	2026-2031	\$ 629,000
	Pockwock-Bennery Interconnection	W31.1	Extension of Fall River to Bennery Lake (Phase 1)	2026	2026-2031	\$ 8,067,000
		W31.2	Extension of Fall River to Bennery Lake (Phase 2)	2026	2026-2031	\$ 9,156,000
		W31.3	Extension of Fall River to Bennery Lake (PS)	2026	2026-2031	\$ 1,310,000
	WSP Decommissioning	W32.1	Decommission Miller Lake WSP - Linear	2019	2016-2021	\$ 628,000
		W32.2	Decommission Miller Lake WSP	2019	2016-2021	\$ 61,000
		W33.1	Decommission Collins Park WSP - Linear	2041	2041-2046	\$ 1,086,000
		W33.2	Decommission Collins Park WSP	2041	2041-2046	\$ 168,000
		W34.1	Decommission Silversands WSP - Linear	2041	2041-2046	\$ 1,931,000
		W34.2	Decommission Silversands WSP	2041	2041-2046	\$ 168,000
Studies	Studies	W40	Aerotech Storage	2021	2021-2026	\$ 4,752,000
		W18	Chain Lake Backup Supply Study	2020	2016-2021	\$ 50,000
		W27	Mt Edward Booster Fire Pump	2019	2016-2021	\$ 50,000
		W29.3	New Orchard Control Chamber	2021	2021-2026	\$ 50,000
		W30.3	Robie Emergency Booster	2021	2021-2026	\$ 50,000
		W35	Safe Yield Study	2020	2016-2021	\$ 100,000
		W36	New Hydraulic Water Model (InfoWater)	2020	2016-2021	\$ 200,000
		W37	Comprehensive PRV Study	2019	2016-2021	\$ 50,000
		W38	Transmission Main Risk Assessment and Prioritization Framework	2020	2016-2021	\$ 50,000
		W39	Tomahawk Lake Supply Study	2036	2036-2041	\$ 50,000
Total Water Servicing Strategy Cost						\$ 284,706,000



Appendix B – Compliance Plan Program

Compliance Plan Program

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
Halifax Wastewater Treatment Facility	Preliminary Treatment	Improved screening capture rates by replacing three (3) existing bar screens with newer technology	2019	2021	2016-2021	\$1,950,000	\$1,950,000	\$1,950,000
	Coagulant Dosing System	Replace existing Alum dosing pumps with PD pumps to match plant flows, includes pumps, valves and appurtenances	2019	2020	2016-2021	\$135,000	\$135,000	\$135,000
	Polymer Dosing System	Replace existing polymer dosing pumps with PD pumps to match plant flows, includes pumps, valves and appurtenances (4 duty, 1 standby)	2019	2020	2016-2021	\$39,500	\$39,500	\$39,500
	Hydraulic Balancing Improvements	CFD Analysis, flow division baffles, and implementation of flow monitoring devices to improve hydraulic flow distribution and loading to the Densadeg reactors	2019	2019	2016-2021	\$395,000	\$608,300	\$539,784
	Disinfection Upgrades	Add 9 additional UV models to per bank (8 banks, 72 total models), power distribution center and system control center (PLC)	2019	2022	2022-2027	\$850,000	\$1,309,000	\$1,161,560
	UV System Level Controls	Replace four (4) existing hydraulic level control weir gate with motorized weir gates with electrical actuators to ensure lamps remain submerged under all flow conditions	2019	2022	2022-2027	\$385,000	\$592,900	\$526,118
	Solids Handling	Improve dewatering to increase capacity	2019	2021	2016-2021	\$935,000	\$1,439,900	\$1,277,715
	Odour Control - Activated Carbon Reactors	Replacement of activated carbon canisters on dry scrubber	2019	2020	2016-2021	\$275,000	\$275,000	\$275,000
	Ballasted Flocculation Upgrades	Retrofit existing Densadeg system with ballasted floc treatment technology for optimal TSS and BOD removal efficiencies, replace tube setters	2029	2029	2026-2031	\$4,070,000	\$5,453,800	\$3,825,924
	Upgrades to meet WSER			2040		\$160,750,000		
Total Halifax WWTF Compliance Cost						\$169,784,500		\$9,730,601

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
Dartmouth Wastewater Treatment Facility	Preliminary Treatment	Improved screening capture rates by replacing three (3) existing bar screens with newer technology	2019	2020	2016-2021	\$1,785,000	\$1,785,000	\$1,785,000
	Coagulant Dosing System	Replace existing Alum dosing pumps with PD pumps to match plant flows, includes pumps, valves and appurtenances	2019	2020	2016-2021	\$120,000	\$120,000	\$120,000
	Polymer Dosing System	Replace existing polymer dosing pumps with PD pumps to match plant flows, includes pumps, valves and appurtenances (4 duty, 1 standby)	2019	2020	2016-2021	\$25,000	\$25,000	\$25,000
	Hydraulic Balancing Improvements	CFD Analysis, flow division baffles, and implementation of flow monitoring devices to improve hydraulic flow distribution and loading to the Densadeg reactors	2019	2020	2016-2021	\$335,000	\$502,500	\$457,791
	Disinfection Upgrades	Add 8 additional UV models to per bank (8 banks, 64 total models), power distribution center and system control center (PLC)	2019	2021	2016-2021	\$775,000	\$1,162,500	\$1,059,069
	UV System Level Controls	Replace four (4) existing hydraulic level control weir gate with motorized weir gates with electrical actuators to ensure lamps remain submerged under all flow conditions	2019	2021	2016-2021	\$325,000	\$487,500	\$444,126
	Solids Handling	Improve dewatering to increase capacity	2023	2022	2021-2026	\$735,000	\$1,102,500	\$867,804
	Ballasted Flocculation Upgrades	Retrofit existing Densadeg system with ballasted floc treatment technology for optimal TSS and BOD removal efficiencies, replace tube setters	2029	2029	2026-2031	\$3,800,000	\$5,700,000	\$3,572,116
	Upgrades to meet WSER			2038		\$87,400,000		
	Total Dartmouth WWTF Compliance Cost						\$95,300,000	\$8,330,906

Compliance Plan Program

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
Herring Cove Wastewater Treatment Facility	Preliminary Treatment	Improved screening capture rates by replacing three (3) existing bar screens with newer technology	2019	2022	2021-2026	\$1,020,000	\$1,020,000	\$1,059,035
	UV System Level Controls	Replace four (4) existing hydraulic level control weir gate with motorized weir gates with electrical actuators to ensure lamps remain submerged under all flow conditions	2019	2022	2021-2026	\$300,000	\$462,000	\$409,962
	Odour Control - Activated Carbon Reactors	Replacement of 144 activated carbon canisters on dry scrubber	2019	2020	2016-2021	\$165,000	\$165,000	\$225,479
	Ballasted Flocculation Upgrades	Retrofit existing Densadeg system with ballasted floc treatment technology for optimal TSS and BOD removal efficiencies, replace tube settlers	2023	2023	2021-2026	\$3,265,000	\$4,766,900	\$3,854,939
	Upgrades to meet WSER			2039		\$38,200,000		
Total Herring Cove WWTF Compliance Cost						\$42,950,000		\$5,549,415

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
Lakeside-Timberlea Wastewater Treatment Facility	Improve Plant Hydraulics	Flow splitter box to allow for equal flow distribution and increased alum dosing for TP reduction	2019	2020	2016-2021	\$25,000	\$38,500	\$34,164
Total Lakeside-Timberlea WWTF Compliance Cost						\$25,000		\$34,164

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
Mill Cove Wastewater Treatment Facility	Mill Cove Wastewater Treatment Plant Capacity Upgrade	WWTF Upgrade	2019	2020	2016-2021	\$70,000,000	\$107,800,000	\$95,657,844
Total Mill Cove WWTF Compliance Cost						\$70,000,000		\$95,657,844

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
Corporate Programs	Wet Weather Management Program	Wet weather Management program - Annual cost of \$250,000	NA	2020	2020-2048	\$7,250,000		
	I&I Reduction Program	Capital Costs related to the purchase of equipment (flow monitors, etc.) for the private side I&I Reduction Program		2019	2019-2048	\$750,000		
	Corporate Flow Monitoring Program	Annual cost for program		2019	2019-2048	\$51,060,000		
	Bio-Solids Facility Upgrades	Bio-Solids Facility Upgrades		2023		\$10,000,000		
Total Corporate Programs Compliance Cost						\$69,060,000		\$0

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
	Armdale CSO Screening		2025	2025	2021-2026	\$3,000,000		
	Quinpool Road CSO Screening		2025	2025	2021-2026	\$3,000,000		
	Coburg Road CSO Screening		2025	2025	2021-2026	\$3,000,000		
	South Street CSO Screening		2025	2025	2021-2026	\$3,000,000		
	Beaufort CSO Screening		2025	2025	2021-2026	\$3,000,000		
	Future Overflow Program			2042		\$198,889,474		
Total Collection System Compliance Cost						\$213,889,474		

Water

Project Category	Project Name	Project Description	NPV Costing Year	Start Year	Planning Period	Total Capital Cost (2019\$)	Total Life Cycle Cost	Life Cycle Cost (NPV) - 2019
General	Watershed Land Acquisition	Annual program of \$100K per year		2020	2019-2048	\$3,000,000		
	Automated Flushing Program	Annual program \$20K per year		2020	2020-2048	\$580,000		
JD Kline	JD Kline WSP – Phase 1			2025		\$32,660,000		
	JD Kline WSP – Phase 2			2025		\$25,440,000		
	Lake Major WSP – Phase 1					\$31,163,000		
	Lake Major WSP – Phase 2					\$16,960,000		
Total Water System Compliance Cost						\$109,803,000		

Appendix C – Asset Management Plan Program

Halifax Water 2018/2019 AMPs
A1 Water Supply Plants

Year	Planned Expenditure	
2019	\$7,211	\$7.21
2020	\$7,554	\$7.55
2021	\$15,682	\$15.68
2022	\$59,033	\$59.03
2023	\$38,625	\$38.63
2024	\$6,483	\$6.48
2025	\$6,483	\$6.48
2026	\$6,483	\$6.48
2027	\$6,483	\$6.48
2028	\$6,483	\$6.48
2029	\$11,483	\$11.48
2030	\$11,483	\$11.48
2031	\$6,483	\$6.48
2032	\$6,483	\$6.48
2033	\$6,483	\$6.48
2034	\$6,483	\$6.48
2035	\$6,483	\$6.48
2036	\$6,483	\$6.48
2037	\$6,483	\$6.48
2038	\$8,483	\$8.48
2039	\$8,483	\$8.48
2040	\$8,483	\$8.48
2041	\$8,483	\$8.48
2042	\$8,483	\$8.48
2043	\$6,483	\$6.48
2044	\$6,483	\$6.48
2045	\$6,483	\$6.48
2046	\$6,483	\$6.48
2047	\$6,483	\$6.48
2048	\$6,483	\$6.48
Total	\$310,180	\$310
30-Year Average		\$10.3

A2 Water Supply Dams

Year	Planned Expenditure	
2019	\$420,000	\$0.42
2020	\$725,000	\$0.73
2021	\$0	\$0.00
2022	\$0	\$0.00
2023	\$0	\$0.00
2024	\$3,000,000	\$3.00
2025	\$0	\$0.00
2026	\$300,000	\$0.30
2027	\$1,000,000	\$1.00
2028	\$0	\$0.00
2029	\$0	\$0.00
2030	\$0	\$0.00
2031	\$0	\$0.00
2032	\$0	\$0.00
2033	\$300,000	\$0.30
2034	\$1,000,000	\$1.00
2035	\$0	\$0.00
2036	\$0	\$0.00
2037	\$0	\$0.00
2038	\$0	\$0.00
2039	\$0	\$0.00
2040	\$300,000	\$0.30
2041	\$0	\$0.00
2042	\$1,000,000	\$1.00
2043	\$0	\$0.00
2044	\$0	\$0.00
2045	\$0	\$0.00
2046	\$0	\$0.00
2047	\$300,000	\$0.30
2048	\$0	\$0.00
Total	\$8,345,000	\$8
30-Year	\$278,166.7	\$0.3

Halifax Water 2018/2019 AMPs
A3 Water Chambers and Booster Stations

Year	Planned Expenditure	
2019	\$971,526	\$0.97
2020	\$680,000	\$0.68
2021	\$1,056,006	\$1.06
2022	\$1,816,330	\$1.82
2023	\$680,000	\$0.68
2024	\$1,056,006	\$1.06
2025	\$680,000	\$0.68
2026	\$680,000	\$0.68
2027	\$2,808,976	\$2.81
2028	\$1,562,889	\$1.56
2029	\$680,000	\$0.68
2030	\$680,000	\$0.68
2031	\$680,000	\$0.68
2032	\$680,000	\$0.68
2033	\$680,000	\$0.68
2034	\$680,000	\$0.68
2035	\$680,000	\$0.68
2036	\$680,000	\$0.68
2037	\$1,900,811	\$1.90
2038	\$680,000	\$0.68
2039	\$1,056,006	\$1.06
2040	\$680,000	\$0.68
2041	\$680,000	\$0.68
2042	\$680,000	\$0.68
2043	\$680,000	\$0.68
2044	\$680,000	\$0.68
2045	\$680,000	\$0.68
2046	\$1,763,530	\$1.76
2047	\$680,000	\$0.68
2048	\$680,000	\$0.68
Total	\$28,272,080	\$28
30-Year Average	\$942,402.7	\$0.9

A4 Water Transmission Mains

Year	Planned Expenditure	
2019	\$3,158,412	\$3.16
2020	\$2,195,809	\$2.20
2021	\$3,700,733	\$3.70
2022	\$578,572	\$0.58
2023	\$1,233,573	\$1.23
2024	\$888,995	\$0.89
2025	\$2,914,110	\$2.91
2026	\$1,438,971	\$1.44
2027	\$14,499,962	\$14.50
2028	\$2,818,305	\$2.82
2029	\$6,390,313	\$6.39
2030	\$17,452,387	\$17.45
2031	\$8,989,294	\$8.99
2032	\$41,620,036	\$41.62
2033	\$9,093,502	\$9.09
2034	\$3,724,250	\$3.72
2035	\$45,778,540	\$45.78
2036	\$5,035,175	\$5.04
2037	\$19,536,934	\$19.54
2038	\$1,595,668	\$1.60
2039	\$5,803,733	\$5.80
2040	\$16,656,700	\$16.66
2041	\$6,867,538	\$6.87
2042	\$7,859,107	\$7.86
2043	\$7,196,873	\$7.20
2044	\$7,439,048	\$7.44
2045	\$7,657,123	\$7.66
2046	\$10,748,340	\$10.75
2047	\$4,911,723	\$4.91
2048	\$4,617,192	\$4.62
Total	\$272,400,917	\$272
30-Year Average	\$9,080,030.6	\$9.1

Halifax Water 2018/2019 AMPs
A5 Water Distribution Mains

Year	Planned Expenditure	
2019	\$9,339,533	\$9.34
2020	\$2,263,652	\$2.26
2021	\$8,950,247	\$8.95
2022	\$7,165,140	\$7.17
2023	\$6,279,950	\$6.28
2024	\$2,319,408	\$2.32
2025	\$2,077,175	\$2.08
2026	\$8,007,113	\$8.01
2027	\$6,931,906	\$6.93
2028	\$6,637,547	\$6.64
2029	\$9,615,798	\$9.62
2030	\$7,657,841	\$7.66
2031	\$5,955,757	\$5.96
2032	\$4,938,520	\$4.94
2033	\$7,585,205	\$7.59
2034	\$8,720,320	\$8.72
2035	\$8,122,103	\$8.12
2036	\$17,236,887	\$17.24
2037	\$9,774,710	\$9.77
2038	\$15,538,535	\$15.54
2039	\$13,167,851	\$13.17
2040	\$14,636,149	\$14.64
2041	\$11,121,269	\$11.12
2042	\$10,280,888	\$10.28
2043	\$13,675,211	\$13.68
2044	\$17,135,886	\$17.14
2045	\$18,061,416	\$18.06
2046	\$30,307,174	\$30.31
2047	\$15,612,285	\$15.61
2048	\$8,475,887	\$8.48
Total	\$307,591,367	\$308
30-Year Average	\$10,253,045.6	\$10.3

A6 Water Reservoirs

Year	Planned Expenditure	
2019	\$0	\$0.00
2020	\$0	\$0.00
2021	\$2,703,375	\$2.70
2022	\$7,146,015	\$7.15
2023	\$2,112,012	\$2.11
2024	\$2,615,566	\$2.62
2025	\$1,879,478	\$1.88
2026	\$1,584,009	\$1.58
2027	\$0	\$0.00
2028	\$1,584,009	\$1.58
2029	\$0	\$0.00
2030	\$2,061,032	\$2.06
2031	\$1,015,555	\$1.02
2032	\$0	\$0.00
2033	\$1,814,874	\$1.81
2034	\$0	\$0.00
2035	\$1,584,009	\$1.58
2036	\$0	\$0.00
2037	\$0	\$0.00
2038	\$0	\$0.00
2039	\$1,421,503	\$1.42
2040	\$0	\$0.00
2041	\$2,112,012	\$2.11
2042	\$0	\$0.00
2043	\$0	\$0.00
2044	\$0	\$0.00
2045	\$0	\$0.00
2046	\$2,615,566	\$2.62
2047	\$0	\$0.00
2048	\$0	\$0.00
Total	\$32,249,015	\$32
30-Year Average	\$1,074,967.2	\$1.1

Halifax Water 2018/2019 AMPs
B1 Wastewater Treatment Facilities

Year	Planned Expenditure	
2019	\$3,245,000	\$3.25
2020	\$5,300,000	\$5.30
2021	\$5,125,000	\$5.13
2022	\$3,730,000	\$3.73
2023	\$3,415,000	\$3.42
2024	\$7,252,981	\$7.25
2025	\$3,828,889	\$3.83
2026	\$4,768,599	\$4.77
2027	\$6,260,084	\$6.26
2028	\$5,352,447	\$5.35
2029	\$25,458,640	\$25.46
2030	\$23,887,870	\$23.89
2031	\$42,461,251	\$42.46
2032	\$21,252,760	\$21.25
2033	\$24,073,154	\$24.07
2034	\$13,619,813	\$13.62
2035	\$10,214,913	\$10.21
2036	\$33,209,862	\$33.21
2037	\$14,776,389	\$14.78
2038	\$29,710,471	\$29.71
2039	\$1,430,073	\$1.43
2040	\$6,815,963	\$6.82
2041	\$11,755,859	\$11.76
2042	\$23,658,867	\$23.66
2043	\$6,851,578	\$6.85
2044	\$5,806,788	\$5.81
2045	\$13,202,394	\$13.20
2046	\$13,202,394	\$13.20
2047	\$13,202,394	\$13.20
2048	\$13,202,394	\$13.20
Total	\$396,071,828	\$396
30-Year Average	\$13,202,394.3	\$13.2

B2 Wastewater Pumping Stations

Year	Planned Expenditure	
2019	\$1,475,000	\$1.48
2020	\$7,230,000	\$7.23
2021	\$9,550,000	\$9.55
2022	\$12,390,000	\$12.39
2023	\$10,150,000	\$10.15
2024	\$27,588,744	\$27.59
2025	\$3,387,113	\$3.39
2026	\$4,644,683	\$4.64
2027	\$1,663,669	\$1.66
2028	\$20,209,244	\$20.21
2029	\$7,711,131	\$7.71
2030	\$35,941,502	\$35.94
2031	\$11,645,360	\$11.65
2032	\$33,865,684	\$33.87
2033	\$16,138,756	\$16.14
2034	\$5,573,572	\$5.57
2035	\$4,409,507	\$4.41
2036	\$8,933,333	\$8.93
2037	\$4,918,501	\$4.92
2038	\$3,784,214	\$3.78
2039	\$15,680,210	\$15.68
2040	\$53,059,590	\$53.06
2041	\$9,734,411	\$9.73
2042	\$6,377,050	\$6.38
2043	\$3,252,683	\$3.25
2044	\$1,938,986	\$1.94
2045	\$4,582,932	\$4.58
2046	\$9,513,268	\$9.51
2047	\$11,970,205	\$11.97
2048	\$596,216	\$0.60
Total	\$347,915,562	\$348
30-Year Average	\$11,597,185.4	\$11.6

Halifax Water 2018/2019 AMPs
B3 Wastewater Gravity Sewers

Year	Planned Expenditure	
2019	\$4,073,232	\$4.07
2020	\$4,073,232	\$4.07
2021	\$4,073,232	\$4.07
2022	\$4,073,232	\$4.07
2023	\$4,073,232	\$4.07
2024	\$4,073,232	\$4.07
2025	\$4,073,232	\$4.07
2026	\$4,073,232	\$4.07
2027	\$4,073,232	\$4.07
2028	\$4,073,232	\$4.07
2029	\$8,309,589	\$8.31
2030	\$8,309,589	\$8.31
2031	\$8,309,589	\$8.31
2032	\$8,309,589	\$8.31
2033	\$8,309,589	\$8.31
2034	\$8,309,589	\$8.31
2035	\$8,309,589	\$8.31
2036	\$8,309,589	\$8.31
2037	\$8,309,589	\$8.31
2038	\$8,309,589	\$8.31
2039	\$4,203,226	\$4.20
2040	\$4,203,226	\$4.20
2041	\$4,203,226	\$4.20
2042	\$4,203,226	\$4.20
2043	\$4,203,226	\$4.20
2044	\$4,203,226	\$4.20
2045	\$4,203,226	\$4.20
2046	\$4,203,226	\$4.20
2047	\$4,203,226	\$4.20
2048	\$4,203,226	\$4.20
Total	\$165,860,471	\$166
30-Year Average	\$5,528,682.4	\$5.5

B4 Wastewater Force mains

Year	Planned Expenditure	
2019	\$4,580,806	\$4.58
2020	\$2,120,072	\$2.12
2021	\$0	\$0.00
2022	\$0	\$0.00
2023	\$2,654,954	\$2.65
2024	\$480,588	\$0.48
2025	\$1,019,438	\$1.02
2026	\$2,120,072	\$2.12
2027	\$0	\$0.00
2028	\$0	\$0.00
2029	\$2,389,950	\$2.39
2030	\$650,182	\$0.65
2031	\$147,729	\$0.15
2032	\$2,626,163	\$2.63
2033	\$705,967	\$0.71
2034	\$8,682,673	\$8.68
2035	\$581,010	\$0.58
2036	\$0	\$0.00
2037	\$4,771,410	\$4.77
2038	\$174,320	\$0.17
2039	\$0	\$0.00
2040	\$0	\$0.00
2041	\$1,693,929	\$1.69
2042	\$180,201	\$0.18
2043	\$814,014	\$0.81
2044	\$4,757,793	\$4.76
2045	\$1,956,197	\$1.96
2046	\$1,768,911	\$1.77
2047	\$72,249	\$0.07
2048	\$3,190,451	\$3.19
Total	\$48,139,079	\$48
30-Year Average	\$1,604,636.0	\$1.6

Halifax Water 2018/2019 AMPs
C1 Stormwater Management Structures

Year	Planned Expenditure	
2019	\$4,350,137	\$4.35
2020	\$2,615,289	\$2.62
2021	\$0	\$0.00
2022	\$2,000,000	\$2.00
2023	\$1,090,289	\$1.09
2024	\$0	\$0.00
2025	\$0	\$0.00
2026	\$0	\$0.00
2027	\$0	\$0.00
2028	\$0	\$0.00
2029	\$0	\$0.00
2030	\$0	\$0.00
2031	\$0	\$0.00
2032	\$0	\$0.00
2033	\$66,528	\$0.07
2034	\$0	\$0.00
2035	\$0	\$0.00
2036	\$0	\$0.00
2037	\$0	\$0.00
2038	\$0	\$0.00
2039	\$0	\$0.00
2040	\$0	\$0.00
2041	\$0	\$0.00
2042	\$0	\$0.00
2043	\$0	\$0.00
2044	\$0	\$0.00
2045	\$0	\$0.00
2046	\$0	\$0.00
2047	\$0	\$0.00
2048	\$416,160	\$0.42
Total	\$10,538,402	\$11
30-Year Average	\$351,280.1	\$0.4

C2 Stormwater Gravity Sewers

Year	Planned Expenditure	
2019	\$1,351,339	\$1.35
2020	\$1,158,911	\$1.16
2021	\$1,152,335	\$1.15
2022	\$1,596,322	\$1.60
2023	\$1,423,623	\$1.42
2024	\$1,152,335	\$1.15
2025	\$1,152,335	\$1.15
2026	\$1,152,335	\$1.15
2027	\$1,152,335	\$1.15
2028	\$1,152,335	\$1.15
2029	\$8,188,156	\$8.19
2030	\$8,135,100	\$8.14
2031	\$7,957,884	\$7.96
2032	\$8,736,299	\$8.74
2033	\$7,957,884	\$7.96
2034	\$8,031,699	\$8.03
2035	\$8,594,173	\$8.59
2036	\$9,226,997	\$9.23
2037	\$12,912,742	\$12.91
2038	\$8,388,758	\$8.39
2039	\$3,717,607	\$3.72
2040	\$7,916,953	\$7.92
2041	\$9,694,251	\$9.69
2042	\$6,732,501	\$6.73
2043	\$7,838,269	\$7.84
2044	\$15,460,984	\$15.46
2045	\$2,545,595	\$2.55
2046	\$2,545,595	\$2.55
2047	\$2,545,595	\$2.55
2048	\$2,545,595	\$2.55
Total	\$162,116,838	\$162
30-Year Average	\$5,403,894.6	\$5.4

Halifax Water 2018/2019 AMPs
C3 Stormwater Cross Culverts

Year	Planned Expenditure	
2019	\$1,000,000	\$1.00
2020	\$1,800,000	\$1.80
2021	\$2,100,000	\$2.10
2022	\$2,100,000	\$2.10
2023	\$2,100,000	\$2.10
2024	\$0	\$0.00
2025	\$0	\$0.00
2026	\$0	\$0.00
2027	\$2,600,000	\$2.60
2028	\$4,100,000	\$4.10
2029	\$100,000	\$0.10
2030	\$100,000	\$0.10
2031	\$300,000	\$0.30
2032	\$0	\$0.00
2033	\$0	\$0.00
2034	\$100,000	\$0.10
2035	\$5,000,000	\$5.00
2036	\$9,500,000	\$9.50
2037	\$0	\$0.00
2038	\$9,200,000	\$9.20
2039	\$2,000,000	\$2.00
2040	\$0	\$0.00
2041	\$1,900,000	\$1.90
2042	\$0	\$0.00
2043	\$4,300,000	\$4.30
2044	\$0	\$0.00
2045	\$9,200,000	\$9.20
2046	\$0	\$0.00
2047	\$7,800,000	\$7.80
2048	\$0	\$0.00
Total	\$65,300,000	\$65
30-Year Average	\$2,176,666.7	\$2.2

C3 Driveway Culverts

Year	Planned Expenditure	
2019	\$850,000	\$0.85
2020	\$850,000	\$0.85
2021	\$850,000	\$0.85
2022	\$850,000	\$0.85
2023	\$850,000	\$0.85
2024	\$850,000	\$0.85
2025	\$850,000	\$0.85
2026	\$850,000	\$0.85
2027	\$850,000	\$0.85
2028	\$850,000	\$0.85
2029	\$850,000	\$0.85
2030	\$850,000	\$0.85
2031	\$850,000	\$0.85
2032	\$850,000	\$0.85
2033	\$850,000	\$0.85
2034	\$850,000	\$0.85
2035	\$850,000	\$0.85
2036	\$850,000	\$0.85
2037	\$850,000	\$0.85
2038	\$850,000	\$0.85
2039	\$850,000	\$0.85
2040	\$850,000	\$0.85
2041	\$850,000	\$0.85
2042	\$850,000	\$0.85
2043	\$850,000	\$0.85
2044	\$850,000	\$0.85
2045	\$850,000	\$0.85
2046	\$850,000	\$0.85
2047	\$850,000	\$0.85
2048	\$850,000	\$0.85
Total	\$25,500,000	\$26
30-Year Average	\$850,000.0	\$0.9



Appendix D – AMPs Expenditure Needs Analysis

Appendix D - AMPs Expenditure Needs Analysis


Asset Level 1 (Asset Group)	Asset Level 2 (Asset Class)	Asset Level 3 (Facility or Object)	Asset Level 4 (Process Area)	Asset Level 5 (Component)	SOCR Need (Annual Expenditure \$M)	Time Period for SOGR Need (Referenced in Column F)	AMP Includes	Granularity	Year Orientated?	GIS Compatible?	AMP Replacement Cost Source	Condition Source
Water	Supply Plant	- 11 Facilities			\$ 11.20	Over 30 years	- Design capacity and replacement cost - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan (summary) - 5-year History of OPEX	Condition and replacement values are to the facility level, capital plan is sometimes to the process area level	Yes	GIS compatible, there is a facilities location map according to the facility name	Staff opinion based off of \$2015 replacement cost and insurance valuation	Staff knowledge
Water	Supply Dam	- 6 Facilities	- Dam, spillway, etc.		\$ 0.19	Over 30 years	- Design capacity and replacement cost - 30-year CAPEX plan - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Condition and replacement values are to the facility level	Yes	There is facility location name however, there is not GIS ID/information	Taken from 2016 AMP (which were taken from 2013 report provided by MECO)	Condition assessment are judgement from Engineering and AM team, using information in the 2012 Dam Safety Review
Water	Booster Station	- 20 Facilities			\$ 0.18	Over 30 years	- 100-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - 5-year History of OPEX	Replacement costs are to the facility level	Yes	Yes, Object ID (GIS) available per facility	Adjusted based off of insurance valuation	- Age/Estimated Service Life (ESL) used for condition - Capital projections based on operations/engineering judgement
Water	Reservoir	- 16 Facilities			\$ 1.00	Over 30 years	- 100-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - 5-year History of OPEX	Condition and replacement values are to the facility level	Yes	GIS compatible, there is a facilities location map with the facility name	- AECOM provided replacement values during the condition assessment, however HW identified that they were low and were contractor costs only and would stick to their costs. - The replacement values consider both replacement and rehabilitation where appropriate. The reservoirs with the condition data have detailed information, the remaining assets' expenditure needs were determined based off of the 2016 AMP	- Half of the assets have condition data (2017 AECOM report), the rest are estimated by age/ESL
Water	Chambers	- 13 Control Chambers - 29 Meter Chambers - 85 PRV Chambers - 11 Reservoir Chambers - 4 Valve Chambers			\$ 0.34	Over 30 years	- 100-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Replacement costs are to the facility level	Yes	Yes, Object ID (GIS) available per facility	Adjusted based off of insurance valuation	- Age/Estimated Service Life (ESL) used for condition - Capital projections based on operations/engineering judgement
Water	Transmission Main	- 1821 Pipe Segments (296km in length)	- Linear	Diameter	\$ 6.60	Over 30 years	- 100-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Replacement costs are to pipe cohorts	Yes	Yes, Object ID and limits available for each transmission main	Unit Costs taken from 2012 IRP App. C Table 3.1 Transmission and Distribution mains and added up to 2015-2016 Stats Can prices for 2017 AMP	Age/ESL
Water	Distribution Main	- 10,666 Pipe Segments (1,216km in length)	- Linear	Diameter	\$ 12.00	Over 30 years	- 100-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Replacement costs are to pipe cohorts	Yes	Yes, Object ID available for each distribution main	Unit Costs taken from 2012 IRP App. C Table 3.1 Transmission and Distribution mains and added up to 2015-2016 Stats Can prices for 2017 AMP	Age/ESL
Wastewater	Treatment Facility	- 14 Facilities	- Civil - Mechanical - Electrical - Instrumental	Pump, valve, gate, tanks, etc.	\$ 12.50	Over 30 years	- 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Condition and replacement values are to the component level	Yes	Yes	- Based on IRP 2012 and 2016 AMP	Condition established by staff discussions
Wastewater	Pumping Station	166 Facilities	- Civil - Mechanical - Electrical - Instrumental	Pump, valve, panel, etc.	\$ 12.50	Over 30 years	- 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Condition and replacement costs are to the process area level	Yes	Yes, it shows GIS data (ID, address, region,etc) in AMP B2 spreadsheet	The pump station access database	Conditions established by staff knowledge and collected at sites
Wastewater	Gravity Sewer	- 24,825 Pipe Segments (1271km in length) - Also broken down by wastewater and combined	- Linear	Diameter	\$ 4.90	Over 30 years	- 100-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Replacement costs are to component level	Yes	Yes	Based on Unit Costs with larger scale from 2012 IRP	Age/ESL
Wastewater	Force Main	- 483 Pipe Segments (126km in length)	- Linear	Diameter	\$ 4.00	Over 30 years	- 50-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Replacement costs are to component level	Yes	Yes, Object ID and Pipe ID) in AMP B4 spreadsheet	Unit Costs initially from IRP 2012	Age/ESL
Stormwater	Management Structure	- 50 Facilities	- Inlet - Outlet - Fence - Bank Stabilization, wall, berm - Accessibility		\$ 0.02	Over 30 years	- 70-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan	Replacement costs are to the facility level	Yes	Yes, it has GIS ObjectID per facility/structure	- Rehabilitation costs - Data taken from 2016 AMP Unit Costs	Age/ESL used for condition
Stormwater	Gravity Sewer	- 44,757 Pipe Segments (1,155km in length)	- Linear	Diameter	\$ 7.00	Over 30 years	- 100-year average CAPEX - 30-year average CAPEX - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Replacement costs are to component level	Yes	Yes, it shows ObjectID, in AMP C2 spreadsheet	- Replacement Costs by condition grade - Data taken from 2016 AMP	Age/ESL, starting to collect condition data from cctv
Stormwater	Cross Culvert	- 2432 Pipe Segments	- Linear	Diameter	\$ 2.20	Over 30 years	- 30-year average CAPEX - 5-year CAPEX program - 5-year History of OPEX	Replacement costs are to the component level	Yes	Yes, there is Pipe ID (have to confirm if there are shape_files)	Unit Costs taken from 2016 AMP	Condition from on site visual inspection
Stormwater	Ditches				\$ -	Replaced when needed	- Maintenance Activity Plan - 5-year History of OPEX		No	There is missing ditch data in GIS (38% missing)	Case by case/ replaced when needed	Annual inspection program identifies assets to treat
Stormwater	Driveway Culvert	- 18,000 Culverts	- Linear	Diameter	\$ 0.72	Over 5 years	- Replacement Plan - 5-year detailed CAPEX - Maintenance Activity Plan - 5-year History of OPEX	Funds are budgeted to the program and not specific assets. But there is asset data that could be made into a plan.	No	Yes, there is limited and incomplete Driveway Culvert GIS inventory (have to confirm if there are shape_files)	Based on unit rate \$3,500 provided by Wastewater and Stormwater Services	- Sample of inspections used - 100 driveway culvert replacements per year. The expenditure need could be significantly higher
Total					\$ 75.354							

Appendix E – Cost Comparison


Water Supply Plants



Booster Stations




Reservoirs



Appendix E – Cost Comparison

Watermains



Halifax AMP		
Diameter (mm)	2017 AMP Unit Cost (\$/m)	2019 AMP Unit Cost (\$/m)
200	\$771	\$802
250	\$867	\$902
300	\$1,011	\$1,052
350	\$1,059	\$1,102
400	\$1,106	\$1,151
450	\$1,154	\$1,201
500	\$1,203	\$1,252
550	\$1,250	\$1,301
600	\$1,298	\$1,350
675	\$1,633	\$1,699
750	\$1,728	\$1,798
900	\$1,920	\$1,998
1,050	\$2,399	\$2,496
1,200	\$2,590	\$2,695
1,350	\$3,164	\$3,292
1,500	\$3,930	\$4,089
2,100		\$6,174

Halifax MP

Diameter (mm)

2019 MP Unit Cost (\$/m)

150

\$610

200

\$682

300

\$860

400

\$1,030

500

\$1,510

700

\$2,330

900

\$2,735

200

\$770

400

\$860

600

\$1,018

800

\$1,216

1,000

\$1,414

1,200

\$1,612

1,400

\$1,810

1,600

\$2,008

1,800

\$2,206

2,000

\$2,404

2,200

\$2,602

2,400

\$2,800

2,600

\$3,008

2,800

\$3,206

3,000

\$3,404

3,200

\$3,602

3,400

\$3,800

3,600

\$4,008

3,800

\$4,206

4,000

\$4,404

4,200

\$4,602

4,400

\$4,800

4,600

\$5,008

4,800

\$5,206

5,000

\$5,404

5,200

\$5,602

5,400

\$5,800

5,600

\$6,008

5,800

\$6,206

6,000

\$6,404

6,200

\$6,602

6,400

\$6,800

6,600

\$7,008

6,800

\$7,206

7,000

\$7,404

7,200

\$7,602

7,400

\$7,800

7,600

\$8,008

7,800

\$8,206

8,000

\$8,404

8,200

\$8,602

8,400

\$8,800

8,600

\$9,008

8,800

\$9,206

9,000

\$9,404

9,200

\$9,602

9,400

\$9,800

9,600

\$10,008

9,800

\$10,206

10,000

\$10,404

10,200

\$10,602

10,400

\$10,800

10,600

\$11,008

10,800

\$11,206

11,000

\$11,404

11,200

\$11,602

11,400

\$11,800

11,600

\$12,008

11,800

\$12,206

12,000

\$12,404

12,200

\$12,602

12,400

\$12,800

12,600

\$13,008

12,800

\$13,206

13,000

\$13,404

13,200

\$13,602

13,400

\$13,800

13,600

\$14,008

13,800

\$14,206

14,000

\$14,404

14,200

\$14,602

14,400

\$14,800

14,600

\$15,008

14,800

\$15,206

15,000

\$15,404

15,200

\$15,602

15,400

\$15,800

15,600

\$16,008

15,800

\$16,206

16,000

\$16,404

16,200

\$16,602

16,400

\$16,800

16,600

\$17,008

16,800

\$17,206

17,000

\$17,404

17,200

\$17,602

17,400

\$17,800

17,600

\$18,008

17,800

\$18,206

18,000

\$18,404

18,200

\$18,602

18,400

\$18,800

18,600

\$19,008

18,800

\$19,206

19,000

\$19,404

19,200

\$19,602

19,400

\$19,800

19,600

\$20,008

19,800

\$20,206

20,000

\$20,404

20,200

\$20,602

20,400

\$20,800

20,600

\$21,008

20,800

\$21,206

21,000

\$21,404

21,200

\$21,602

21,400

\$21,800

21,600

\$22,008

21,800

\$22,206

22,000

\$22,404

22,200

\$22,602

22,400

\$22,800

22,600

\$23,008

22,800

\$23,206

23,000

\$23,404

23,200

\$23,602

23,400

\$23,800

23,600

\$24,008

23,800

\$24,206

24,000

\$24,404

24,200

\$24,602

24,400

\$24,800

24,600

\$25,008

24,800

\$25,206

25,000



\$25,404

25,200

\$25,602

</div


Wastewater Treatment Plants



Wastewater Treatment Plants




Pumping Stations



Appendix E – Cost Comparison

Sewers



Halifax AMP		
Diameter (mm)	2019 AMP Unit Cost (\$/m)	
200	\$759	
300	\$797	
375	\$836	
450	\$894	
525	\$952	
600	\$1,010	
750	\$1,068	
900	\$1,145	
1050	\$1,261	
1200	\$1,744	
1350	\$2,130	
1500	\$2,323	
1650	\$2,516	
1800	\$2,902	
2100	\$3,288	
2400	\$4,061	
3000	\$4,061	

Halifax MP		
Diameter (mm)	2019 MP Unit Cost (\$/m)	
300	\$736	
375	\$786	
450	\$849	
525	\$911	
600	\$997	
750	\$1,387	
900	\$1,599	
1050	\$1,965	
1200	\$2,238	
1500	\$2,879	
1800	\$3,807	

ON Municipality F		
Diameter (mm)	Unit Cost (2012 \$/m)	Unit Cost (2019 \$/m)
375	\$900	\$1,057
400	\$970	\$1,139
450	\$1,010	\$1,186
525	\$1,040	\$1,221
600	\$1,250	\$1,468

ON Municipality D		
Diameter (mm)	Unit Cost (2012 \$/m)	Unit Cost (2019 \$/m)
300	\$633	
375	\$675	
450	\$735	\$949
525	\$780	\$1,008
600	\$865	\$1,117
675	\$1,086	\$1,403
750	\$1,190	\$1,537
825	\$1,239	\$1,600
900	\$1,517	\$1,960
975	\$2,349	\$3,034
1050	\$2,693	\$3,479
1200	\$3,006	\$3,883
1350	\$3,383	\$4,370
1500	\$3,794	\$4,901
1650	\$4,202	\$5,428
1800	\$4,742	\$6,125
2100	\$5,355	\$6,917
2400	\$6,960	\$8,990
3000	\$9,509	\$12,283

ON Municipality G		
Diameter (mm)	Cost 2013\$	Cost 2019\$
375	\$692	\$894
450	\$735	\$949
525	\$780	\$1,008
600	\$865	\$1,117
675	\$1,086	\$1,403
750	\$1,190	\$1,537
825	\$1,239	\$1,600
900	\$1,517	\$1,960
975	\$2,349	\$3,034
1050	\$2,693	\$3,479
1200	\$3,006	\$3,883
1350	\$3,383	\$4,370
1500	\$3,794	\$4,901
1650	\$4,202	\$5,428
1800	\$4,742	\$6,125
2100	\$5,355	\$6,917
2400	\$6,960	\$8,990
3000	\$9,509	\$12,283


ON Municipality H		
Diameter (mm)	Total Unit Cost 2019 \$/m	
300	\$632	
375	\$659	\$725
450	\$715	\$787
525	\$769	\$846
600	\$990	\$1,090
675	\$1,208	\$1,330
750	\$1,331	\$1,465
825	\$1,428	\$1,572
900	\$1,680	\$1,849
975	\$1,804	\$1,985
1050	\$1,995	\$2,196
1200	\$2,239	\$2,464
1350	\$2,454	\$2,701
1500	\$2,752	\$3,029
1800	\$3,496	\$3,848
2100	\$4,322	\$4,757
2400	\$5,323	\$5,858
3000	\$7,424	\$8,171

ON Municipality I		
Diameter (mm)	Total Unit Cost 2016 \$/m	Total Unit Cost 2019 \$/m
300	\$618	\$680
375	\$659	\$725
450	\$715	\$787
525	\$769	\$846
600	\$990	\$1,090
675	\$1,208	\$1,330
750	\$1,331	\$1,465
825	\$1,428	\$1,572
900	\$1,680	\$1,849
975	\$1,804	\$1,985
1050	\$1,995	\$2,196
1200	\$2,239	\$2,464
1350	\$2,454	\$2,701
1500	\$2,752	\$3,029
1800	\$3,496	\$3,848
2100	\$4,322	\$4,757
2400	\$5,323	\$5,858
3000	\$7,424	\$8,171

ON Municipality J		
Diameter (mm)	Total Unit Cost 2016 \$/m	Total Unit Cost 2019 \$/m
300	\$618	\$680
375	\$659	\$725
450	\$715	\$787
525	\$769	\$846
600	\$990	\$1,090
675	\$1,208	\$1,330
750	\$1,331	\$1,465
825	\$1,428	\$1,572
900	\$1,680	\$1,849
975	\$1,804	\$1,985
1050	\$1,995	\$2,196
1200	\$2,239	\$2,464
1350	\$2,454	\$2,701
1500	\$2,752	\$3,029
1800	\$3,496	\$3,848
2100	\$4,322	\$4,757
2400	\$5,323	\$5,858
3000	\$7,424	\$8,171

Appendix E – Cost Comparison

Forcemains



Halifax AMP	
Diameter (mm)	2017 AMP Unit Cost (\$/m)
150	\$765
200	\$827
250	\$893
300	\$972
350	\$1,253
400	\$1,485
450	\$1,710
500	\$1,950
600	\$2,445
750	\$2,624
900	\$3,035
1,050	\$3,548
1,200	\$4,064

Halifax MP	
Diameter (mm)	2019 MP Unit Cost (\$/m)
150	\$765
200	\$860
250	\$929
300	\$1,011
350	\$1,204
400	\$1,440
450	\$1,545
500	\$1,779
600	\$2,544
750	\$2,730
900	\$3,158
1,050	\$3,691
1,200	\$4,228
1,350	\$5,247
1,500	\$5,806
1,800	\$7,414

ON Municipality F	
Diameter (mm)	Unit Cost (2012 \$/m)
150	\$710
200	\$891
250	\$960
400	\$1,070

ON Municipality D	
Diameter (mm)	2019 MP Unit Cost (\$/m)
400	\$869
450	\$960
500	\$1,131
600	\$1,330
750	\$1,525
900	\$1,813
1,050	\$2,131
1,200	\$2,516
1,350	\$3,062
1,500	\$3,400


ON Municipality G	
Diameter (mm)	Cost 2012\$
150	\$564
200	\$608
250	\$656
300	\$713
350	\$910
400	\$1,072
450	\$1,232
500	\$1,402
600	\$1,784
750	\$1,900
900	\$2,211
1,050	\$2,597
1,200	\$2,987

ON Municipality H	
Diameter (mm)	Total Unit Cost (2019 \$/m)
150	\$459
200	\$527
250	\$604
300	\$676
350	\$784
400	\$846
450	\$959
500	\$1,094
600	\$1,309
750	\$1,565
900	\$1,944
1,050	\$2,248
1,200	\$2,655
1,350	\$3,216
1,500	\$3,683
1,650	\$4,150
1,800	\$4,605
2,100	\$5,253

ON Municipality I	
Diameter (mm)	Total Unit Cost 2016 \$/m
150	\$867
200	\$867
250	\$867
300	\$867
350	\$868
400	\$868
450	\$868
500	\$1,104
600	\$1,309
750	\$1,565
900	\$1,944
1,050	\$2,248
1,200	\$2,655
1,350	\$3,216
1,500	\$3,683
1,650	\$4,150
1,800	\$4,605
2,100	\$5,253

ON Municipality J	
Diameter (mm)	Total Unit Cost 2019 \$/m
400	\$868
450	\$968
500	\$1,104
600	\$1,309
750	\$1,565
900	\$1,944
1,050	\$2,248
1,200	\$2,655
1,350	\$3,216
1,500	\$3,562
1,650	\$4,131
1,800	\$4,605
2,100	\$5,253

Stormwater Sewers



Appendix F – Unit Cost Tables

Table 1: Sewer Unit Costs up to 5m Depth

Diameter	Excavation			Granular Bedding			Pipe			Backfill			Subtotal Unit Cost	Restoration	Manhole Allowance	Total Unit Cost
	Volume	Cost	Unit Cost	Volume	Cost	Unit Cost	Supply Cost	Install	Pipe Supply + Install	Vol	Cost	Unit Cost				
(mm)	(m³/m)	(\$/m³)	(\$/m)	(m³/m)	(\$/m³)	(\$/m)	(\$/m)	(\$/m)	(\$/m)	(m³/m)	(\$/m³)	(\$/m)	(\$/m)	(\$/m)	(\$/m)	(2019 \$/m)
300	5.0	32	\$ 160	1.0	67	\$ 67	\$ 77	\$ 44	\$ 121	4.0	30	\$ 120	\$ 468	\$ 212	\$ 55	\$ 736
375	5.5	32	\$ 176	1.0	67	\$ 67	\$ 96	\$ 44	\$ 140	4.5	30	\$ 135	\$ 518	\$ 212	\$ 55	\$ 786
450	6.0	32	\$ 192	1.1	67	\$ 74	\$ 123	\$ 44	\$ 167	4.9	30	\$ 147	\$ 580	\$ 214	\$ 55	\$ 849
525	6.5	32	\$ 208	1.2	67	\$ 80	\$ 148	\$ 44	\$ 192	5.3	30	\$ 159	\$ 640	\$ 216	\$ 55	\$ 911
600	7.0	32	\$ 224	1.4	67	\$ 94	\$ 195	\$ 44	\$ 239	5.6	30	\$ 168	\$ 725	\$ 216	\$ 55	\$ 997
750	9.0	32	\$ 288	2.0	67	\$ 134	\$ 390	\$ 53	\$ 443	7.0	30	\$ 210	\$ 1,075	\$ 247	\$ 65	\$ 1,387
900	9.5	32	\$ 304	2.4	67	\$ 161	\$ 542	\$ 53	\$ 595	7.1	30	\$ 213	\$ 1,273	\$ 251	\$ 75	\$ 1,599
1050	11.5	32	\$ 368	3.1	67	\$ 208	\$ 715	\$ 53	\$ 768	8.4	30	\$ 252	\$ 1,596	\$ 279	\$ 90	\$ 1,965
1200	12.5	32	\$ 400	3.4	67	\$ 228	\$ 896	\$ 53	\$ 949	9.1	30	\$ 273	\$ 1,850	\$ 284	\$ 105	\$ 2,238
1500	14.0	32	\$ 448	3.9	67	\$ 261	\$ 1,341	\$ 60	\$ 1,401	10.1	30	\$ 303	\$ 2,413	\$ 316	\$ 150	\$ 2,879
1800	16.0	32	\$ 512	5.1	67	\$ 342	\$ 1,942	\$ 60	\$ 2,002	10.9	30	\$ 327	\$ 3,182	\$ 325	\$ 300	\$ 3,807
2100	17.5	32	\$ 560	6.0	67	\$ 402	\$ 2,581	\$ 60	\$ 2,641	11.5	30	\$ 345	\$ 3,948	\$ 331	\$ 350	\$ 4,629
2400	19.5	32	\$ 624	7.0	67	\$ 469	\$ 3,433	\$ 60	\$ 3,493	12.5	30	\$ 375	\$ 4,961	\$ 340	\$ 400	\$ 5,700
3000	23.0	32	\$ 736	9.0	67	\$ 603	\$ 5,261	\$ 60	\$ 5,321	14.0	30	\$ 420	\$ 7,080	\$ 355	\$ 450	\$ 7,885

Table 2: Sewer Unit Costs up to 10m Depth

Diameter	Excavation			Granular Bedding			Pipe			Backfill			Subtotal Unit Cost	Restoration	Manhole Allowance	Total Unit Cost
	Volume	Cost	Unit Cost	Volume	Cost	Unit Cost	Supply Cost	Install	Pipe Supply + Install	Vol	Cost	Unit Cost				
(mm)	(m³/m)	(\$/m³)	(\$/m)	(m³/m)	(\$/m³)	(\$/m)	(\$/m)	(\$/m)	(\$/m)	(m³/m)	(\$/m³)	(\$/m)	(\$/m)	(\$/m)	(\$/m)	(2019 \$/m)
300	10.0	45	\$ 450	0.9	67	\$ 57	\$ 77	\$ 44	\$ 121	9.1	30	274	\$ 903	\$ 212	\$ 110	\$ 1,225
375	11.0	45	\$ 495	1.0	67	\$ 64	\$ 96	\$ 44	\$ 140	10.0	30	301	\$ 1,001	\$ 212	\$ 110	\$ 1,323
450	12.0	45	\$ 540	1.1	67	\$ 73	\$ 123	\$ 44	\$ 167	10.9	30	327	\$ 1,108	\$ 214	\$ 110	\$ 1,432
525	13.0	45	\$ 585	1.4	67	\$ 92	\$ 148	\$ 44	\$ 192	11.6	30	349	\$ 1,218	\$ 216	\$ 110	\$ 1,545
600	14.0	45	\$ 630	1.5	67	\$ 102	\$ 195	\$ 44	\$ 239	12.5	30	374	\$ 1,346	\$ 216	\$ 110	\$ 1,673
750	18.0	45	\$ 810	1.9	67	\$ 127	\$ 390	\$ 53	\$ 443	16.1	30	484	\$ 1,863	\$ 247	\$ 130	\$ 2,240
900	19.0	45	\$ 855	2.2	67	\$ 147	\$ 542	\$ 53	\$ 595	16.8	30	505	\$ 2,101	\$ 251	\$ 150	\$ 2,502
1050	23.0	45	\$ 1,035	2.5	67	\$ 169	\$ 715	\$ 53	\$ 768	20.5	30	615	\$ 2,586	\$ 279	\$ 180	\$ 3,046
1200	25.0	45	\$ 1,125	2.8	67	\$ 186	\$ 896	\$ 53	\$ 949	22.2	30	667	\$ 2,927	\$ 284	\$ 210	\$ 3,421
1500	28.0	45	\$ 1,260	3.5	67	\$ 233	\$ 1,341	\$ 60	\$ 1,401	24.5	30	736	\$ 3,629	\$ 316	\$ 300	\$ 4,246
1800	32.0	45	\$ 1,440	4.2	67	\$ 284	\$ 1,942	\$ 60	\$ 2,002	27.8	30	833	\$ 4,559	\$ 325	\$ 600	\$ 5,484
2100	35.0	45	\$ 1,575	5.0	67	\$ 338	\$ 2,581	\$ 60	\$ 2,641	30.0	30	899	\$ 5,453	\$ 331	\$ 700	\$ 6,484
2400	39.0	45	\$ 1,755	5.9	67	\$ 399	\$ 3,433	\$ 60	\$ 3,493	33.1	30	992	\$ 6,639	\$ 340	\$ 800	\$ 7,779
3000	46.0	45	\$ 2,070	7.8	67	\$ 522	\$ 5,261	\$ 60	\$ 5,321	38.2	30	1147	\$ 9,059	\$ 355	\$ 900	\$ 10,315

Table 3: Watermain Unit Costs up to 2m Depth

Diameter (mm)	Excavation			Granular Bedding			Pipe			Backfill			Subtotal Unit Cost	Restoration	Valves and Appurtenances	Total Unit Cost
	Volume (m ³ /m)	Cost (\$/m ³)	Cost (\$/m)	Volume (m ³ /m)	Cost (\$/m ³)	Cost (\$/m)	Supply Cost (\$/m)	Install (\$/m)	Pipe Supply + Install (\$/m)	Vol (m ³ /m)	Cost (\$/m ³)	Unit Cost (\$/m)				
150	1.6	25	\$ 39	0.7	67	\$ 44	\$ 79	\$ 162	\$ 241	0.9	30	27	\$ 350	\$ 150	\$ 110	\$ 610
200	1.7	25	\$ 41	0.7	67	\$ 49	\$ 111	\$ 162	\$ 273	0.9	30	28	\$ 392	\$ 170	\$ 120	\$ 682
250	1.8	30	\$ 53	0.8	67	\$ 54	\$ 147	\$ 162	\$ 309	1.0	30	29	\$ 445	\$ 185	\$ 130	\$ 760
300	1.9	30	\$ 56	0.9	67	\$ 59	\$ 185	\$ 162	\$ 347	1.0	30	30	\$ 492	\$ 212	\$ 140	\$ 844
350	2.0	30	\$ 59	1.0	67	\$ 64	\$ 228	\$ 162	\$ 391	1.0	30	31	\$ 545	\$ 212	\$ 145	\$ 902
400	2.1	30	\$ 63	1.0	67	\$ 70	\$ 275	\$ 162	\$ 437	1.0	40	42	\$ 611	\$ 214	\$ 150	\$ 976
500	2.3	30	\$ 69	1.2	67	\$ 81	\$ 350	\$ 175	\$ 525	1.1	40	44	\$ 719	\$ 230	\$ 160	\$ 1,109
600	2.5	30	\$ 75	1.4	67	\$ 92	\$ 425	\$ 175	\$ 600	1.1	45	52	\$ 819	\$ 245	\$ 170	\$ 1,233
750	2.8	40	\$ 113	1.6	67	\$ 109	\$ 625	\$ 200	\$ 825	1.2	50	60	\$ 1,107	\$ 275	\$ 180	\$ 1,562
900	3.1	50	\$ 157	1.9	67	\$ 127	\$ 800	\$ 400	\$ 1,200	1.3	55	69	\$ 1,553	\$ 300	\$ 200	\$ 2,053
1050	3.4	65	\$ 223	2.1	67	\$ 143	\$ 1,200	\$ 600	\$ 1,800	1.3	90	116	\$ 2,282	\$ 330	\$ 250	\$ 2,862
1200	3.8	80	\$ 302	2.5	67	\$ 165	\$ 1,500	\$ 750	\$ 2,250	1.3	125	166	\$ 2,883	\$ 360	\$ 300	\$ 3,543
1350	4.1	95	\$ 392	2.8	67	\$ 187	\$ 1,750	\$ 800	\$ 2,550	1.3	150	202	\$ 3,330	\$ 400	\$ 350	\$ 4,080
1500	4.3	110	\$ 476	3.0	67	\$ 200	\$ 1,900	\$ 850	\$ 2,750	1.3	175	236	\$ 3,663	\$ 425	\$ 400	\$ 4,488
1800	5.5	150	\$ 825	4.2	67	\$ 283	\$ 2,252	\$ 900	\$ 3,152	1.3	200	259	\$ 4,518	\$ 450	\$ 475	\$ 5,443
2100	6.1	175	\$ 1,068	4.9	67	\$ 329	\$ 2,581	\$ 900	\$ 3,481	1.2	225	272	\$ 5,149	\$ 475	\$ 550	\$ 6,174

Table 4: Watermain Unit Costs >5m Depth

Diameter	Excavation			Granular Bedding			Pipe			Backfill			Subtotal Unit Cost	Restoration	Total Unit Cost	HALIFAX FORCEMAIN Total Unit Cost (+40% for twin)
	Volume	Cost	Cost	Volume	Cost	Cost	Supply Cost	Install	Pipe Supply + Install	Vol	Cost	Cost				
(mm)	(m³/m)	(\$/m³)	(\$/m)	(m³/m)	(\$/m³)	(\$/m)	(\$/m)	(\$/m)	(\$/m)	(m³/m)	(\$/m³)	(\$/m)	(\$/m)	(\$/m)	(2019 \$/m)	(2019 \$/m)
150	4.0	45	\$ 180	1.0	67	\$ 67	\$ 44	\$ 57	\$ 101	3.0	30	90	\$ 439	\$ 150	\$ 589	\$ 824
200	4.0	45	\$ 180	1.0	67	\$ 67	\$ 72	\$ 57	\$ 129	3.0	30	90	\$ 467	\$ 170	\$ 637	\$ 891
250	4.5	45	\$ 203	1.1	67	\$ 74	\$ 103	\$ 57	\$ 160	3.4	30	102	\$ 539	\$ 185	\$ 724	\$ 1,013
300	4.5	45	\$ 203	1.2	67	\$ 81	\$ 141	\$ 57	\$ 198	3.3	30	99	\$ 581	\$ 212	\$ 793	\$ 1,110
350	5.0	45	\$ 225	1.4	67	\$ 94	\$ 332	\$ 57	\$ 389	3.6	30	108	\$ 816	\$ 212	\$ 1,029	\$ 1,440
400	5.3	45	\$ 236	1.9	67	\$ 128	\$ 372	\$ 57	\$ 429	3.4	30	101	\$ 894	\$ 214	\$ 1,108	\$ 1,551
450	5.3	45	\$ 236	2.0	67	\$ 134	\$ 390	\$ 57	\$ 447	3.3	30	98	\$ 915	\$ 220	\$ 1,135	\$ 1,590
500	6.3	45	\$ 284	2.2	67	\$ 148	\$ 452	\$ 57	\$ 510	4.1	30	123	\$ 1,064	\$ 230	\$ 1,294	\$ 1,812
600	6.3	45	\$ 284	2.4	67	\$ 161	\$ 542	\$ 162	\$ 705	3.9	30	117	\$ 1,266	\$ 245	\$ 1,511	\$ 2,116
750	8.9	45	\$ 402	2.5	67	\$ 168	\$ 625	\$ 162	\$ 787	6.4	30	193	\$ 1,549	\$ 275	\$ 1,824	\$ 2,554
900	13.3	45	\$ 599	3.1	67	\$ 208	\$ 715	\$ 162	\$ 877	10.2	30	306	\$ 1,990	\$ 300	\$ 2,290	\$ 3,206
1050	14.4	45	\$ 649	3.4	67	\$ 228	\$ 896	\$ 189	\$ 1,085	11.0	30	331	\$ 2,293	\$ 330	\$ 2,623	\$ 3,672
1200	16.9	45	\$ 762	3.9	67	\$ 262	\$ 1,096	\$ 221	\$ 1,316	13.0	30	391	\$ 2,732	\$ 360	\$ 3,092	\$ 4,329
1350	20.6	45	\$ 928	4.2	67	\$ 282	\$ 1,341	\$ 303	\$ 1,644	16.4	30	493	\$ 3,348	\$ 400	\$ 3,748	\$ 5,247
1500	22.1	45	\$ 992	3.1	67	\$ 207	\$ 1,606	\$ 347	\$ 1,954	19.0	30	569	\$ 3,722	\$ 425	\$ 4,147	\$ 5,806
1800	27.6	45	\$ 1,240	3.5	67	\$ 233	\$ 2,252	\$ 398	\$ 2,650	24.1	30	723	\$ 4,846	\$ 450	\$ 5,296	\$ 7,414
2100	30.6	45	\$ 1,378	6.0	67	\$ 403	\$ 2,581	\$ 398	\$ 2,979	24.6	30	739	\$ 5,499	\$ 475	\$ 5,974	\$ 8,364

Table 5: Sewer Trenchless Crossing Costs

Sewer Trenchless Crossings Assumed Length Stated on table and includes manhole each side of crossing			
Diameter (mm)	For Creeks & Trans Canada	For Regional Roads, Rail and Hydro Corridors	For Freeways, Major Creek Crossings
	Length = 20m	Length = 60m	Length = 150m
	2019 \$ Cost		
200	\$66,000	\$118,000	\$235,000
250	\$66,000	\$118,000	\$235,000
300	\$66,000	\$118,000	\$235,000
375	\$166,000	\$418,000	\$985,000
450	\$196,000	\$448,000	\$1,015,000
525	\$196,000	\$448,000	\$1,015,000
600	\$196,000	\$448,000	\$1,015,000
675	\$246,000	\$498,000	\$1,065,000
750	\$246,000	\$498,000	\$1,065,000
825	\$316,000	\$708,000	\$1,590,000
900	\$366,000	\$758,000	\$1,640,000
975	\$366,000	\$758,000	\$1,640,000
1050	\$416,000	\$808,000	\$1,690,000
1200	\$416,000	\$808,000	\$1,690,000
1350	\$480,000	\$1,000,000	\$2,170,000
1500	\$480,000	\$1,000,000	\$2,170,000
1650	\$480,000	\$1,000,000	\$2,170,000
1800	\$480,000	\$1,000,000	\$2,170,000
2100	#N/A	#N/A	#N/A
2400	#N/A	#N/A	#N/A
3000	#N/A	#N/A	#N/A

Table 6: Forcemain/Watermain Trenchless Crossing Costs

Forcemain/Watermain Trenchless Crossings Assumed Length Stated on table and includes valve each side of crossing			
Diameter (mm)	For Creeks & Trans Canada	For Regional Roads, Rail and Hydro Corridors	For Freeways, Major Creek Crossings
	Length = 20m	Length = 60m	Length = 150m
	2019 \$ Cost		
150	\$29,000	\$81,000	\$198,000
200	\$30,000	\$82,000	\$199,000
250	\$30,000	\$82,000	\$199,000
300	\$37,000	\$89,000	\$206,000
350	\$45,000	\$97,000	\$214,000
400	\$203,000	\$455,000	\$1,022,000
450	\$208,000	\$460,000	\$1,027,000
500	\$220,000	\$472,000	\$1,039,000
600	\$248,000	\$500,000	\$1,067,000
750	\$296,000	\$548,000	\$1,115,000
900	\$378,000	\$770,000	\$1,652,000
1050	\$439,000	\$831,000	\$1,713,000
1200	\$507,000	\$899,000	\$1,781,000

Table 6: Tunneling Construction Unit Costs

Tunnelling Construction Costs			
Diameter	2019 \$ Cost	Diameter	2019 \$ Cost
150	\$ 1,300.00	750	\$ 6,300.00
200	\$ 1,300.00	825	\$ 9,800.00
250	\$ 1,300.00	900	\$ 9,800.00
300	\$ 1,300.00	975	\$ 9,800.00
325	\$ 1,300.00	1050	\$ 9,800.00
350	\$ 1,300.00	1200	\$ 9,800.00
375	\$ 6,300.00	1350	\$ 13,000.00
400	\$ 6,300.00	1500	\$ 13,000.00
450	\$ 6,300.00	1650	\$ 13,000.00
500	\$ 6,300.00	1800	\$ 13,000.00
525	\$ 6,300.00	2100	\$ 13,000.00
600	\$ 6,300.00	2400	\$ 13,000.00
675	\$ 6,300.00	3000	\$ 13,000.00

Appendix G – Sample Costing Sheet

PROJECT NO.:	Strategy 2c - 4
PROJECT NAME:	Existing Conveyance Upgrades
PROJECT DESCRIPTION:	Sackville Trunk Upgrades (1050mm)

CAPITAL BUDGET YEAR:	
VERSION:	
DATE UPDATED:	
UPDATED BY:	

Class Estimate Type:	Class 4	Class adjusts Contingency and expected accuracy
Project Complexity	Low	Complexity adjusts expected accuracy
Accuracy Range:	20%	
Area Condition:	Urban	Area Condition uplifts unit cost and restoration

= Field has drop down
= Field must be manually populated
= Field auto-filled based on project details

PROPOSED DIAMETER:	1050 mm	
TOTAL LENGTH:	632 m	
Tunnelled	0 m	0%
Open Cut	632 m	100%

CONSTRUCTION ASSUMPTION:	Sewer 5m
SYSTEM:	Wastewater


COST ESTIMATION SPREADSHEET

COMPONENT	RATE (%)	RATE (\$)	UNIT	ESTIMATED QUANTITY	COST PER UNIT	SUB-TOTAL	COMMENTS
Construction Cost							
Pipe Construction - Open Cut			m	632 m	\$1,965	\$1,241,884	
Pipe Construction - Tunneling			m	0 m	\$0	\$0	
Pipe Construction Uplift (Based on Area Conditions)	30%					\$372,565	
Minor Creek Crossings			ea.	0	\$416,000	\$0	
Major Creek Crossings			ea.	0	\$1,690,000	\$0	
Road Crossings (Highway)			ea.	2	\$808,000	\$1,616,000	Bedford Bypass crossing
Major Road Crossings (Freeway)			ea.	1	\$1,690,000	\$1,690,000	Crossing Harvest Hwy
Utility Crossings			ea.	0	\$808,000	\$0	
Pumping Station - New			l/s	0	\$0	\$0	
Pumping Station - Upgrade			l/s	0	\$0	\$0	
Storage (In Ground)			m3	0	\$0	\$0	
Treatment			ML/d	0	\$0	\$0	
Sub-Total Construction Only Costs					\$4,920,000		
Engineering/Design	10%				\$492,000		includes planning, pre-design, detailed design, training, CAD, commissioning
Engineering/Design Sub-Total					\$492,000		
Professional Fees / Geotechnical / Hydrogeological /	1.0%				\$49,200		
Geotechnical Sub-Total Cost					\$49,200		
Construction Management/Contract Administration	10.0%				\$492,000		
Geotechnical Sub-Total Cost					\$492,000		
Property Requirements	0.0%				\$0		
Property Requirements Sub-Total					\$0		
Sub-Total Additional Costs					\$1,033,000		
Sub-Total Construction and Additional Costs					\$5,953,000		
Project Contingency	30%				\$1,786,000		Construction Contingency is dependent on Cost Estimate Class
Project Contingency Sub-Total					\$1,786,000		
Sub-Total after Contingency					\$7,739,000		
Non-Refundable HST	4.286%				\$331,700		
Non-Refundable HST Sub-Total					\$331,700		
Overhead	1%				\$77,000		
Project Contingency Sub-Total					\$77,000		
In House Labour/Engineering/Wages/CAD	2%				\$98,400		
In-house Labour/Wages Sub-Total					\$98,400		
Total (2018 Dollars)					\$8,246,000		Rounded to nearest \$1,000
Other Estimate							
Chosen Estimate					\$8,246,000	2019 Estimate	

Appendix H – Sample RDII Costing Sheet

RDII Reduction Costing Sheet	
Catchment Name	FMZ03
WWTF Catchment	Mill Cove
Relevant Flow Monitors	FMZ01, FMZ18
Date of Assessment	11/20/2018

Item	Amount
Hectares	162
Residential Properties	1776
ICI Properties	12
Meter of Sewer	23477
Number of Manholes	451
Estimated Labour Hours (0.8hr/manhole)	360.8

ONLY ADJUST GREEN CELLS
Map of RDII Reduction Area (Wastewater Model)


Investigation					
	Item and Description	Unit	Quantity	Unit Fee	Total Price
1	Project Management	hours	25.3	\$ 120	\$ 3,031
2	Meetings and Interviews	hours	28.9	\$ 120	\$ 3,464
3	Background information, Desktop studies, Analysis of existing information	hours	18.0	\$ 120	\$ 2,165
4	Preparation of Scope Documentation	hours	36.1	\$ 120	\$ 4,330
5	Smoke Testing - sewers smaller than 675mm	meters	8217.0	\$ 1	\$ 8,217
6	Drainage Survey - Class A - Residential	properties	1243.2	\$ 20	\$ 24,864
7	Drainage Survey - Class A - ICI	buildings	6.0	\$ 85	\$ 510
8	Dye testing (8hrs day, dye trunk+ 2 on-site staff)	days	9.0	\$ 960	\$ 8,659
9	Drainage Survey - Class B	properties	88.8	\$ 80	\$ 7,104
10	Complete CCTV as required	meters	11738.5	\$ 6	\$ 70,431
11	Flow Monitoring	monitor/month	20.0	\$ 1,200	\$ 24,000
12	Rain Gauges	gauge/month	5.0	\$ 850	\$ 4,250
13	Flow Monitoring Data Analysis	monitor/month	20.0	\$ 200	\$ 4,000
14	Survey Management and results analysis	hours	109.0	\$ 120	\$ 13,080
15	Documentation (Report writing, GIS work, etc.)	hours	145.0	\$ 120	\$ 17,400
16	Provisional items (15%)				\$ 29,326
Total Investigation					\$ 224,830

Remediation					
	Item and Description	Unit	Quantity	Unit Fee	Total Price
1	Sewer lining	meters	7043.1	\$ 670	\$ 4,718,877
2	Property disconnection	per property	669	\$ 500	\$ 334,500
Total Remediation					\$ 5,053,377

Total Investigation & Remediation **\$ 5,278,207**



B

HALIFAX WATER
2019 INTEGRATED RESOURCE PLAN
APPENDIX B.1
INFRASTRUCTURE MASTER PLAN



INFRASTRUCTURE MASTER PLAN

EXECUTIVE SUMMARY

Prepared by: GM BluePlan Engineering
For: Halifax Water
October 2019



INFRASTRUCTURE MASTER PLAN

Executive Summary

EXECUTIVE SUMMARY

The Infrastructure Master Plan is a long-term infrastructure planning and engineering study to identify the optimal regional water and wastewater infrastructure implementation plan for Halifax Water to service growth until 2046.

The Infrastructure Master Plan expands on work completed by GM BluePlan under the West Region Wastewater Infrastructure Plan (WRWIP, 2017), which formalized the foundational policies of regional infrastructure planning in wastewater infrastructure needs and formed the servicing strategy for the West Region (Halifax, Beechville-Lakeside-Timberlea (BLT) and Herring Cove). The Infrastructure Master Plan incorporates the WRWIP and provides servicing strategies for the rest of the wastewater network, covering the Central and East Regions. The Infrastructure Master Plan then follows a similar approach for the water system, by formalizing the foundational policies of regional water infrastructure planning and forming a preferred servicing strategy that covers the regional water network for Halifax Water.

Aims and Objectives

The Infrastructure Master Plan has three distinct primary aims:

- To develop, evaluate, identify and detail the water and wastewater infrastructure servicing plans for Halifax Water to service growth to 2046.
- To integrate the WRWIP servicing strategy and its supporting studies into the Infrastructure Master Plan, forming a complete infrastructure master plan for Halifax Water.
- Provide value added through conceptual design and study scoping that support the Infrastructure Master Plan and enhance the preferred strategies.

To achieve the aims of the Infrastructure Master Plan the following objectives have been satisfied:

- Undertake a baseline review of the water and wastewater systems and update assumptions made in the WRWIP.
- In coordination with Halifax Regional Municipality (HRM) Planning Department and Halifax Water, determine baseline and growth planning projections for HRM.
- Review existing criteria, level of service, policy, legislation and best practices related to long term infrastructure planning for water and wastewater networks.
- Review and study potential wet weather management techniques that may be beneficial for overall system management (Wet Weather Flow Management Study).
- Create a Climate Change Management Framework and assess the impact of climate change on water and wastewater design standards.
- Host a series of workshops with Halifax Water Planning, Asset Management, Engineering and Operation staff to understand and document known opportunities and constraints in the water and wastewater networks.
- Build and enhance the modelling tools for Halifax Water through transitioning wastewater models to InfoWorks ICM and updating the existing WaterCAD models.
- Develop strategy solutions, cost estimates, and evaluate alternatives to identify preferred servicing strategies.
- Develop Capital Programs for the water and wastewater projects, studies and costs and identify an implementation phasing plan for the preferred servicing strategies.


INFRASTRUCTURE MASTER PLAN

Executive Summary

- Undertake conceptual designs and study scoping for imminent projects where value can be added to the design.

Document Layout

The Infrastructure Master Plan is comprised of five Volumes as outlined in Executive Summary Figure 1.



Executive Summary Figure 1: Infrastructure Master Plan Volume Layout

Volume 1 includes baseline information supporting the water and wastewater systems, the planning and growth projections, a summary of the standalone studies that were completed under the WRWIP and Infrastructure Master Plan, the general approach and methodologies used to develop the hydraulic model, strategy development processes used to form the final Capital Program, the conceptual designs completed and recommendations moving forward.

Volumes 2 to 5 cover the details within the water and wastewater networks, the unique features, opportunities and constraints in the networks, the assessment of alternatives and projects that lead to forming the preferred strategies, costing and phasing to form the Capital Programs.

As illustrated in Figure 1, the WRWIP has been incorporated into the Infrastructure Master Plan to form a complete master plan of the wastewater and water networks across Halifax Water.



INFRASTRUCTURE MASTER PLAN

EXECUTIVE SUMMARY VOLUME 1 GENERAL INFORMATION

Prepared by: GM BluePlan Engineering

For: Halifax Water

October 2019



VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

VOLUME 1 – GENERAL INFORMATION

Volume 1 covers the general information of the Infrastructure Master Plan. It starts out with outlining how the WRWIP has been integrated into the Infrastructure Master Plan, the aim and objectives, document layout, as described above. The subsequent sections of Volume 1 are summarized below.


Baseline Review and Consultation

The baseline review and consultation process were completed to develop the team's project knowledge on the water and wastewater study areas, and form technically feasible and acceptable solutions. The background review included existing data available and past reports on infrastructure needs and requirements. The background review provided detailed understanding on the existing and potential future requirements on the water and wastewater study areas.

The Figures below provide a general overview of the systems and the location of the main water and wastewater facilities included in the Infrastructure Master Plan study.

WATER

Executive Summary Figure 2 illustrates the delineation of the three main water distribution systems that are owned and operated by Halifax Water, and circles the main water supply plants (WSP) included in the Infrastructure Master Plan. The three main WSP are Pockwock, Lake Major and Bennery Lake WSPs, and the emergency back-ups supplies are Chain Lake and Lake Lamont.




Executive Summary Figure 2: Overview of the Water Distribution System, highlighting the WSPs

VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

WASTEWATER

Executive Summary Figure 3 illustrated the wastewater treatment facilities systems that are owned and operated by Halifax Water and circles the main wastewater treatment facilities (WWTF) included in the Infrastructure Master Plan. The six main WWTF are Halifax, Herring Cove, Beechville Lakeside Timberlea (BLT), Mill Cove, Dartmouth and Eastern Passage.




Executive Summary Figure 3: Overview of the Wastewater Distribution System, highlighting WWTFs

An important component of the Infrastructure Master Plan is stakeholders' involvement and input throughout the consultation process. The main consultation teams involved in the Infrastructure Master Plan are outlined in Executive Summary Figure 4. GM BluePlan has been liaising with the consultation teams to confirm regulatory requirements, determine population growth figures, understand issues and constraints in the networks, and to inform parties on progress and decisions made.

VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary



Executive Summary Figure 4: Baseline Review Consultation Teams

Planning Data and Population Numbers

Halifax Water, GM BluePlan Engineering, and HRM Planning staff collaborated to define the planning projections dataset required to complete the Infrastructure Master Plan. Planning data and growth projections formed the baseline and growth demands on the systems, spanning the period from 2016-2046 (a 30-year planning horizon).



To form the baseline population numbers Census Data was used and distributed using dissemination blocks to civic address points, allowing existing population to be accurately added to the hydraulic models. The baseline employment numbers were determined from Industrial, Commercial and Institutional (ICI) customer billing points, that were then converted to population equivalent (PE), following design standards.

The growth projections defined under the Infrastructure Master Plan, reflect growth trends and planning guidelines to develop the Regional Centre, as outlined in the Centre Plan and Integrated Mobility Plan. Population growth was set to a 1% rate, and employment growth equating to 58% of population growth. Growth was divided between the Regions based on meeting the Integrated Mobility Plan population and employment growth splits and aligning with the Growth Areas and Allocation table, which included data on developments occurring over the project horizon.

Executive Summary Table 1: Growth Population Equivalent (PE) 2016-2046

Location	Employment Growth PE	Population Growth PE	Total Growth PE
Mill Cove	5,623	11,102	16,725 ¹
Halifax	28,839	66,365	95,204
Herring Cove	-	3,814	3,814
BLT	-	4,473	4,473
Dartmouth	32,436	42,074	74,510
Eastern Passage	3,591	3,385	6,976
Aerotech	8,597	-	8,597
Rural	6,877	17,000	23,877
Total	85,963	148,213	234,176

¹ Total growth varied for Mill Cove between the water and wastewater systems. As two growth areas in the Central Region were only serviced by water the growth PE for wastewater was lower at 15,191.

VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

Supporting Studies

Several supporting studies have been completed to formalize the foundational policies of regional infrastructure planning and guide the development of the preferred servicing strategies through a robust and defensible process. The supporting studies are a compilation of studies completed under the WRWIP and Infrastructure Master Plan. The studies are as follows:

1. Design Criteria, Level of Service and Policy Review

A comprehensive review of Halifax Water's existing design criteria, level of service (LOS) objectives, and relevant policies, for water supply and wastewater collection was completed as part of the Infrastructure Master Plan and supported by the investigations completed under the WRWIP.

WASTEWATER

The WRWIP assessed the design criteria, LOS and policy review for the wastewater collection system, to guide the West Region servicing strategy. This document was reviewed under the Infrastructure Master Plan to confirm and update the underlying assumptions for the East and Central Regions covered in the Infrastructure Master Plan.



WATER

A full review of the design criteria, LOS and policy review for the water distribution system was completed under the Infrastructure Master Plan, to support the water servicing strategies. The review for water followed the same approach as the WRWIP, including trend analyses and an industry best practice to validate the appropriateness of the criteria and level of service objectives, as they relate to the Infrastructure Master Plan.



2. WRWIP Supporting Studies

The Long-Term Planning Framework and Cost Estimation Framework were developed under the WRWIP to guide infrastructure planning needs and costing guidance and have been included in the Infrastructure Master Plan, as studies that assisted in guiding the final strategies.



- The Long-Term Planning Framework document provides direction for long-term water, wastewater and stormwater infrastructure planning needs, in a holistic approach that integrates and considers infrastructure types together. The framework considers all drivers of infrastructure management including growth, asset renewal, regulatory compliance, and operability.
- The Cost Estimation Framework was developed to form a standardized process for costing infrastructure projects. Infrastructure project cost estimates are used to create short, medium, and long-term budgets and impact funding requirements, and ultimately customer and developer charges.

3. Wet Weather Flow Management Study

The Wet Weather Flow Management Study was initiated under the WRWIP to better understand the feasibility of alternative wastewater servicing strategies, that focus on wet weather flow management options. The Wet Weather Flow Management Study was initially completed on just the West Region and therefore under the Infrastructure Master Plan the study was revisited and updated to include the Central and East Regions.



VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

The study focuses on three feasibility studies:

- Combined Sewer Separation Feasibility Study
- Low Impact Development (LID) Feasibility Study
- Rainfall Derived Inflow and Infiltration (RDII) Reduction Feasibility Study

COMBINED SEWER SEPARATION FEASIBILITY STUDY

The intent of this study is to identify the potential for strategic sewer separation within the combined networks (Halifax Peninsula and Dartmouth). Requirements to meet the Infrastructure Master Plan objectives and minimum local level of service of the wastewater infrastructure were considered against high level cost and feasibility.

It was ultimately determined that *Young Street, Kempt Road, and Connaught Avenue* in Halifax Peninsula and *Jamieson Street, Wyse Road, Nantucket Avenue, Thistle Street and Canal Street* in Dartmouth, are feasible areas for sewer separation and provide the greatest opportunities for flow reduction.

LOW IMPACT DEVELOPMENT FEASIBILITY STUDY

The intent of this study was to highlight areas across the combined networks with the greatest opportunities to implement Low Impact Development (LID) solutions. This study assessed the feasibility of LID solutions in terms of constructability, cost/benefit, and implementation.

Based on the feasibility study and background review, it is unlikely that LID practices can provide sufficient reductions in flow with confidence in the performance over the short and long term to be an overall solution for the Regional servicing plan. However, these practices can be incorporated into the larger solution, where feasible, to reduce the extent of other capital projects and set the stage for a potential LID programs that targets the private level.

INFLOW AND INFILTRATION REDUCTION FEASIBILITY STUDY

The intent of this study is to identify the potential for rainfall derived inflow and infiltration (RDII) reduction as part of the regional servicing strategy. The study covers the flow monitored separated networks across West, Central and East Regions. The RDII feasibility study provided RDII guidance for the West region under the WRWIP and was then expanded on under the Infrastructure Master Plan, for the Central and East Regions. A more in-depth assessment under the Infrastructure Master Plan led to providing pre-defined target RDII reduction areas that were incorporated into the preferred strategies for East and Central Regions.

VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

4. Climate Change Study

The 2012 Integrated Resource Plan (IRP) identified the need to bring climate change considerations into municipal planning and meet a new objective of “adapting to future climate change”. Through the Infrastructure Master Plan two climate change tasks were completed:



- Developing a “Vulnerability to Climate Change Risk Assessment” framework to create a robust framework that can be applied consistently across assets and be used to complete vulnerability assessments of existing infrastructure
- Review existing Design Standards and the Long-Term Planning Framework with climate change factors, allowing for future projects to include climate change considerations

The outcomes of the study led to climate change being included in the Infrastructure Master Plan as follows:

- Rainfall simulation events include a climate change factor of 16%
- Sea level rise was considered for infrastructure requirements
- A drought study was recommended on drinking water sources

5. Opportunities and Constraints Workshop

An Opportunities and Constraints workshop covering the wastewater and water systems was held at Halifax Water on March 6th, 2018. The workshop included Halifax Water's Operation Teams, Project Managers and Directors and the Halifax Water and GM BluePlan project teams. The workshop was set up to enable the project team to understand issues, constraints and opportunities within the wastewater and water supply networks. The GM BluePlan team then used the outcomes from the workshop to inform the overall servicing strategies that accommodate the Long-Term strategy drivers of growth, compliance, asset renewal, and operational optimization.



6. Unit Costing Workshop

Halifax Water's Unit Costing template is the main tool used for costing projects. The Unit Costing template has been refined over recent years, from costing capital projects under the IRP, being updated under the WRWIP to align with the Cost Estimation Framework, and further reviewed under the Infrastructure Master Plan at a Unit Costing Workshop. At the workshop the template was assessed to confirm current trends and updated to produce 2019 rates. The outcome of changes from a project cost perspective are relatively minor, and covered in the Project Evaluation and Costing section.



VOLUME 1: INFRASTRUCTURE MASTER PLAN


Executive Summary

Hydraulic Modelling

A series of activities were completed to prepare and ultimately use the water and wastewater models to undertake the growth impact analysis on infrastructure requirements. The modelling process included model build, loading and calibration to form the baseline scenario, growth was then applied to the calibrated models to form the growth scenario, from there capacity and compliance was assessed, allowing the strategy development stage to occur. Executive Summary Figure 5 outlines the modelling stages with the processes and steps completed for both the water and wastewater models.



At the end of the modelling process the water systems were included in one model, while the wastewater models were divided by WWTFs. The combined water model was due to the interconnection and synergies between the water systems and strategies combining the regions serviced, while the wastewater models were distinctly separated by the existing WWTFs catchments.



Executive Summary Figure 5: Modelling Stages for the Water and Wastewater Models

To assist with future update to the models, guidelines on the modelling process are included in the appendices of Volume 1.

Capacity and Compliance



The newly calibrated models were used to assess system performance under both existing and growth scenarios. The results from these simulations were used to validate and identify the primary constraints within the system, and to evaluate opportunities to resolve these limitations.

VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

Two other key sources of information were used for the capacity and compliance assessment, they were the opportunities and constraints workshop with Halifax Water staff and a facility desktop analyses. The desktop facility analysis included supply, storage and WSPs capacities for the water systems and WWTFs capacity for the wastewater systems.

The outcomes of the capacity and compliance assessment were used in the development of the servicing strategy for the water and wastewater systems.

Strategy Development

The strategy development process varied between the water and wastewater systems to align with service requirements and regulations. The processes are as follows.

WASTEWATER

The wastewater models followed the same strategy development process completed in the WRWIP. The opportunities and constraints identified for the Regions were used to inform the development of multiple servicing strategy alternatives, that were simulated using the model, costed and evaluated, to identify a preferred servicing strategy. Informed by the hydraulic model and various studies, the strategy development process began with the identification of projects common across all strategies, considered “Common Projects”. Once the Common Projects were defined different servicing strategies were tested in the models and compared, and the preferred servicing strategy was selected.



WATER

The water distribution strategy was developed using four key drivers; accommodate growth, provide security of supply and system resiliency, identify synergies with asset renewal, and where possible provide opportunities for system optimization. The strategy approach for growth followed a top-down approach starting with providing adequate supply to all systems, ensuring transmission networks can sufficiently convey the supply, and confirming local needs are met.



Project Evaluation and Costing Considerations

WASTEWATER

The selection of the preferred strategy was based on selecting the top three to five alternative strategies that would be evaluated against each other to determine the preferred strategy.



The first step was to remove less desirable strategies due to aspects of feasibility, cost and level of service. Then the top three to five alternative strategies were evaluated using the five-point evaluation factors (Technical, Financial, Legal/Jurisdictional, Environmental, and Socio/Cultural). Following stakeholder consultation, the final preferred strategy was presented with input from the project team.

PROJECT COSTING

A capital cost estimate (in 2019 dollars) was completed for all projects encompassed within the proposed strategies. Halifax Water's Unit Costing template, a newly developed RDII Reduction Costing Template and existing knowledge on projects were used to build the final Capital Program costs.



VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

The Unit Costing template is a detailed costing sheet that includes hard and soft cost components. Use of this template in the Infrastructure Master Plan resulted in Class 4 (Master Plan level) cost estimates (planning cost estimate with a 30% margin), in accordance to the Cost Estimation Framework. The costs are unit based and include an allowance for the following additional components:

- Engineering and Design
- Professional Fees/Geotechnical/Hydrogeological
- Construction Management/Contract Administration
- In-House Labour/Engineering/Wages/CAD
- Overheads
- Project Contingency

The Unit Cost template was reviewed and updated through the Infrastructure Master Plan, based on outcomes from the Unit Costing Workshop. The changes to the Unit Cost template included adjustments to unit rates for pipe construction, moving the location of the soft costs in the template and updating the overhead contingencies rate.

The impact of the above changes from a project cost perspective are relatively minor. The main change to costing projects was introducing a RDII Costing Template. The RDII Costing Template was developed to improve the accuracy of costing RDII reduction, through reviewing case studies and costing RDII based on catchment size, land use and volume of existing facilities in the catchment.

A cash flow analysis was completed to assess the annual lifecycle costs and net present value of each project. The individual project costs were added to determine the capital cost of each strategy.

PROJECT PHASING

A project phasing exercise was completed to identify the timing requirements for each project. Projects are either triggered immediately due to existing constraints, in the future when a specified capacity is reached because of growth, or dependent on the completion of other projects.



CAPITAL PROGRAMS

The final Capital Programs for wastewater are in Executive Summary Table 3 and for water are in Executive Summary Table 4, including project name, description, phasing, and capital cost. Executive Summary Table 2 summarizes the capital cost per region for water and wastewater.



Executive Summary Table 2: Total Water and Wastewater Capital Costs Per Region


Location	Total Capital Cost (2019\$)
West Region*	\$186,261,000
Central – Mill Cove	\$163,483,000
East – Eastern Passage	\$49,478,000
East – Dartmouth	\$104,358,000
Water all Regions	\$284,706,000
Total	\$788,286,000

VOLUME 1: INFRASTRUCTURE MASTER PLAN

Executive Summary

*Cost updated from WRWIP to 2019 dollars using the updated Unit Costing and RDII Costing templates

As mentioned above, Volume 1 provides several supporting documents, methodologies and processes that feed into Volumes 2 to 5. Executive Summary Figure 6 summarizes the major components in Volume 1 that support the subsequent volumes.



Executive Summary Figure 6: Volume 1 Supporting Studies Summary

Executive Summary Table 3: Wastewater Capital Program Summary

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)
West Region: Halifax	WR1	WRWIP: Spring Garden Area Sewer Separation	<i>Full separation of Spring Garden LoWSCA pocket - 5 individual projects</i>	2018-2023	2016-2021	\$ 7,281,000
	WR2	WRWIP: Young Street Area Sewer Separation	<i>Full separation of Young Street LoWSCA pocket - 18 individual projects</i>	2018-2023	2016-2021	\$ 21,879,000
	WR3	WRWIP: Sewer Separation Upstream of Kempt CSO	<i>Full separation of a portion of the Kempt CSO sewershed - 17 individual projects</i>	2018-2025	2016-2021	\$ 14,752,000
	WR4	WRWIP: Linear Upsize - Quinpool Road	<i>525mm ø combined sewer upsize along Quinpool Road (from Preston to Oxford)</i>	2020	2016-2021	\$ 437,000
	WR5	WRWIP: Linear Upsize - Gottingen & Cogswell Area	<i>750mm ø combined sewer upsize along Portland Place (from Saunders to Brunswick) + 900mm ø combined sewer upsize along Brunswick Street</i>	2020	2016-2021	\$ 221,000
	WR6	WRWIP: Gottingen Street and North Street Intersection Flow Split	<i>Lower the invert of the combined sewer along Gottingen, on the south side of North Street</i>	2020	2016-2021	\$ 500,000
	WR7	WRWIP: Young Pumping Station Upgrade	<i>New 300mm diameter alignment + Installation of new pumps to increase the station capacity from 114L/s to 250L/s</i>	2027	2026-2031	\$ 2,169,000
	WR8	WRWIP: New Fairfield Holding Tank	<i>New 3,700 cubic metre holding tank at the existing Fairfield Holding Tank site</i>	2046	2041-2046	\$ 12,403,000
	WR9	WRWIP: Replace Armdale Pumping Station Force mains	<i>Upsize the existing 300mm ø Armdale Pumping Station force mains with new twinned 400mm ø force mains</i>	2020	2016-2021	\$ 3,850,000
	WR13	WRWIP: RDII Reduction Program	<i>Implement an Inflow and Infiltration Reduction Program within the Fairview, Clayton Park, and Bridgeview areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)</i>	2020	2016-2021	\$ 15,491,589
Halifax Inflow and Infiltration	WR19	WRWIP: Fairview Cove Linear Upsize	<i>Upsize existing 1050mm ø tunnel to 1800mm ø</i>	2019	2016-2021	\$ 19,781,000
Halifax Fairview Cove Tunnel	WR20	WRWIP: Halifax Treatment Plant Capacity Upgrade	<i>Increase the rated capacity of Halifax WWTF from 134 MLD to 140 MLD</i>	2041	2036-2041	\$ 25,142,000
Wastewater Treatment Facility	WR21	WRWIP: Linear Upgrades within the Kearney Lake Road Area	<i>Sanitary sewer upgrades downstream of the Kearney Lake Road Pumping Station</i>	2033	2031-2036	\$ 2,997,000
Halifax Flow Optimization	WR22	Infrastructure Master Plan: CSO Management Study	<i>Monitor and assess CSO facilities to mitigate discharges (16 facilities). Costed at \$14,000/monitor and \$15,000/CSO for assessment.</i>	2026	2016-2021	\$ 965,000
	WR23	Infrastructure Master Plan: SSO Management Study	<i>Monitor and assess SSO facilities to mitigate discharges (6 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.</i>	2021	2016-2021	\$ 415,000
HALIFAX Total Wastewater Servicing Strategy Cost						\$ 128,283,589



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)
West Region: BLT	BLT WWTF Decommission	WR10	WRWIP: BLT WWTF Decommission - New Timberlea PS	2020	2016-2021	\$ 5,928,000
		WR11	WRWIP: BLT WWTF Decommission - New Timberlea Force main			\$ 19,436,000
		WR12	WRWIP: BLT WWTF Decommission			\$ 500,000
	BLT Diversion to Herring Cove	WR14	WRWIP: BLT Flow Diversion to Herring Cove - New Crown Drive Pumping Station	2033	2031-2036	\$ 8,063,000
		WR15	WRWIP: BLT Flow Diversion to Herring Cove - New Crown Drive Force main			\$ 9,026,000
		WR16	WRWIP: BLT Flow Diversion to Herring Cove - New Gravity Sewer			\$ 4,319,000
		WR17	WRWIP: BLT Flow Diversion to Herring Cove - New Gravity Sewer			\$ 3,266,000
BLT Total Wastewater Servicing Strategy Cost						\$ 50,538,000
Herring Cove	Herring Cove Linear Upsizing	WR18	WRWIP: Herring Cove Road - Gravity Sewer Upsize	2033	2031-2036	\$ 7,439,000
HERRING COVE Total Wastewater Servicing Strategy Cost						\$ 7,439,000
WEST REGION Total Wastewater Servicing Strategy Cost						\$ 186,260,589



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)	
Central Region: Mill Cove and Springfield Lake	Trunk Upgrades	MC1	Trunk Sewer Upgrades	Sackville Trunk Upgrades to 1200mm diameter	2036	2036-2041	\$ 5,101,000
		MC2	Trunk Sewer Upgrades	Sackville Trunk Upgrades to 1050mm diameter	2036	2036-2041	\$ 8,246,000
		MC3	Trunk Sewer Upgrades	Sackville Trunk Upgrades to 1500mm diameter	2036	2036-2041	\$ 144,000
	Storage tank Upgrades	MC4	Storage Tank	Offline storage tank near Sackville Goodlife Fitness Centre (5ML)	2031	2031-2036	\$ 17,469,000
	Upgrades to Pumping Stations	MC5	Fish Hatchery Park Pumping Station Upgrade	Upsize existing 450mm forcemain from Fish Hatchery Park PS to 675mm diameter and increase pumping capacity to 1500 L/s with an addition of 100 L/s capacity	2036	2031-2036	\$ 10,529,000
		MC6	Pumping Station (Beaver Bank #3 PS and Majestic Avenue PS)	Increase pumping capacity at Beaver Bank #3 PS from 55 L/s to 100 L/s, and increase pumping capacity of Majestic Avenue PS from 82 L/s to 165 L/s to eliminate growth-impacted SSO discharge	2036	2036-2041	\$ 1,090,000
	Wastewater Treatment Facility	MC7	Mill Cove Wastewater Treatment Plant Capacity Upgrade	WWTF Upgrade	2021	2021-2026	\$ 89,256,000
	Inflow and Infiltration	MC8	RDII Reduction Program FMZ07, FMZ10, & FMZ40	Implement an Inflow and Infiltration Reduction Program within the Lower Sackville areas FMZ07, FMZ10, & FMZ40 (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)	2020	2016-2021	\$ 9,288,248
		MC9	RDII Reduction Program FMZ02 & FMZ03	Implement an Inflow and Infiltration Reduction Program within Bedford areas FMZ02 & FMZ03 (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)	2031	2031-2036	\$ 8,023,065
	Local New Networks and Upgrades	MC10	Local network upgrades on Beaver Bank Rd. North of Glendale Dr.	Upsize from 200mm to 450mm diameter gravity sewer along Beaver Bank Rd.	2021	2021-2026	\$ 2,086,000
		MC11	Local network upgrades on Beaver Bank Rd. at Galloway Dr.	Upsize from 300mm to 450mm diameter gravity sewer along Beaver Bank Rd.	2021	2021-2026	\$ 1,490,000
		MC12	Local network upgrades on Beaver Bank Rd by Windgate Drive	Upsize from 300mm to 375mm diameter gravity sewer along Beaver Bank Rd.	2021	2021-2026	\$ 1,667,000
		MC13	Local network upgrades on Old Sackville Road south of Harvest Hwy	Upsize from 200mm to 375mm diameter gravity sewer along Old Sackville Road	2036	2036-2041	\$ 845,000
		MC14	Local network upgrades on Hallmark Ave.	Upsize from 200mm to 375mm diameter gravity sewer on Hallmark Ave.	2036	2036-2041	\$ 437,000
		MC15	Local Sewer Upgrades on Waterfront Drive	375 mm Sewer Upgrade on Waterfront Drive	2036	2036-2041	\$ 500,000
	Springfield Lake	MC16	Springfield Lake Connection to Sackville	Decommission Springfield Lake WWTF, divert all flow to Mill Cove WWTF via new pumping station and gravity sewer to connect at top of Sackville trunk sewer.	2043	2041-2046	\$ 6,226,000
	Flow Optimization	MC17	SSO Management Study	Monitor and assess SSO facilities to mitigate discharges (18 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.	2021	2021-2026	\$ 1,086,000
CENTRAL REGION Total Wastewater Servicing Strategy Cost						\$ 163,483,313	



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)	
East Region Eastern Passage	Gravity Pressure Sewer	EP1	Install new Gravity Pressure Sewer	Install new 450 and 825mm Ø gravity pressure sewer	2021	2021-2026	\$ 23,372,000
		EP2	Connect Beaver Crescent and Caldwell Force mains to new 450mm gravity pressure sewer	Connect Beaver Crescent and Caldwell Force mains to new gravity pressure sewer	2026	2026-2031	\$ 78,000
		EP3	Install new pump out stations	Install 4 new pump out stations in the low point of the gravity pressure sewer	2026	2026-2031	\$ 1,676,000
		EP4	Install gate valves at surge tank	Optimize flows at the surge tank through gate valves	2026	2026-2031	\$ 420,000
		EP5	Decommission existing 450mm gravity pressure sewer	Grout fill the 450mm Ø asbestos gravity pressure sewer	2043	2041-2046	\$ 559,000
	Upgrades to Pumping Stations	EP6	Upgrade Quigley Corner Pumping Station	Increase pumping capacity at Quigley to 570l/s with an addition of 343l/s	2021	2021-2026	\$ 2,875,000
		EP7	Optimize Quigley's Corner PS	Force main optimization and SLR assessment	2021	2021-2026	\$ 336,000
		EP8	Upgrade Memorial Drive Pumping Station	Increase pumping capacity at Memorial Drive PS with an addition of 65l/s. Install new dual 300mm Ø force main	2031	2031-2036	\$ 2,633,000
		EP9	Upgrade Beaver Crescent Pumping Station	Increase pumping capacity at Beaver Crescent PS with an addition of 20l/s	2036	2036-2041	\$ 168,000
		EP10	Upgrade Bissett Lake Pumping Station	Increase pumping capacity at Bissett Lake PS with an addition of 350l/s	2041	2036-2041	\$ 2,934,000
		EP11	Upgrade Caldwell Road Pumping Station	Increase pumping capacity at Caldwell Road PS with an addition of 70l/s. Install new dual 200mm Ø force mains	2039	2036-2041	\$ 631,000
Inflow and Infiltration	EP12	RDII Reduction Program FMZ23	Implement an Inflow and Infiltration Reduction Program within the Cole Harbour areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining) - FMZ23	2031	2031-2036	\$ 3,204,580	
	EP13	RDII Reduction Program FMZ24	Implement an Inflow and Infiltration Reduction Program within the Loon Lake areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining) - FMZ24	2020	2016-2021	\$ 1,570,040	
	EP14	RDII Reduction Program FMZ37	Implement an Inflow and Infiltration Reduction Program within the Eastern Passage areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining) - FMZ37	2020	2016-2021	\$ 2,479,704	
Local New Networks and Upgrades	EP15	Local network upgrades on Caldwell Road	Upsize from 200 to 300mm Ø gravity sewer along Caldwell Road	2036	2036-2041	\$ 607,000	
	EP16	Local network upgrades on Colby Drive	Upsize from 200 to 300mm Ø gravity sewer along Colby Drive	2031	2031-2036	\$ 1,176,000	
	EP17	Local network upgrades on Forest Hill Parkway	Construct new 450mm Ø gravity sewer along Forest Hill Parkway connect to pipeline on Nestor Crescent	2041	2041-2046	\$ 4,275,000	
Flow Optimization	EP18	SSO Management Study	Monitor and assess SSO facilities to mitigate discharges (8 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.	2021	2021-2026	\$ 484,000	
EASTERN PASSAGE Total Wastewater Servicing Strategy Cost						\$ 49,478,324	



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)	
East Region : Dartmouth	Lakes and Sewer Separation	D1	LoWSCA: Canal Street Separation	Full separation of Canal Street LoWSCA pocket - 1 individual project. Install new stormwater pipelines, separate 35 properties and reconnect 8 catchbasins.	2020	2016-2021	\$ 1,842,000
		D2	LoWSCA: Wyse Road Separation	Full separation of Wyse Road LoWSCA pocket - 3 individual project, two phases. Phase 1 - Install new stormwater pipelines along Albro Lake Road and Windmill Road, separate 43 properties and reconnect 18 catchbasins (Area A). Phase 2 - Install new stormwater pipelines along Wyse Road, connecting to Albro Lake stormwater pipe, separate 111 properties and reconnect 4 catchbasins (Area B). Install new sewer diversion from Lyle St Catchment to Jamieson(Area C).	2020	2016-2021	\$ 3,860,000
		D3	Additional Stormwater Separation on Wyse Street	450mm Ø stormwater pipe connecting to Park Ave CSO, separate 6 properties and reconnect 1 catchbasin.	2031	2026-2031	\$ 1,912,000
		D5	Albro Lakes Watershed Separation	Full separation of Albro Lakes Watershed, install new stormwater trunk line, connecting to Jamieson Street CSO outfall.	2021	2021-2026	\$ 8,111,000
		D6	Maynard Lake and Clement Street Wetland Separation	Full separation of Maynard Lake and the Clement Street Wetland - 4 phases Phase 1 - Install 1050mm pipeline in Old Ferry Rd, connection to CSO outfall, connect stormwater pipeline from Hazlehurst Street and catchbasins en route Phase 2 - Install 750mm pipeline working upstream to the Wetland, continue to connect to catchbasin en route Phase 3 - Install 600mm pipeline connecting Maynard Lake to the pipeline Phase 4 - Connect to stormwater network for DSM and Fenwick Drive properties and separate North Woodside - Southdale Elementary and surrounding businesses	2031	2026-2031	\$ 642,000
	Upgrades to Pumping Stations	D7	New Valleyford Pumping Station	Install new pumping station by the Valleyford Holding Tank to a capacity of 300/l/s. Install new forcemain down Raymond Street and Maple Drive, to connect to the trunk sewer	2041	2036-2041	\$ 10,446,000
		D8	390 Waverley Road Upgrades	Install new dual 500mm Ø forcemain following existing path with a diversion to the North Dartmouth Trunk Sewer, by Highway 118	2021	2021-2026	\$ 11,361,000
		D9	Anderson Pumping Station Upgrades	Install new 300mm Ø forcemain following existing path. Alter flow path from holding tank to PS by adjusting pipe grades between infrastructure	2031	2031-2036	\$ 340,000
	Dartmouth WWTF Upgrades	D10	Upgrades to Dartmouth WWTF	Upgrade Dartmouth WWTF to meet demand at end of Project Horizon	2043	2036-2041	\$ 12,572,000
	Inflow and Infiltration	D11	RDII Reduction Program	Implement an Inflow and Infiltration Reduction Program within the Ellenvale areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)	2021	2021-2026	\$ 5,941,076
		D12	RDII Reduction Program	Implement an Inflow and Infiltration Reduction Program within the Woodside areas (CCTV, Smoke/Dye Testing, Property Disconnections, Sewer Lining)	2031	2031-2036	\$ 1,120,232
		D13	Additional flow monitoring	Flow monitoring through the catchment to assess areas in model showing flooding	2020	2016-2021	\$ 252,000



Executive Summary Table 3: Wastewater Capital Program Summary (continued)

Project Category	Project ID	Project Name	Project Description	Start Year	Planning Period	Total Capital Cost (2019\$)
East Region : Dartmouth	D15	Green St Upsize	Common project - Upsize from 375 to 750mm Ø gravity sewer along Green Street	2041	2041-2046	\$ 513,000
	D16	Pinecrest Dr Upgrade	Common project - Upsize from 200 to 375mm Ø gravity sewer along Pinecrest Drive	2031	2031-2036	\$ 1,013,000
	D17	Peddars Way Upgrade	Common project - Upsize from 300 to 375mm Ø gravity sewer along Peddars Way	2031	2031-2036	\$ 555,000
	D18	Atlantic Street Upgrade	Common project - Upsize from 250 to 450mm Ø gravity sewer along Atlantic St	2021	2021-2026	\$ 3,831,000
	D19	Akerley Blvd and Railway Alignment Upgrade	Strategy project - Upsize from 250 to 600mm Ø gravity sewer along Akerley Blvd and Railway easement towards Ferguson Road CSO	2041	2036-2041	\$ 4,814,000
	D20	Pleasant Street Upgrade	Strategy project - Upsize from 200 to 450mm Ø gravity sewer along Pleasant St, and towards Cuisack Street CSO	2021	2021-2026	\$ 767,000
	D21	Princess Margaret Blvd. Upgrade	Strategy project - Upsize from 450 to 600mm Ø gravity sewer along Princess Margaret Blvd.	2031	2031-2036	\$ 3,106,000
	D22	Anderson Lake Development Connection	Strategy project - Construct new 450mm Ø gravity sewer to connect Anderson Lake development to Akerley Blvd	2036	2036-2041	\$ 7,609,000
	D23	Marvin Connection	Strategy project - Construct new 450mm Ø gravity sewer in Marvin Street and connect to connect Cuisack Street CSO	2026	2026-2031	\$ 1,380,000
	D24	King Street Diversion	Common Project - 450mm Ø sewer diversion to NDTs	2026	2026-2031	\$ 78,000
Flow Diversion	D25	Diversion to Eastern Passage	Install new pumping station at Melva St CSO. Install new dual 600mm Ø forcemain following Pleasant Street and connecting to existing gravity pipe in Eastern Passage network. Upgrade existing gravity pipe from a 200 to 600mm Ø.	2036	2036-2041	\$ 12,113,000
	D14	CSO Flow Management Study	Monitor and assess CSO facilities to mitigate discharges (11 facilities). Costed at \$14,000/monitor and \$15,000/CSO for assessment.	2036	2036-2041	\$ 675,000
Flow Optimization	D26	SSO Flow Management Study	Monitor and assess SSO facilities to mitigate discharges (9 facilities). Costed at \$14,000/monitor and \$15,000/SSO for assessment.	2021	2016-2021	\$ 555,000
	DARTMOUTH Total Wastewater Servicing Strategy Cost					\$ 104,358,308
EAST REGION Total Wastewater Servicing Strategy Cost					\$ 153,836,631	
ALL REGIONS Total Wastewater Servicing Strategy Cost					\$ 563,082,533	



Executive Summary Table 4: Water Capital Program Summary

Project Category	Project Name	Project ID	Project Task	Start Year	Planning Period	Total Capital Cost (2019\$)
Pockwock - Peninsula	Peninsula Transmission Upgrades (Chain Control)	W06.1	Chain Control Transmission - Existing Peninsula Low Upsize	2021	2021-2026	\$ 3,841,000
		W06.2	Chain Control Transmission - Existing Peninsula Intermediate Upsize	2021	2021-2026	\$ 2,650,000
		W06.3	Pepperell Transmission	2036	2036-2041	\$ 2,702,000
		W06.4	Chain Control Transmission - Existing Peninsula Low Lining	2036	2036-2041	\$ 2,916,000
		W06.5	Chain Control Transmission - Valve Chambers	2036	2036-2041	\$ 1,258,000
	Twinning of Peninsula Transmission (Robie)	W07	Replace High Risk Peninsula Transmission (Robie)	2026	2026-2031	\$ 17,312,000
	Quinpool to Young Connection	W08	Peninsula Intermediate Looping - Quinpool Rd to Young St	2021	2021-2026	\$ 4,319,000
	Young Street Pocket Upgrades	W10.1	Young St Upsize	2026	2026-2031	\$ 1,315,000
		W10.2	Robie St Upsize	2026	2026-2031	\$ 956,000
		W10.3	Almon St Upsize	2026	2026-2031	\$ 1,168,000
		W10.4	Windsor St Upsize	2026	2026-2031	\$ 1,004,000
Pockwock - Other	Lakeside Projects	W01.1	Geizer 158 to Lakeside High Looping	2021	2021-2026	\$ 2,249,000
		W01.2	Gravity Supply to Brunello	2041	2041-2046	\$ 2,328,000
		W01.3	Dominion Cres Upsize	2041	2041-2046	\$ 447,000
		W01.4	Brunello Booster Pump Upgrades	2021	2021-2026	\$ 236,000
	Lively, Geizer Hill, and Leiblin Booster Pump Upgrades	W03	Geizer Hill Booster Pump Upgrades	2021	2021-2026	\$ 277,000
		W04	Leiblin Booster Fire Pump	2019	2016-2021	\$ 395,000
		W15	Lively Booster Pump Upgrades	2036	2036-2041	\$ 38,000
	Herring Cover Upgrades	W05.1	Herring Cove Rd Twinning	2020	2016-2021	\$ 3,585,000
		W05.2	St Michaels Ave Upsize	2041	2041-2046	\$ 502,000
		W05.3	Herring Cove Rd Looping - McIntosh St	2021	2021-2026	\$ 2,272,000
	Lucasville Road Twinning	W12.1	Lucasville Rd Twinning (Phase 1)	2019	2016-2021	\$ 8,117,000
		W12.2	Lucasville Rd Twinning (Phase 2)	2026	2026-2031	\$ 8,956,000
	New Primary Sackville High and Beaver Bank Supply	W13.1	New Primary Feed to Sackville High	2026	2026-2031	\$ 4,953,000
		W13.2	New Sackville Beaver Bank Valve Chamber	2026	2026-2031	\$ 839,000
		W13.3	Reconfiguration of Beaver Bank Booster	2026	2026-2031	\$ 100,000
		W13.4	New Sackville High PRV	2026	2026-2031	\$ 420,000
	Second Supply to Windsor Junction	W14.1	Cobequid High Looping	2026	2026-2031	\$ 2,233,000
		W14.2	Windgate Dr Upsize	2026	2026-2031	\$ 882,000
	New Hemlock Tank	W16	New Hemlock Elevated Tank	2020	2016-2021	\$ 6,209,000
	Pockwock Transmission Looping	W17	Pockwock Transmission Loop through Bedford	2021	2021-2026	\$ 5,069,000
	Second Geizer 158 Feed and Lacewood Drive Loop	W02	Geizer 158 Looping - Lacewood Dr	2041	2041-2046	\$ 2,002,000
		W20	Second Geizer 158 Feed	2041	2041-2046	\$ 9,612,000



Executive Summary Table 4: Water Capital Program Summary (continued)

Project Category	Project Name	Project ID	Project Task	Start Year	Planning Period	Total Capital Cost (2019\$)
Lake Major	New Transmission from Topsail to Burnside	W22.1	New Main Street to Caledonia Road Connection	2021	2021-2026	\$ 3,072,000
		W22.2	Caledonia Rd Twinning	2021	2021-2026	\$ 3,429,000
		W22.3	New Breeze Dr Watermain	2021	2021-2026	\$ 5,801,000
		W28	Tacoma PRV Chamber	2021	2021-2026	\$ 420,000
	Highway 118 Crossing	W23	Highway 118 Crossing - Shubie Park to Dartmouth Crossing	2021	2021-2026	\$ 6,063,000
	Windmill Road Upgrade	W24	Windmill Rd Upsize	2026	2026-2031	\$ 6,104,000
	New Woodside Industrial Park Feed	W25	New Woodside Industrial Park Feed	2021	2021-2026	\$ 1,649,000
	Willowdale-Eastern Passage Connection	W26	Willowdale to Eastern Passage Connection	2036	2036-2041	\$ 6,290,000
System Interconnections Pockwock Transmission WTP Decommissioning	Pockwock Transmission Twinning	W19.1	Pockwock Transmission Twinning - 60in	2031	2031-2036	\$ 65,516,000
		W19.2	Pockwock Transmission Twinning - 54in	2036	2036-2041	\$ 16,228,000
	Extension to Springfield Lake	W21	Extension to Springfield Lake	2041	2041-2046	\$ 3,043,000
	Bedford-Burnside Interconnection	W29.1	Bedford-Burnside System Interconnection (Phase 1)	2036	2036-2041	\$ 24,499,000
		W29.2	Bedford-Burnside System Interconnection (Phase 2)	2036	2036-2041	\$ 11,779,000
	Dartmouth-Peninsula Interconnection	W30.1	Lyle Emergency Booster	2026	2026-2031	\$ 1,045,000
		W30.2	Valving for Central Intermediate Boundary Change	2026	2026-2031	\$ 629,000
	Pockwock-Bennery Interconnection	W31.1	Extension of Fall River to Bennery Lake (Phase 1)	2026	2026-2031	\$ 8,067,000
		W31.2	Extension of Fall River to Bennery Lake (Phase 2)	2026	2026-2031	\$ 9,156,000
		W31.3	Extension of Fall River to Bennery Lake (PS)	2026	2026-2031	\$ 1,310,000
	WSP Decommissioning	W32.1	Decommission Miller Lake WSP - Linear	2019	2016-2021	\$ 628,000
		W32.2	Decommission Miller Lake WSP	2019	2016-2021	\$ 61,000
		W33.1	Decommission Collins Park WSP - Linear	2041	2041-2046	\$ 1,086,000
		W33.2	Decommission Collins Park WSP	2041	2041-2046	\$ 168,000
		W34.1	Decommission Silversands WSP - Linear	2041	2041-2046	\$ 1,931,000
		W34.2	Decommission Silversands WSP	2041	2041-2046	\$ 168,000
	Aerotech Storage	W40	Aerotech Storage	2021	2021-2026	\$ 4,752,000
Studies	Studies	W18	Chain Lake Backup Supply Study	2020	2016-2021	\$ 50,000
		W27	Mt Edward Booster Fire Pump	2019	2016-2021	\$ 50,000
		W29.3	New Orchard Control Chamber	2021	2021-2026	\$ 50,000
		W30.3	Robie Emergency Booster	2021	2021-2026	\$ 50,000
		W35	Safe Yield Study	2020	2016-2021	\$ 100,000
		W36	New Hydraulic Water Model (InfoWater)	2020	2016-2021	\$ 200,000
		W37	Comprehensive PRV Study	2019	2016-2021	\$ 50,000
		W38	Transmission Main Risk Assessment and Prioritization Framework	2020	2016-2021	\$ 50,000
		W39	Tomahawk Lake Supply Study	2036	2036-2041	\$ 50,000
Total Water Servicing Strategy Cost						\$ 284,706,000





INFRASTRUCTURE MASTER PLAN

VOLUME 2 WATER INFRASTRUCTURE

Prepared by: GM BluePlan Engineering

For: Halifax Water

October 2019



VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

VOLUME 2 – WATER INFRASTRUCTURE



Catchment Overview

Halifax Water currently owns and operates three main water supply plants (WSP), two back-up WSPs, and six smaller community supply plants:

Main WSPs

- J.D. Kline WSP (West Region and Central Region) – the Pockwock System
- Lake Major WSP (East Region) – the Lake Major System
- Bennery Lake WSP (Airport and Aerotech Business Park) – the Bennery System

Back-up WSPs:

- Chain Lake
- Lake Lamont


Smaller Community WSPs

- Collins Park
- Silversands
- Miller Lake
- Five Island Lake
- Bomont
- Middle Musquodoboit

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

The water distribution systems are shown in Executive Summary Figure 7.



Executive Summary Figure 7: Existing Water Network Overview

Water Infrastructure Strategy Development

The water distribution servicing strategy has been developed with the primary aim of providing an adequate level of service to existing and future customers out to the 2046 planning horizon, and provides the following key drivers:

- Servicing strategy can accommodate the planned growth and 2046 future system demands;
- Water supply and overall system resiliency are secured, and risk of service interruption is minimized;
- The water distribution system is optimized to enhance operations and maintenance;
- Asset renewals and opportunities for synergy are considered.

The following inputs were used to complete the capacity and compliance analysis for the water distribution system under both existing and growth scenarios, and then assist in developing and testing multiple servicing strategies and selecting the preferred strategy:

Opportunities and Constraints Workshop with Halifax Water Staff

- Input from the Halifax Water staff knowledgebase through workshops and other correspondence was invaluable for the identification of system constraints, opportunities for optimization, operational concerns, growth pressures, and previously-recommended infrastructure solutions.

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

Supply, Pumping, and Storage Desktop Analysis

- The desktop analysis identified facilities and water supply sources with insufficient capacity to meet growth demands.

Hydraulic Modelling

- The updated WaterCAD hydraulic water model was used to highlight areas with limitations or constraints within the transmission network and validate the selected servicing strategy to ensure that overall servicing needs were met.

Water Infrastructure Preferred Strategy

The Capital Program for the Water Infrastructure Preferred Strategy is included in Volume 1 Executive Summary and supports the servicing of all regions. The Capital Costs for Water Infrastructure total approximately **\$285M (in 2019 dollars)**. The program costs are evenly distributed over the planning period as best as possible, by adjusting the implementation year of projects with flexible timing.

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

Projects to Accommodate Growth

System Supply

The servicing strategy aims to ensure sufficient system supply to meet 2046 growth demands for all three systems, with consideration given to post-2046 demands. Several concepts were reviewed to assess feasibility, social implications, and economic impacts.

- i. Increase safe yield
- ii. Water conservation
- iii. New supply
- iv. System interconnections

The following capital projects are proposed to accommodate system supply needs due to growth:

- Tomahawk Supply Study
- Lucasville Road Twinning
- New Primary Supply to Sackville High and Beaver Bank Boosted
- Orchard Control Chamber Study
- Bedford-Burnside Connection
- Second Supply to Windsor Junction
- Pockwock System Extension to Bennery Lake

Peninsula Supply

There is significant proposed growth on the Halifax Peninsula (approximately 51,000 population equivalent), and the existing transmission system is insufficient to meet 2046 demands. The preferred strategy for water supply to the Peninsula is through increased Chain Control transmission main capacity using a strategically-timed upsizing approach. The individual Peninsula supply strategy projects are shown in **Executive Summary** Figure 8.

Peninsula Transmission


Several opportunities have been identified to enhance the existing spine network to accommodate growth in the Peninsula, including:

- Young Street Pocket watermain upsizing
- Quinpool Road to Young Street transmission connection
- “Closing the Loop” strategy to enhance system resiliency from Young Street area to Quinpool/Robie intersection, as small old watermains are replaced
- Three (3) critical transmission mains in poor condition are to be strategically cleaned, lined, or replaced within the next 5 years as part of the Asset Management Program
- Local distribution watermains have not been focused on under the Infrastructure Master Plan; however, the replacement and/or upsizing of these local distribution mains will continue to improve localized pressure and fire flow capacity issues

These Peninsula transmission strategy opportunities are shown in **Executive Summary** Figure 8.

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary



Executive Summary Figure 8: Peninsula Supply and Transmission Objectives and Projects

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

Hemlock Elevated Tank

A new storage facility is recommended within the Hemlock High pressure zone to support growth in the Bedford area, reduce peaking of water supply at Pockwock WSP, and improve overall system resiliency.

Aerotech Tank

The existing Aerotech Tank is currently operating at 90% of its design capacity. Proposed growth will require significantly more storage volume. A design study is recommended for storage tank replacement, as well as a review of tank location to identify opportunities for system optimization. The new storage facility should consider the proposed Fall River extension and new supply source.

Lakeside and Timberlea

The following projects are proposed to meet growth requirements in the Lakeside and Timberlea area:

- Brunello Booster Pump Upgrades
- Bayers Industrial Park Looping
- Gravity Supply to Brunello
- Dominion Crescent Watermain Upsize

Herring Cove

The previous water servicing strategy created in 2000 provided recommendations for the watermain extension along Herring Cove Road, a new reservoir, and local servicing throughout the Herring Cove area. The servicing strategy proposed in the Infrastructure Master Plan included a review of the previous water servicing strategy, and includes the following key projects:

- Twinning of Herring Cove Road watermain
- Upsize St. Michaels Avenue watermain and loop McIntosh Street watermain
- Extension of servicing along John Brackett Drive and Ketch Harbour Road (part of previous water servicing strategy) is likely to proceed

Lively (Berry Hills)

The Lively Booster was designed to meet peak domestic demands and provide fire flow capacity to the Lively subdivision. The existing capacity of the Lively Booster cannot meet the proposed 2046 growth demands, therefore future upgrades are needed. Demand monitoring is recommended as development comes online; when demands reach 80% of the existing capacity, the proposed upgrades should be implemented.

Geizer Hill

The Geizer Hill Booster was designed and constructed to meet domestic flows and provide fire flow capacity for current and future water demands. However, the existing capacity cannot meet the proposed growth demands to the 2046 planning horizon. Therefore, future upgrades are needed. Demand monitoring is recommended as development comes online; when demands reach 80% of the existing capacity, the proposed upgrades should be implemented.

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

Woodside Industrial Park

A gravity solution is recommended from the Woodlawn Intermediate transmission main to the Woodside Industrial Park, to accommodate the growth expansion. The existing Woodlawn Intermediate pressure zone HGL is adequate to service existing and future customers.

Shannon Park

Additional capacity is required within the Burnside Low pressure zone to accommodate significant growth in the Shannon Park and Wyse Road areas. It is recommended that the existing Windmill Road watermain is upsized to accommodate this growth.

Projects to Enhance System Resiliency

System resiliency is a key objective for the servicing strategy to minimize risk of loss of service, water quality issues, fire flow capacity, adaption to climate change, transmission main failure, etc. Numerous projects have been proposed in both the Pockwock and Lake Major systems that aim to enhance system resiliency.

Pockwock System

- Pockwock Lake has some redundancy available through Chain Lake emergency backup supply and will have additional redundancy through future Tomahawk Lake supply.
- Separate study for JD Kline WSP is recommended to review level of risk associated with the supply plant and the requirements to provide an adequate level of resiliency.
- Twinning of the single 60-inch transmission main servicing the Pockwock system from JD Kline WSP to provide capacity for post-2046 demands and allow the existing transmission main to be taken offline for rehabilitation.
- Twinning the single 54-inch transmission main from Lucasville Road to Hammonds Plains Road; however, this strategy should be reevaluated during the next Infrastructure Master Plan update.
- Loop watermain from Nine Mile Drive to Hammonds Plains Road to join the Pockwock transmission mains and provide redundancy to a large portion of the 48-inch transmission main, in addition to providing a second supply to Orchard Control, reducing risk for the existing single feed.
- The Peninsula transmission main from Geizer 123 to Robie does not require additional capacity to meet growth demands; however, as it is a critical piece of infrastructure and its current condition is not known, a detailed study is recommended to evaluate different strategies aimed at minimizing risk of failure.
- Twinning of the Geizer 158 transmission main is proposed, including looping of the Lacewood Drive watermain. This twinning would increase conveyance to the Geizer reservoirs, provide a second feed to Geizer 158 High zone, and enhance resiliency to Geizer-158 supported pressure zones.
- An investigation is proposed to determine the performance benefits of implementing an advanced operational system at the Robie 2 Emergency Booster (currently operated manually on an as-needed basis).
- The Chain Lake backup water supply does not provide major redundancy for the Pockwock transmission main. A comprehensive study is recommended to determine the requirements to activate Chain Lake WSP, the before and after conditions of the Pockwock system, and the overall additional resiliency that Chain Lake could provide.

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

Lake Major System

- A capacity increase is recommended from the Topsail Chamber to Burnside to improve system resiliency under the 2046 horizon. This will be achieved through a new 30-inch diameter watermain, and will allow increased conveyance to Akerley Reservoir, support the Bedford-Burnside connection, and allow for full Lake Major system resiliency.
- It is recommended that the flow capacity through Tacoma PRV is increased to eliminate the needs for significant linear upgrades. It is recommended that the PRV chamber is upgraded while the Topsail to Waverley projects are being constructed to strengthen and optimize system operations as demands increase with growth.
- The proposed Bedford-Burnside interconnection can provide over 60% of ADD supply to the Lake Major system; it is recommended that the Lyle Street Booster is designed to convey the other 40% of ADD supply, effectively providing complete redundancy to the Lake Major system in the event of catastrophic failure under 2046 demands. This redundancy would also negate the need for the Lake Lamont backup supply.

Projects to Provide System Optimization

Eastern Passage

The recommendation of the Infrastructure Master Plan is to construct a new feed to Eastern Passage from Willowdale (higher HGL) with a new PRV. This new 16-inch watermain would meet fire flow objectives, create a loop for improved resiliency, provide opportunities for improved water quality, and optimize system pressures.

Treatment Facilities

There are opportunities to connect three of the six smaller community WSP's (Miller Lake, Collins Park, and Silversands) into the main networks and decommission the existing smaller facilities. These projects are not growth-triggered, and their timing requirements are flexible.

Springfield Lake Connection

There is an opportunity to extend potable water distribution service to the Springfield Lake area via new watermain connection, through a synergy opportunity with the planned wastewater diversion along Sackville Drive. The Infrastructure Master Plan includes the service extension to Springfield Lake; a more detailed servicing study will be required to develop a specific plan for adequate customer servicing.

The extension of water service to Springfield Lake would require consultation with HRM on an extension of the water service boundary. The extension would depend on the desire of residents to receive water service as system extensions are typically paid for by the new customers who would be receiving service.

Mt. Edward Booster Fire Pump Upgrade

The capacity and compliance analysis desktop study concluded that the fire flow provided by Mt. Edward Booster is inadequate for some serviced buildings, including multiple schools. It was noted that this was a desktop review using master planning criteria and a review in greater detail should be completed using the Fire Underwriters Survey (FUS) calculation approach.

VOLUME 2: INFRASTRUCTURE MASTER PLAN

Executive Summary

Leiblin Booster Fire Pump Upgrade

The capacity and compliance analysis desktop study concluded that the fire flow provided by Leiblin Booster is inadequate for some serviced buildings, including the school. It should be noted that a fire pump capacity upgrade at the booster station is already underway.



INFRASTRUCTURE MASTER PLAN

EXECUTIVE SUMMARY VOLUME 3 WEST REGION WASTEWATER INFRASTRUCTURE

Prepared by: GM BluePlan Engineering
For: Halifax Water
October 2019



VOLUME 3: INFRASTRUCTURE MASTER PLAN

Executive Summary

VOLUME 3 – WEST REGION WASTEWATER INFRASTRUCTURE



Catchment Overview

As the West Region's servicing strategy was completed under the WRWIP, this volume has taken components of the WRWIP relating directly to the West Region. The more generic components in the WRWIP have been included in Volume 1 of the Infrastructure Master Plan.

The West Region includes the wastewater sewer sheds of Halifax, Herring Cove and Beechville, Lakeside and Timberlea (BLT). Herring Cove and BLT are separated systems while Halifax, being an older system, is combined, particularly within Halifax Peninsula. The main unique features for the West Region are in the Halifax catchment surrounding the combined areas. Several major combined sewer overflow (CSO) facilities are located at pumping stations and other locations throughout the combined network of Halifax Peninsula, and discharge to the Halifax Harbour. Flow that bypass the CSO are either conveyed by the Northwest Arm Trunk Sewer along the southern side of Halifax Peninsula, or the Fairview Cove tunnel along the north side of Halifax Peninsula, to the Halifax WWTF. Real time control (RTC) set-up restricts flows entering Young Street Pumping Station and the amount of flows pumped from Duffus Street to the WWTF.

The primary constraints identified in the West Region were the Halifax and BLT WWTFs exceeding rated capacity, bottlenecks in the trunk sewer along Fairview Cove, limited capacity to accommodate significant growth in Young Street and Spring Garden Road areas, and limitations downstream of Roaches Pond forcemain discharge. The main opportunities in the West Region are surplus capacity at Herring Cove WWTF and an upgrade to Mill Cove WWTF, which would allow for Central Region to accommodate growth, removing the need for the major diversion towards the Peninsula as previously noted in the RWWFP.

Additionally, under the Infrastructure Master Plan, components of the WRWIP were updated to align with the overall Infrastructure Master Plan process. This included outlining the revised growth in the West Region in accordance to the *Planning Data and Population Numbers* study and the Capital Program costs updated to align with 2019 dollars and include the new RDII Costing Template.

Key Supporting Studies

WET WEATHER MANAGEMENT STUDY

The Wet Weather Management Study was developed under the WRWIP for the West Region. The combined areas in Halifax Peninsula were assessed under the sewer separation and LID feasibility studies, as outlined in Volume 1. For the RDII reduction feasibility study, it should be noted that the analysis was originally completed during the WRWIP for all areas within the West Region, including combined areas in the Peninsula. As part of the Infrastructure Master Plan, only the separated systems were carried forward for RDII reduction, as sewer separation is a more appropriate option for the combined sewer areas.

The outcome of the study for Halifax are as follows:

- The sewer separation study identified Young Street, Kempt Road, upstream of Bedford Hwy and Connaught Avenue as areas that were most feasible for sewer separation
- The RDII reduction study identified Bridgeview, Clayton Park and Fairview/Fairmount (flow monitor catchments FM-3, FM-4 and FM-6) as having significant issues of RDII and providing opportunities to remove wet weather from the separate sanitary system

VOLUME 3: INFRASTRUCTURE MASTER PLAN

Executive Summary

- The study recommended that the RDII analysis was refined as a component of the overall strategy in the WRWIP, along with sewer separation

Adjustment to the RDII reduction areas made in the strategy, was to include only the Fairview area of FM-6 in the RDII reduction, this was done in recognition of Fairview being an old system and being located near other areas with high RDII.

ADDITIONAL STUDIES

In addition to the Supporting Studies in Volume 1, the other studies used to guide the preferred servicing strategies are as follows:

- Local Wastewater Servicing Capacity Analysis (LoWSCA)
- Northwest Arm Sewer Lining and Reconfiguration of Armdale Pumping Station
- Rehabilitation of Fairfield Holding Tank

West Region Strategy Development

The PCSWMM models and WRWIP growth numbers were used to complete the capacity and compliance analysis for the West Region under both existing and growth scenarios, and then assisted in developing and testing multiple servicing strategies and selecting the preferred strategy. Climate change was not considered in the West Region strategy as it is a new component under the Infrastructure Master Plan.

Common Projects in the strategies included: decommission BLT WWTF and divert flows, upgrades to Young Street and Armdale Pumping Stations, sewer separation in Young Street and Spring Garden LoWSCA areas and upstream of Kempt Road CSO, re-commission the Fairfield Holding Tank, North Street flow split configuration and RDII reduction.

Once the Common Projects were confirmed a range of serving strategies were assessed. In the West Region four (4) overarching servicing strategy alternatives were considered, including:

- One strategy that conveys all flows to Halifax WWTF (Strategy 1), including BLT flows.
- Two strategies with flow diversion to Herring Cove WWTF (Strategy 2a – 2b), to reduce upgrades to Halifax WWTF. Strategy 2a includes the BLT diversion to Herring Cove WWTF and reduced upgrades to Halifax WWTF. Strategy 2b include the BLT and Armdale diversion to Herring Cove WWTF to remove upgrades to Halifax WWTF but requires an expansion at Herring Cove WWTF.
- One strategy to protect the peninsula from upgrades (Strategy 3), through a major Highway 102 diversion and the BLT diversion to Herring Cove WWTF. With all flows diverted to Herring Cove WWTF, significant expansions at that facility are required.

West Region Preferred Strategy

The preferred strategy for West region was Strategy 2a which is detailed in Executive Summary Figure 9: Preferred Servicing Strategy for the West Region. Strategy 2a was selected mainly due to providing greater flexibility, utilizes existing capacity at Herring Cove WWTF, ‘buys time’ on the Halifax WWTF upgrade, performing to an acceptable level of service, and being a cost-effective solution. In addition to selecting the preferred approach, two component evaluations were considered – Roaches Pond Pumping Station alternatives and determining the location of Crown Drive Pumping Station. The Roches Pond Pumping Station alternatives considered the pros and cons of removing the pumping station and replacing with a gravity pipe. Due to the expected difficulties, level of disruption and costs it was not recommended to proceed, instead more detailed investigation and data collection is recommended to properly identify the

VOLUME 3: INFRASTRUCTURE MASTER PLAN

Executive Summary


best operational strategy for this facility. The preferred strategy (2a) included a new pumping station within the Crown Drive and Northwest Arm Drive area. An exercise was completed to evaluate various locations and select a preferred location for the proposed Crown Drive Pumping Station.

The Capital Program for the West Region is included in Volume 1 Executive Summary. The capital cost for the WRWIP were updated under the Infrastructure Master Plan to be in 2019 dollars, including the updated RDII Costing Template and WRWIP Concept Design updates. This led to an increase in capital costs from **\$165M (2018 dollars)** to **\$186M (2019 dollars)**.

The scope of work for the WRWIP project included conceptual design for all projects that are required within a 10-year horizon. The WRWIP preferred strategy Concept Design Projects were:

- New Fairview Cove Trunk Sewer
- New Crown Drive Pumping Station
- New BLT Pumping Station and Decommissioning of BLT WWTF
- Sewer Separation
- Young Street Pumping Station Upgrades

Refer to the WRWIP for the Conceptual Designs of the above projects.



Executive Summary Figure 9: Preferred Servicing Strategy for the West Region



INFRASTRUCTURE MASTER PLAN

EXECUTIVE SUMMARY VOLUME 4 CENTRAL REGION WASTEWATER INFRASTRUCTURE

Prepared by: GM BluePlan Engineering
For: Halifax Water
October 2019



VOLUME 4: INFRASTRUCTURE MASTER PLAN

Executive Summary

VOLUME 4 – CENTRAL REGION WASTEWATER INFRASTRUCTURE



Catchment Overview

Central Region servicing strategy was completed under the Infrastructure Master Plan, following the same process as the West Region under the WRWIP. The Central Region included Mill Cove WWTF, Springfield Lake WWTF, and Aerotech WWTF sewersheds.

The Springfield Lake catchment was not originally included in study area, however in recognition of the potential future benefits of diverting flows from Springfield Lake to Mill Cove WWTF, it was added to the Central Region study area.

The Aerotech wastewater collection system has been considered in the Infrastructure Master Plan; however, the only regional infrastructure features in the area is the Aerotech wastewater treatment facility itself. A significant facility upgrade was completed in 2016 on the WWTF, which included a full assessment of existing flows and future growth to evaluate capacity expansion requirements. As these upgrades have already been completed, the Aerotech WWTF system is not a primary focus area within the Infrastructure Master Plan.

The Mill Cove wastewater collection system is a separated system that covers the Sackville and Bedford areas and contains several key features that affect flow conveyance to the treatment facility.

- Main conveyance feature in Sackville is the Sackville trunk sewer, which drains by gravity to Fish Hatchery Pumping Station
- Fish Hatchery PS is located at the northernmost tip of the Bedford Basin and pumps all flow from the Sackville trunk sewer to Mill Cove WWTF
- Wastewater flows from the Bedford area converge via multiple smaller trunk sewers at the Bedford Pumping Station, located directly southwest of the Mill Cove WWTF
- Local wastewater network along Shore Drive that conveys wastewater flows directly to Mill Cove WWTF via Bedford Yacht Club Pumping Station.
- The Mill Cove Wastewater Treatment Facility is located near the Bedford Basin, and planning for major expansion to this treatment facility is currently underway

The Springfield Lake wastewater collection system is a separated system that surrounds Springfield Lake. Flows are conveyed to the Springfield WWTF through a chain of pumping stations due to the hilly topography around the lake. There is a localized low pressure system in the low-lying Falcon Crest Court peninsula catchment, that conveys flows to higher elevation without pumping.

Key Supporting Studies

WET WEATHER MANAGEMENT STUDY

As Mill Cove sewersheds is a separated system the only Wet Weather Flow Management study incorporated into the strategy was the RDII Reduction Analysis. The Mill Cove flow monitoring catchments FMZ02 (Glen Moir), FMZ03 (Millview), FMZ10 (Bedford Common), and FMZ07 and FMZ40 (Lower Sackville), were highlighted as having significant RDII issues and provide an opportunity to remove wet weather from the separated sewer system.

VOLUME 4: INFRASTRUCTURE MASTER PLAN

Executive Summary

ADDITIONAL STUDIES

In addition to the Supporting Studies in Volume 1, the other studies used to guide the preferred servicing strategies are as follows:

- The National Disaster Mitigation Program (NDMP) - identify thirty (30) key areas in HRM that are prone to frequent flooding during heavy rainfall events
- Fish Hatchery Force main Inspection Report

Central Region Strategy Development

The InfoWorks ICM model for the Central Region was used to complete the capacity and compliance analysis under both existing and growth scenarios, and then assist in developing and testing multiple servicing strategies and selecting the preferred strategy. Climate change was considered in the strategies through applying a climate change factor to the rainfall simulations as outlined in the Climate Change Study.

Common Projects in Central Region included upgrades to Mill Cove WWTF, decommission of Springfield WWTF and connection to Mill Cove sewershed, upgrades to Majestic Avenue, Beaver Bank #3 Pumping Stations, local pipe upgrades and the RDII reduction.

Once the Common Projects were confirmed a range of serving strategies were assessed. In Central Region there were six (6) overarching servicing strategy alternatives were considered, including:

- Two conveyance strategies (Strategy 1a – 1b) based on upsizes to the Sackville trunk with/without enhanced RDII to reduce catchment flows.
- Three storage strategies (Strategy 2a – 2c) based on installing storage tanks along the Sackville trunk, with/without upgrade to the Sackville trunk. Variations between strategies included tanks sized and applying enhanced RDII to reduce catchment flows.
- Two tunnel strategies (Strategy 3a – 3b) aim to decommission Fish Hatchery Pumping Station via the construction of a new tunnel to Mill Cove WWTF. Strategy 3a has the tunnel starting from Fish Hatchery PS and includes trench upgrades to the Sackville trunk upstream of Fish Hatchery. Strategy 3b extends the tunnel up to the Bedford Bypass crossing to remove trench upgrades.

Central Region Preferred Strategy

The preferred strategy for Central was Strategy 2c which is detailed in Executive Summary Figure 10. Strategy 2c was selected mainly due to providing future flexibility, maximizes the use of existing assets, performing to an acceptable level of service, and being a cost-effective solution. In addition to selecting the preferred strategy for Central a component evaluation was done on RDII reduction rates and the impact on infrastructure requirements as RDII reduction directly affects tank sizing.


The Capital Program for the Central Region is included in Volume 1 Executive Summary. The Capital Costs for Central Region total **\$163M (2019\$)**. The program is front heavy due to the cost associated with the upgrades to Mill Cove WWTF and the RDII reduction project required at the start of the project horizon.

The scope of work for the Infrastructure Master Plan included conceptual design for certain projects which are complex in feasibility and/or constructability. The projects selected for Conceptual Design were:

- Springfield Lake WWTF decommissioning and diversion to Mill Cove WWTF wastewater system
- Fish Hatchery PS forcemain upsizing (450mm to 675mm diameter)

VOLUME 4: INFRASTRUCTURE MASTER PLAN

Executive Summary



Executive Summary Figure 10: Preferred Servicing Strategy for the Central Region



INFRASTRUCTURE MASTER PLAN

EXECUTIVE SUMMARY VOLUME 5 EAST REGION WASTEWATER INFRASTRUCTURE

Prepared by: GM BluePlan Engineering
For: Halifax Water
October 2019



VOLUME 5: INFRASTRUCTURE MASTER PLAN

Executive Summary

VOLUME 5 – EAST REGION WASTEWATER INFRASTRUCTURE



Catchment Overview

East Region servicing strategy was completed under the Infrastructure Master Plan, following the same process as the West Region under the WRWIP. The East Region includes two wastewater sewersheds Eastern Passage and Dartmouth, and the sewersheds contain unique components and constraints with them.

The Eastern Passage is a separated system that covers the Cole Harbour and Eastern Passage areas. The main unique feature in the catchment is the gravity pressure sewer that connects the Cole Harbour area to the Eastern Passage treatment facility. Due to existing capacity constraints at the gravity pressure sewer there is a real time control (RTC) set-up that restricts flows from the main pumping station in Cole Harbour, Bissett Lake Pumping Station, to the surge tank at the start of the gravity pressure sewer. The main issues identified with the gravity pressure sewer include: flow restrictions causing spills at Bissett Lake, the condition of the asset affecting conveyance, odour control requirement and ongoing operational and maintenance concerns. Additional concerns in the catchment are Memorial Drive, Beaver Crescent and Quigley's Corner Pumping Stations being under capacity, and Caldwell Crescent and Bissett Lake Pumping Stations being impacted by growth. The main opportunity in Eastern Passage is the newly upgraded WWTF. The treatment plant is located near Halifax Harbour and was expanded in 2014 to accommodate projected population growth in the serviceable boundary areas.

Dartmouth sewershed is an older system, largely comprised of combined systems within the Circumferential Highway, an area referred to as the Regional Centre. Outside the Regional Centre of the Dartmouth sewershed, it is considered a separated system. The combined system in Dartmouth includes flows from Albro Lake Watershed, Maynard Lake and the Clement Street Wetland located in the Southdale area, which leads to high peak flows and volumes being conveyed under storm events, causing capacity constraints on the system and combined sewer overflow (CSO) spills. Significant growth in the Dartmouth catchment will worsen conditions and lead to additional treatment capacity required at Dartmouth WWTF and increase flooding on Wyse Road and by Old Ferry Road CSO. In the separated areas upstream, there are existing constraints made worse by growth including SSO spills at Valleyford Holding Tank, Anderson Pumping Station and 111 Waverley Road Pumping Station.

Key Supporting Studies

WET WEATHER MANAGEMENT STUDY

It is evident from the background review and feasibility study outputs that there is significant potential for sewer separation within the combined system in Dartmouth and RDII reduction in the separated areas. The outcome of the wet weather management study for Dartmouth are as follows, and have been included in the strategy:

- The sewer separation study identified Jamieson Street, Wyse Road, Nantucket Avenue, Thistle Street, Rose Street and Canal Street as areas that were most feasible for sewer separation
- The Dartmouth flow monitoring catchments FMZ27 (Ellenvale) and FMZ45 (Woodside) were highlighted as having significant RDII issues and provide an opportunity to remove wet weather from the separated sewer system

VOLUME 5: INFRASTRUCTURE MASTER PLAN

Executive Summary

As Eastern Passage sewershed is a separated system the only Wet Weather Flow Management strategy incorporated into the strategy was the RDII Reduction Analysis. The predefined flow monitor target areas were FMZ24 (Loon Lake), FLM23 and FMZ81 (Colby Village) and FMZ37 (Eastern Passage). All of the target areas were included with the exception of FMZ81, as the RDII reduction strategy did not alleviate flow restrictions observed along Colby Road making RDII reduction not the most cost-effective strategy.

ADDITIONAL STUDIES

In addition to the Supporting Studies in Volume 1, the other studies used to guide the preferred servicing strategies are as follows:

Dartmouth:

- Local Wastewater Servicing Capacity Analysis (LoWSCA)
- Gravity Stormwater Sewer from Little Albro Lake to Jamieson Street Pumping Station, Preliminary Design Report
- Port Wallace Master Plan Infrastructure Study
- National Disaster Mitigation Program (NDMP)

Eastern Passage:

- Eastern Passage WW Management Plan
- Quigley's Corner Preliminary Design Report
- Cow Bay Road Draining Investigation – Hydrologic and Hydraulic Analysis
- National Disaster Mitigation Program (NDMP)

Eastern Passage Strategy Development

The InfoWorks ICM models for the East Region were used to complete the capacity and compliance analysis under both existing and growth scenarios, and then assist in developing and testing multiple servicing strategies and the preferred strategy. Climate change was considered in the strategies through applying a climate change factor to the rainfall simulations and through looking at the impact of sea level rise on CSOs discharging to the Halifax Harbour in Dartmouth and SSOs in Eastern Passage.

Common Projects in Eastern Passage included upgrades to Memorial Drive, Beaver Crescent and Quigley's Corner Pumping Stations, local pipe upgrades and the RDII reduction.

Once the Common Projects were confirmed a range of servicing strategies were assessed. In Eastern Passage ten (10) overarching servicing strategy alternatives were considered, including:

- Four conveyance strategies (Strategy 1a – 1d) based on installing a new gravity pressure sewer with pump out stations to improve conveyance and odour issues. Strategy 1d is a sub-option to all strategies where an alternate route for the gravity pressure sewer crossing under the Shearwater Airport is considered. Variation between Strategies 1a-1c included different pipe sizes and the use of enhanced RDII to reduce catchment flows.
- Four storage strategies (Strategy 2a – 2d) based on installing storage tanks, with/without upgrade to the gravity pressure sewer. Limited upgrades to the gravity pressure sewer meant the Strategies did not address odour issues. Variations between strategies included tanks sized to different level of services and applying enhanced RDII to reduce catchment flows.
- Two tunnel strategies (Strategy 3a – 3b) to remove the gravity pressure sewer. Strategy 3a installs a gravity tunnel from Bissett Lake Pumping Station to just upstream of Eastern Passage WWTF

VOLUME 5: INFRASTRUCTURE MASTER PLAN

Executive Summary

and Strategy 3b is shortened alignment from the surge tank to the WWTF, including connections by Morris Lake to service growth in the area.


Eastern Passage Preferred Strategy

The preferred strategy for Eastern Passage was Strategy 1c which is detailed in Executive Summary Figure 11. Strategy 1c was selected mainly due to addressing the operations and maintenance issues surrounding the gravity pressure sewer, performing to an acceptable level of service, and being a cost-effective solution. The selected gravity pressure sewer alignment travels around the Shearwater Airport, forming an indirect path. It was recommended to revisit the cost saving of tunneling under the airport throughout the design stages. In recognition that additional assessment of the gravity pressure sewer could improve the design, it was included as one of the Conceptual Designs included under the Infrastructure Master Plan.

The Capital Program for Eastern Passage is included in Volume 1 Executive Summary. The program is front-heavy due to the cost associated with the gravity pressure sewer replacement which is required at the start of the project horizon.

VOLUME 5: INFRASTRUCTURE MASTER PLAN

Executive Summary



VOLUME 5: INFRASTRUCTURE MASTER PLAN

Executive Summary

Dartmouth Strategy Development

Common Projects in Dartmouth included separation of Lake Albro, Maynard lake and the Clement Street Wetland, sewer separation in Wyse Road and Canal Street LoWSCA areas, Rose Street and Thistle Street, flow diversions in the Lyle Street and King Street CSO catchments, upgrades to Anderson Pumping Station, local pipe upgrades, RDII reduction, additional flow monitoring and a CSO Management Plan to improve CSO performance.

Once the Common Projects were confirmed a range of serving strategies were assessed. In Dartmouth seven (7) overarching servicing strategy alternatives were considered, including:

- Four conveyance strategies (Strategy 1a – 1d) include upgrades to existing alignment, reducing upgrades required through enhance RDII reduction and new conveyance alignments. Strategy 1d was a sub-option to all strategies with a diversion of Dartmouth flows to Eastern Passage WWTF to reduce the upgrades required at Dartmouth WWTF.
- Two storage strategies (Strategy 2a – 2b) consider installing storage tanks over conveyance upgrades to. Variations between strategies included tanks with/without applying enhanced RDII to reduce catchment flows.
- One tunnel strategies (Strategy 3) explores a tunnel option to eliminate CSO spills. The tunnel option is a cost on top of the other strategies, that address inner system constraints, making this strategy an expensive addition to the other strategies.

Dartmouth Preferred Strategy


The preferred strategy for Dartmouth was Strategy 1c which is detailed in Executive Summary Figure 12. Strategy 1c was selected mainly due to providing future flexibility, balancing flows across system trunks, performing to an acceptable level of service, and being a cost-effective solution. In addition to selecting the preferred approach for inner system constraints two component evaluations were also considered - increasing the bypass rates at two CSOs and a flow diversion from Dartmouth to Eastern Passage WWTF (Strategy 1d). The CSO assessed were Cuisack and Wallace and based on the growth upstream the bypass rates were adjusted to match the CSO design rate of 4x average dry weather flow (ADWF). The rates were able to be increased due to the extent of sewer separation in the catchment and offsetting spill rates at other CSOs.

The flow diversions from Dartmouth to Eastern Passage WWTF was considered due to additional space for treatment being reserved at Eastern Passage WWTF, allowing for the rated capacity to be increased at a lower cost than upgrading Dartmouth WWTF. Upgrades to Dartmouth WWTF are expected to be high as the WWTF would likely require a system overhaul to accommodate growth while considering higher treatment standards and improved processes. The flow diversion therefore showed significant cost savings and 'buys time' on the upgrades to Dartmouth. As the diversion did not completely remove the need for increase capacity at Dartmouth WWTF a cost to upgrade Dartmouth WWTF by 3MLD was included in the strategy. The projects within Dartmouth that were brought forward to the Infrastructure Master Plan Concept Designs, were the separation of Lake Albro, Maynard lake and Clement Street Wetland, as sewer separation became a major component in the Dartmouth strategy and the projects showed potential for improvements to the designs.


The Capital Program for the East Region is included in Volume 1 Executive Summary. The Capital Costs for Eastern Passage total **\$49M** and for Dartmouth are **\$104M (2019\$)** totaling **\$153M** for the East Region.

VOLUME 5: INFRASTRUCTURE MASTER PLAN

Executive Summary



Executive Summary Figure 12: Preferred Servicing Strategy for Dartmouth



Executive Summary Figure 13: Preferred Servicing Strategy for Dartmouth



B

HALIFAX WATER
2019 INTEGRATED RESOURCE PLAN


APPENDIX B.2

COMPLIANCE PLAN

Compliance Plan

2019

EXECUTIVE SUMMARY



Contents

1	Introduction	2
2	Wastewater Compliance	2
2.1	Wastewater Treatment Facilities	3
2.2	Wastewater Collection System	4
3	Water Compliance	5
3.1	Water Supply Plants	6
3.2	Transmission and Distribution System	6
4	Integration with the Integrated Resource Plan	7

1 Introduction

The overall goal of the Compliance Plan is to use the information Halifax Water has available to create a path forward to maintain or achieve compliance for our wastewater, water and stormwater infrastructure systems over the next 30 years. The Engineering and IS, Water Services, Wastewater and Stormwater Services and Regulatory Services departments all contributed to the development of the Compliance Plan. The Compliance Plan highlights the current state of compliance at our wastewater treatment facilities and water supply plants as well as examines future compliance requirements. Additional sections discuss the wastewater collection systems, sanitary and combined sewer overflows and water distribution systems including water storage reservoirs.

The Compliance Plan was developed based on the best available data at the time of preparation. The information presented in the compliance plan is only as accurate as the data that is collected. Ensuring the collection of quality data through proper quality assurance and quality control practices is critical to developing accurate long-term plans.

Past studies that support the 2019 Compliance Plan are listed below:

- Integrated Resource Plan (IRP, 2012)
- Infrastructure Master Plan (2019)
- West Region Wastewater Infrastructure Plan (WRWIP, 2017)
- 5-year Capital Program and project table – *outlines known projects occurring over the next 5 years, including compliance related projects*
- Asset Management Plans (2018)

The Compliance Plan, the 2019 Infrastructure Master Plan and the 2018/2019 Asset Management Plans, will be used to form part of the 2019 Integrated Resource Plan (IRP), covering the three drivers behind infrastructure planning (Growth, Asset Renewal and Compliance).

2 Wastewater Compliance

Wastewater management in Canada is governed federally, provincially and at the municipal level. Legislation is issued federally to stipulate minimum standards for wastewater effluent, while provincial governments are responsible for issuing permits or licenses to wastewater treatment facilities to construct and operate under their regulatory framework. Permits are typically site specific and may require increased stringency based on provincial legislation to improve human health and ensure environmental protection based on population density and assimilative capacity of the receiving waters.

Halifax Water has been consistently working toward achieving the provincial level of wastewater treatment as stipulated by Nova Scotia Environment (NSE) permits and the Federal Wastewater System Effluent Regulations (WSER). Historically, NSE has set compliance standards for each wastewater treatment facility (WWTF) by issuing an Approval for Operation which sets the effluent limits and the Canada-wide Strategy for the Management of Municipal Wastewater Effluent (CSMMW) provided national standards for combined sewer overflows (CSO) and sanitary sewer overflows (SSO). June of 2012,

the WSER was enacted which set national standards for WWTF effluent discharge and CSO and SSO standards.

Since the introduction of the federal WSER standards, NSE has been reviewing and renewing Halifax Water's operating permits with steady increases in compliance and reporting requirements.

To understand the current level of compliance and actions required for remaining compliant, several initiatives have recently been completed or are underway. Current compliance initiatives are as follows:

- Compliance Monitoring and Reporting through the Regulatory Services Department
- Engaging Dalhousie University in compliance research
- Adopting the Environmental Management System (EMS)
- Environmental Risk Assessments (ERA)
- WSER Transitional Authorization

2.1 Wastewater Treatment Facilities

Halifax Water's wastewater treatment facilities provide varying levels of treatment ranging from chemically enhanced primary to tertiary and have a broad range of average daily flow (ADF) capacities. Halifax Water owns and operates fourteen wastewater treatment facilities (Table 1). Five of the wastewater treatment facilities discharge to marine receiving environments whereas the remainder discharge to a variety of small freshwater lakes or streams.

Table 1: Wastewater Treatment Facility Summary

Facility	Treatment Level	Treatment Process	Type of Receiving Water
Halifax	Enhanced Primary	High rate solids contact clarifier w/ UV disinfection and sludge dewatering	Marine
Dartmouth	Enhanced Primary	High rate solids contact clarifier w/ UV disinfection and sludge dewatering	Marine
Herring Cove	Enhanced Primary	High rate solids contact clarifier w/ UV disinfection and sludge dewatering	Marine
Eastern Passage	Secondary	Conventional activated sludge w/ UV and sludge dewatering	Marine
Mill Cove	Secondary	Pure oxygen activated sludge w/ UV disinfection, anaerobic digestion and sludge dewatering	Marine
Uplands	Secondary	Trickling filter, clarification w/ UV and wetland polishing	fresh water
Middle Musquodoboit	Secondary	Rotating biological contactor w/ UV disinfection and aerated polishing pond	fresh water
Springfield Lake	Secondary	Enhanced aeration activated sludge w/ UV	fresh water
Timberlea (BLT)	Secondary	Rotating biological contactor w/ Sodium hypochlorite	fresh water

North Preston	Advanced Treatment	Sequencing batch reactor w/ UV and engineered wetland polishing	fresh water
Frame	Advanced Treatment	Membrane bioreactor (MBR) w/ UV	fresh water
Wellington	Advanced Treatment	Conventional activated sludge w/ UV and reed bed	fresh water
Fall River	Advanced Treatment	Conventional activated sludge w/ post filtration and UV	fresh water
Aerotech	Advanced Treatment	Membrane bioreactor (MBR) w/ UV and sludge dewatering	fresh water

The Compliance Plan reviews each facility, summarizes the data from 2015 to 2019 and provides a short and near-term corrective action plan where applicable. Other compliance related project may be generated through the 2019 Infrastructure Master Plan and therefore the costs outlined below may be adjusted.

Table 2: Short Term WWTF Expenditures

Facility	Total Capital Costs (\$2019)
Halifax WWTF	\$9,034,500
Dartmouth WWTF	\$7,900,000
Herring Cove WWTF	\$4,750,000
Lakeside-Timberlea WWTF	\$25,000
Mill Cove WWTF	\$70,000,000

Table 3: Long Term WWTF Expenditures

Facility	Total Capital Costs (\$2019)
Halifax WWTF – Upgrades to meet WSER	\$160,750,000
Dartmouth WWTF - Upgrades to meet WSER	\$87,400,000
Herring Cove WWTF	\$38,200,000

2.2 Wastewater Collection System

Along with WWTFs, Halifax Water also operates the wastewater collection system. This includes wastewater pipe, forcemains, pump stations and combined sewer overflows (CSOs). The following programs support the operation of the operation of the wastewater collection system from a compliance perspective.

Table 4: Collection System Annual Program Expenditures

Project	Estimated Cost
Wet Weather Management Program	\$250,000 annually
Inflow and Infiltration Reduction Program	\$25,000 annually
Corporate Flow monitoring Program	\$1,700,000 annually

3 Water Compliance

In Nova Scotia, Drinking Water treatment and delivery is regulated by Nova Scotia Environment through Approvals issued under the Environment Act. Approvals are issued for a period of 10 years. It is anticipated that new Approvals will be issued for all water supplies in Nova Scotia in 2019. The water supply plants are to be operated in accordance with the terms and conditions of the Approval.

Health Canada publishes the Guidelines for Canadian Drinking Water Quality. The guidelines can be published as either Maximum Acceptable Concentrations (MAC's) which are health related parameters; Aesthetic Objectives (AO's) and Operational Objectives. Drinking Water Approvals in Nova Scotia require that all MAC's must be achieved. While achievement of AO's is not required, many of them must be monitored and reported on. Any new or revised MAC published during the life of an Approval is deemed to form part of the Approval by NSE.

In Nova Scotia, there is no formal standard for water supply plant process wastewater discharge quality. There are no specific technology requirements for treatment and discharge limits are set on a site-specific basis by NSE when issuing the Approval.

Halifax Water has consistently met the requirements of provincial Approvals and regulations for its major drinking water supplies. Halifax Water does not anticipate any changes to regulations or standards that would challenge our ability to maintain compliance. There are challenges due to changes in source water quality and aging infrastructure that will challenge our ability to achieve compliance and these are discussed for each facility.

Over the last five years, Halifax Water has experienced changes in source water quality. These changes will impact the ability of our large treatment plants to maintain compliance and/or will reduce their effective capacity as filter runs become shorter and other process components are impaired.

There are two phenomenon that are currently being experienced which are working to have this effect; climate change and lake recovery. In response, Halifax Water has made the study of lake recovery and its treatment challenges two of four themes in its most recent water quality master plan and the NSERC Industrial Research Chair sponsored at Dalhousie University. The chairholder, Dr. Graham Gagnon, will be directing research into understanding lake recovery for the duration of the current term, ending in 2022.

3.1 Water Supply Plants

Halifax Water owns and operates three large water supply plants (WSP) and six small community water supply plants. The WSPs provide an average day demand of 329,616 m³/day of drinking water serving approximately 360,000 people. The water supply plants use different treatment technologies depending on the source water quality and the size of the facility, refer to Table 5 for a summary.

Table 5: Treatment Technology by Water Supply Plant

Treatment Technology	Water Supply Plant							
	JD Kline	Lake Major	Bennery Lake	Collins Park	Five Island	Middle Musq.	Silver Sands	Bomont
Direct dual media filtration	X							
Sedimentation with multi-media filtration		X	X					
Disinfection (gas chlorine)	X	X						
Disinfection (sodium hypochlorite)			X		X		X	
Disinfection (ultraviolet & sodium hypochlorite)				X		X		X
Ultrafiltration				X		X		X
Nanofiltration				X		X		
Ion exchange								X
Iron/manganese removal (green sand filtration)							X	
Air Stripping (removal of natural radionuclides)					X			

Table 6: WSP Expenditures

Facility	Total Capital Costs (\$2019)
JD Kline WSP – Phase 1	\$32,660,000
JD Kline WSP – Phase 2	\$25,440,000
Lake Major WSP – Phase 1	\$31,163,000
Lake Major WSP – Phase 2	\$16,960,000

3.2 Transmission and Distribution System

Regulatory requirements related to the operation of the transmission and distribution system include the following:

- Free chlorine residual of 0.20 mg/L at all location in the distribution system at all times.

- Distribution system turbidity of < 5 NTU.
- Total Trihalomethanes < 100 ug/L based on a locational running annual average (LRAA)
- Haloacetic Acids (5), <80 ug/L based on LRAA.
- Continuous chlorine residual monitoring on the outlet of all storage facilities.
- Provide water that is not corrosive to lead.

Halifax Water generally meets its free chlorine residual requirements. There are a small number of sampling locations where meeting the chlorine residual requirements is challenging, particularly in summer. Halifax Water is required to respond to all low chlorine residuals. The response may include increasing the residual at the treatment plant or flushing the distribution system. Also, Halifax Water has seven rechlorination facilities which are used to supplement distribution chlorine residuals.

4 Integration with the Integrated Resource Plan

Compliance is one of the three drivers for the IRP. The compliance program including costs, driver allocation and timing will be reviewed through the integration process for the IRP. The final compliance program in the IRP may differ from what is contained in the Compliance Plan due to integration. The Compliance Plan will be updated on a five year cycle to support the future IRP updates.



B

HALIFAX WATER
2019 INTEGRATED RESOURCE PLAN

APPENDIX B.3

ASSET MANAGEMENT PLAN

Asset Management Plan

2018/19



Prepared by Halifax Water
Staff July 2019

**STRAIGHT from
the SOURCE**

 **Halifax Water**

This page intentionally left blank

Sign-offs

This document has been reviewed and accepted by:

Jamie Hannam, MBA, P.Eng.
Director, Engineering & Information Services

Table of Contents

PREFACE.....	3
HALIFAX WATER ASSET MANAGEMENT PROGRAM.....	4
LEADING PRACTICE FOR ASSET MANAGEMENT PLANS	5
HALIFAX WATER'S ASSET MANAGEMENT PLAN	8
State of the Infrastructure	8
Levels of Service	9
Asset Investment Strategies.....	10
FINANCING STRATEGY.....	15
ASSET MANAGEMENT PLAN IMPROVEMENTS.....	17

List of Figures

Figure 1 - Guiding Asset Management Questions	4
Figure 2 - CIRC Report Card.....	6
Figure 3 - Typical Asset Management Planning Cycle.....	7
Figure 4 - Asset Classes for Halifax Water's AMP	8
Figure 5 - Typical Relationship of Asset Condition Over Time and Asset Intervention Strategies	10
Figure 6 - AMP Statistics	12
Figure 7 - Reinvestment Rates	16
Figure 8 - Evolution from Data to Knowledge.....	19

List of Tables

Table 1 - Condition Grade Definitions.....	9
Table 2 - Typical Lifecycle Activities	11
Table 3 - Summary State of Infrastructure Observations	13
Table 4 - Strategic Asset Management Integration	14
Table 5 - Asset Management Plan and Program Improvements.....	17

PREFACE

The Asset Management Plan (AMP) provides a summary of how a municipality or utility manages its assets over a defined time period (e.g. annually). In some provincial jurisdictions in Canada, AMPs must be completed in order for municipalities to be eligible for federal and provincial infrastructure funding. While not yet a requirement in Nova Scotia, indications across Canada are moving towards AMPs as a basis for infrastructure funding.

Regardless of funding eligibility, an AMP acts as a report card on the state of the utility's infrastructure. It lays out the current status of the organization's assets, discusses levels of service the assets provide, what interventions are routinely undertaken to keep the assets providing service, and the financing approach to allow for implementing planned actions and improvements.

A key aspect of an AMP is its relationship to corporate goals – there should be a clear connection between Halifax Water's mission, vision, and values and the infrastructure that enables the services to be provided. The AMP will also show connections with other corporate programs where appropriate (e.g. Wet Weather Management Program, Water Loss Control Program, infrastructure master planning).

Halifax Water Mission, Vision, and Values

Halifax Water's mission is "**To provide world class services for our customers and our environment**" and this is to be accomplished through our vision that states:

- We will provide our customers with high quality water, wastewater, and stormwater services.
- Through adoption of best practices, we will place the highest value on public health, customer service, fiscal responsibility, workplace safety and security, asset management, regulatory compliance, and stewardship of the environment.
- We will fully engage employees through teamwork, innovation, and professional development.

To achieve the mission and vision, Halifax Water's values promote a culture that:

- Engages employees, partners and stakeholders in achieving success;
- Encourages openness and transparency;
- Demonstrates individual and corporate accountability for results;
- Fosters innovation and progressive thinking;
- Respects diverse ideas, opinions and people;
- Is committed to service excellence; and
- Nurtures leadership at all levels.

HALIFAX WATER ASSET MANAGEMENT PROGRAM

To ensure service delivery to ratepayers, Halifax Water has been carrying out asset management (AM) practices for decades simply through good utility management. In 2011, the utility underwent an asset management program assessment to identify where along the formal AM maturity spectrum the Halifax Water program was situated. Following the assessment, a number of implementation tasks were identified to fill information gaps and move the program along the spectrum.

Halifax Water's Asset Management Policy

Halifax Water's asset management policy examines how corporate objectives are supported through the organization's goals, commitment, and expectations for asset management. The policy presents the broader intent of the asset management program and lists principles and opportunities for corporate integration including:

- Maintain and manage infrastructure assets at defined levels to support public and environmental safety, community well-being, and provide sustainable and affordable water, wastewater and stormwater services.
- Monitor standards and service levels to ensure corporate goals and objectives are met.
- Develop and maintain asset inventories of all infrastructures.
- Establish infrastructure replacement strategies through the use of full life cycle costing principles.
- Plan appropriate levels of maintenance of assets to meet service levels and to extend their useful life.
- Plan for and provide stable long term funding to replace, renew and/or decommission infrastructure assets.
- Consider and integrate, where appropriate, asset management in other corporate plans.
- Provide regular reports on the status and performance of the asset management policy.

Asset Management Foundation

An asset management program works to answer fundamental questions (refer to Figure 1) about an organization's assets including:

- What do we own?
- Where is it located?
- What condition is it in?
- What are the service levels?
- How much is it worth?
- When does it need to be replaced?
- What is the right balance of capital versus maintenance effort?




Figure 2 - Guiding Asset Management Questions

Future Program Considerations

The asset management foundational questions in the previous section are intended to act as a minimum requirement for the AM program. In reality, Halifax Water would benefit from incorporating several other factors or considerations into the program. Initially these factors would include:

Risk – establishing a solid risk assessment and management process for asset management is essential to assisting with prioritizing where funds should be spent. Assessing the factors of assets with the highest criticality to the organization, highest probability of failure, and greatest consequence of failure (impact to the organization) must be incorporated into a risk-based prioritization strategy.

Performance – another factor in prioritizing where Halifax Water determines to spend its funds is asset performance. Is the asset performing as intended or designed? This may relate to a capacity constraint or a capability assessment of the asset – can it do what it was supposed to do? Are we expecting the asset to perform more or less than what it was designed for? What are the implications to operational practices and costs and system integrity?

Climate resilience - Halifax Water will be commencing a project to assess vulnerability to climate change on an asset class basis. The program will have a phased implementation and outcomes will be brought into the AMP. Climate resilience and impacts to existing assets may result in climate-related infrastructure programs (e.g. addressing submerged outfalls).

As the AM program continues to mature, there will be other factors that must be introduced. Asset Management Implementation Teams (AMITs) have been established with representation from engineering, operations, and asset management as a minimum. Where appropriate based on the recommended work plans, staff from other departments will be engaged. Through the AMITs and information provided from other initiatives, emerging factors can be built into the program.

LEADING PRACTICE FOR ASSET MANAGEMENT PLANS

Alignment of Corporate Direction and AMP

The Institute of Asset Management (IAM) – a leading association that advocates for asset management practices – encourages organizations to create alignment or “line of sight” between an organization’s strategic direction and the asset management activities performed by its staff. Corporate alignment connects the organization’s mission, vision and values with the asset management policy and program. The alignment also allows for staff, at all levels of the organization, to understand the role their individual tasks have in supporting the corporate strategic direction and service delivery expectations.

Once corporate alignment has been established, the asset management policy and program allow the organization to create more detailed asset management plans and tasks. Having this clear connection

to the asset management program enables both top down (strategic) direction supported by bottom-up (evidence-based) analysis on asset performance, capacity, and service potential.

Canadian Infrastructure Report Card

The Canadian Infrastructure Report Card (CIRC) Asset Management Primer 2014, provides guidance on the recommended content for an AMP (Figure 2). It should cover:

Current State of Infrastructure

- Asset inventory and replacement value
- Summary of asset condition
- Statement about services infrastructure supports

Levels Current level of service

- Current level of service
- Organizational goals for future or changed levels of service
- Include both technical and customer levels of service

Plan Improvements

- Highlights of tasks undertaken in current AMP period
- Outline items that may impact next iteration of AMP

Asset Strategies

- Develop long term renewal plans (consideration of 50 to 100 year plans)
- Infrastructure needs to support growth and regulatory requirements
- Balance of operations and maintenance versus renewal needs

Financial Strategy

- Funds needed to support ongoing operations and maintenance activities
- Funding strategy that balances long term renewal needs with available revenue

The CIRC Report Card is being updated in fall 2019 and subject to release of the updated report, the findings will be incorporated into the next AMP.

Asset Management and Capital Program Process

The infrastructure asset management planning to capital program process is an iterative practice. At the outset it is based on assumptions and estimates that may seem overly conservative. As information is collected and the program continues to mature, the process will be refined. Efforts undertaken through the AM Program and with the AMP iterations are providing greater detail in the asset attribution that improves the utility's understanding of the asset classes.

The Asset Management and Capital Program process is an ongoing cycle. The master plan informs the long term needs, there may be additional assessments or studies needed to refine the problem, preliminary and detailed design is completed and the projects constructed, the assets are operated and maintained, and then they are monitored over time. Information resulting from the monitoring is




Figure 3 - CIRC Report Card

fed back into the process again at the master planning stage, together with a review of assumptions, growth projections, and regulatory inputs, and the cycle commences again.



Figure 4 - Typical Asset Management Planning Cycle

Through the annual capital budget process, the AMITs, or both, there is the opportunity for Engineering, Operations, and Asset Management staff to develop a more robust approach to identifying and planning for operational expenditures. Essentially, this could provide a clearly defined operational budget for each asset class. There may be additional operationally delivered programs that require a capital line in the 5 year capital budget (e.g. similar to the pump replacements or lateral replacements lines that are capitalized but delivered by Operations).

HALIFAX WATER'S ASSET MANAGEMENT PLAN

Halifax Water's Asset Management Plan 2018/19 is based on the suggested sections outlined in the CIRC Asset Management Primer and covers the following asset classes:



WATER

- Supply Plants
- Supply Dams
- Chambers & Booster Stations
- Transmission Mains
- Distribution Mains
- Service Reservoirs

WASTEWATER

- Treatment Facilities
- Pumping Stations
- Gravity Sewers
- Force mains

STORMWATER

- Management Structures
- Gravity Sewers
- Cross Culverts
- Driveway Culverts and Ditches

Figure 5 - Asset Classes for Halifax Water's AMP

State of the Infrastructure

The State of the Infrastructure section documents the current state of Halifax Water's core infrastructure under the direct ownership and control of the utility. This infrastructure enables Halifax Water to deliver water, wastewater and stormwater services to the residents of Halifax Municipality. The State of Infrastructure sections review our assets and form a picture of our asset base as a snapshot in time. The key questions answered here are what do we own, where is it, what condition is it in and what is its valuation?

Asset Inventory, Valuation and Data Improvements

Inventories are provided based on known information as well as full field data collection exercises. Asset valuation is based on a variety of sources including detailed inventories, and staff knowledge. Any data improvements for the asset class will be noted in this section.

Condition Summary

As part of the Halifax Water Asset Management Roadmap Implementation Project an Asset Condition Assessment Methodology was developed. This methodology allows Halifax Water to assign a condition grade on each asset based on known information, detailed condition assessments and/or operational experience, knowledge, and judgment. Table 1 – Condition Grade Definitions outlines the rating scale and general description used by Halifax Water.

Table 1 - Condition Grade Definitions

Grade	Description	Label
1	Acceptable condition.	Very Good
2	Minimal failure risk in short term but potential for further deterioration.	Good
3	Failure unlikely in near future but further deterioration likely.	Fair
4	Failure likely in foreseeable future.	Poor
5	Failure or failure imminent.	Very Poor

Generally, the point of optimum intervention to arrest asset deterioration and extend asset life occurs around Grade 3 or "Fair". This middle-of-the-road approach is established as a place to start given the early stage of AM implementation. As the utility gathers more information about the asset (e.g. condition, performance, complaints, operational effort, maintenance practices and frequency), staff will be in a better position to adjust the timing and types of intervention for each asset class. This will vary depending on the asset and its criticality. For example, intervention on a transmission main may start earlier in the condition life cycle to ensure a failure is avoided and service disruption does not occur. In contrast, intervention on a driveway culvert may not happen until failure as limited customers and service are impacted. The criticality of each asset class and in some cases a specific asset must be assessed to confirm the consequence of failure and the impact to Halifax Water's customers.

Levels of Service

Asset management is about maintaining a balance between the full life cycle costs of various services and the levels of service being provided. It is about knowing what levels of service customers expect and what they are willing to pay to receive that service. In other words, the level of service is a reflection of the quality, function and capacity of the services being provided.

The levels of service Halifax Water provides directly impacts many parts of asset management including both life cycle costs and risk management. As a rough generalization, the higher the level of service provided, the higher the life cycle costs of providing that service.

Levels of service drive the expected treatments in the management of infrastructure. Customer levels of service outline the overall quality, function, capacity, and safety of the service being provided. Technical levels of service outline the operating, maintenance, rehabilitation, renewal and upgrade activities expected to occur within the utility.

Developing appropriate LOS must be balanced with the availability of data as well as the ability to collect and analyze that data. It is important that the information collected supports the service areas, identifies any deficiencies, and sets goals for improvement.

ASSET MANAGEMENT PLAN – 2018/19

Continued measurement of a variety of metrics will provide valuable information for Halifax Water staff. As more information becomes available, staff can analyze it and identify possible changes to the levels of service as needed.

Asset Investment Strategies

Assets have a limited life expectancy, and their rate of deterioration can be estimated. An asset strategy is a set of actions that enable assets to provide the desired level of service in a sustainable way, while managing risk, at the lowest lifecycle cost.

Halifax Water applies a number of strategies to maintain, improve and grow its assets in a sustainable, effective manner. The asset strategy covers the development and implementation of plans and programs for asset creation, operation, maintenance, rehabilitation/replacement, disposal, and performance monitoring to ensure that the desired levels of service and other operational objectives are achieved at optimum cost.

Current Replacement and Renewal Strategy

Often total asset renewal needs exceed the available financial resources dedicated towards asset renewal. Therefore, in order to prioritize asset renewal needs across the service area, personnel from the Operations, Engineering & IS Capital, and Asset Management teams review the first cut of identified projects and programs to identify the greatest need and for consideration and prioritization as part of the annual budget.

Future Strategy Considerations

Data collected during the annual AMP process will be passed on to Operations and Engineering for use in prioritizing asset interventions. This provides a bit more formality to the current annual budget process with continuous improvement of the background information each year. Additional effort would be beneficial for improved understanding of asset intervention strategies. Figure 5 shows a typical asset deterioration curve. As an asset ages, condition continues to deteriorate. By undertaking asset interventions throughout this deterioration cycle, asset life can be extended.




Figure 6 - Typical Relationship of Asset Condition Over Time and Asset Intervention Strategies

Table 2 highlights typical activities at various stages of the lifecycle.

Table 2 - Typical Lifecycle Activities

	Phase	Lifecycle Activity	Asset Life Stage
Operating Budget	Minor Maintenance / Inspections	Activities such as inspections, monitoring, cleaning and flushing, hydrant flushing, pressure tests, visual / remote inspections, etc.	0 – 25% of asset life
	Major Maintenance	Such events as repairing water main breaks, repairing valves, replacing individual small sections of pipe, rewinding motors, etc.	25 – 50% of asset life
Capital Budget	Rehabilitation	Rehabilitation events such as structural lining, sleeves, cathodic protection programs to slow the rate of deterioration.	50 – 75% of asset life
	Replacement	Asset or component replacements.	75 – 100% of asset life

Utilities want to balance the economic value of the interventions (operating to capital) so that the assets remain in a state of good repair and are able to deliver the intended service. Earlier, more frequent, less costly interventions not only extend the asset life but enable Halifax Water to more carefully predict when major expenditures will be needed. Carrying out more frequent, less costly interventions does not eliminate the need for complete replacement however it does support a more predictable and manageable approach to asset longevity. With more predictability, major expenditures can be mitigated by ‘smoothing’ out the expenditures (e.g. breaking larger projects into phases, staggering project starts, and layering on projects by other drivers, etc.) across the planning horizon.

The AMP provide a starting point for further discussions with engineering and operations personnel. Leading AM organizations go a step further and use multi-disciplinary working groups (set up by asset class and including representatives from all departments) to review the findings and recommendations of the AMP, develop an action plan, and implement the action plan. This approach further supports embedding the asset management culture more formally throughout the organization and allows individuals to see that their actions tie back to overall corporate goals and objectives (IAM’s “line of sight” principle).



Summary of 2018/19 AMP Results

Figure 6 – AMP Statistics provides a summary of the inventory, condition, valuation, and projected 30 year spend for each of the water, wastewater, and stormwater systems. Additional detail is provided in Table 3 – Summary State of Infrastructure Observations.



Asset Management Plan 2018/19



Water Facts



Wastewater Facts



Stormwater Facts

















Figure 7 - AMP Statistics

Table 3 - Summary State of Infrastructure Observations

System	Valuation	Condition	Projected Reinvestment				Capex / Opex Projections
Water	\$2.5 B replacement value	     	<ul style="list-style-type: none"> • \$32 M annual average reinvestment needed over 30 years for water assets • Near term (2022, and 2023) large expenditures projected for Water Supply Plants • Near term (2022) – expenditure for Water Reservoirs • 2032 and 2035 – large expenditures projected for Water Transmission Mains with some moderate expenditures anticipated in 2027, 2030, 2037, and 2040 • Increasing expenditure projection for Water Distribution Mains after 2036 – indicative of age-based replacement • Very little indicated for Water Boosters & Chambers – suggests Halifax Water investigate this asset class in greater detail to confirm this is accurate 				<ul style="list-style-type: none"> • Variation in the annual projected capex budget (\$15M to \$65M) – indicates near term asset renewal needs with a slightly higher 5-year projected average capex spend than the 30-year average (\$32M) projected in the reinvestment profile; indicates Halifax Water needs to assess its capacity to deliver this larger projected program with specific focus on year 4 and 5 with a sustained level needed to deliver the average capex • Opex budget stable at the \$22M mark – indicates no surprises in the operating environment however, there may be a need to confirm the direct correlation to the increasing capex projection
		<p>Generally, the water asset classes show a positive position. In some asset classes, we are seeing larger percentages or asset value rated in Very Poor condition indicating a need for intervention or action in the near term. Higher percentages at the Poor condition indicate the need for ongoing monitoring of the asset class to plan for needed interventions.</p>					
Wastewater	\$3.2 B replacement value	   	<ul style="list-style-type: none"> • \$31.9 M annual average reinvestment needed over 30 years for wastewater assets • Near term (2024) large expenditures projected for Wastewater Pumping Stations • Near term (2019, 2020) expenditures projected for Wastewater Force mains followed by sporadic investment over the planning horizon • Several large expenditures predicted for Wastewater Treatment Facilities (2029, 2030, 2031, 2032, 2033, 2036, 2038, 2042) • Several large expenditures projected for Wastewater Pumping Stations outside of the near term (2028, 2030, 2032, 2040) • Increasing expenditure projection for Wastewater Gravity Sewers from 2029 to 2038 – indicative of age-based replacement 				<ul style="list-style-type: none"> • Variation in the annual projected capex budget (\$17M to \$34M) – indicates an increasing level of asset renewal in the near term with a slightly lower 5-year projected average capex spend than the 30-year average (\$31.9M) projected in the reinvestment profile; indicates Halifax Water can likely ramp up its capacity to deliver the projected program and will have time to determine its capacity to deliver the larger mid-horizon program with a focus on a sustained level needed to deliver the average capex thereafter • Opex budget stable at around the \$32M mark with regular anticipated inflationary increases – indicates no surprises in the operating environment however, there may be a need to confirm the direct correlation to the increasing capex projection
Stormwater	\$1.7 B replacement value	   	<ul style="list-style-type: none"> • \$8.8 M annual average reinvestment needed over 30 years for stormwater assets • First five years shows a good mix of asset reinvestments across the four asset classes followed by fairly lean reinvestment over the next five years (2024 to 2028) 				<ul style="list-style-type: none"> • The projected capex budget fluctuates over the near term varying between \$7.4 M and \$10.5 M and indicating a slightly lower 5-year capex average than the 30-year average (\$8.8M) projected in the reinvestment profile • Opex budget stable at around the \$5.5M mark with regular anticipated inflationary increases – indicates no surprises in the operating environment however, there may be a need to confirm the direct correlation to the increasing capex projection
		<p>Overall, the stormwater asset classes show an extremely positive position.</p>					

Asset Strategy Recommendations

Leading AM organizations have successfully integrated asset management practices and culture into all levels of their organization. Staff understand how the work they do on a daily basis contributes to the overall service requirements and strategic goals of the organization.

Table 4 highlights specific actions that support the integration of an asset management culture at Halifax Water. The Executive Team has a lead role in establishing the appropriate level of involvement from the various departments. Halifax Water's Executive Team role continues to:

- support asset management integration throughout the organization
- confirm roles of AM Team resources, Operations resources, Engineering resources
- guide and direct staff to incorporate enhancements to the AMP

Table 4 - Strategic Asset Management Integration

Action	Lead	Supporting Roles
Be informed and provide direction to the Asset Management Program	Executive Team	Water / WWSW Services, Asset Management, Engineering Capital, Finance, IS as needed, GIS as needed
Establish multi-disciplinary Asset Management Implementation Team (AMIT) ¹ for the asset classes ²	Executive Team	Water / WWSW Services, Engineering (Capital & Asset Management), others as appropriate
Prepare annual AMP updates	Asset Management	AMIT
Use AMP outputs to provide input into annual budget process (Operating and Capital)	AMIT	Asset Management
Provide input to Operations maintenance strategy rationalization (where, why, what, when, how)	AMIT	Others as needed
Provide input to Engineering for capital prioritization process	AMIT	Others as needed
Review existing LOS measures and identify potential changes or additions	AMIT	Executive Team
Use AMP to establish the long term capital funding needs by asset class	AMIT	Finance, Asset Management
Formally sign off on Asset Management Policy	Executive Team	Asset Management
Align with Strategic Corporate goals (HW mission, vision, critical success factors, AM Policy)	Asset Management	AMIT, Executive Team
Develop an asset management data strategy (includes storage, extents (how much detail), roles and responsibilities, maintenance and updating, frequency). Coordinate with ongoing Data Governance initiative	Asset Management	AMIT, IS, GIS
Develop methods for monitoring and reporting, analyzing findings, and acting on outcomes	Asset Management	Data management resource (Asset Management team)
Reconcile reporting periods for corporate data collection exercises (e.g. Annual Report, NWWBI, AMP) [COMPLETE]	Executive Team	AMIT, GIS

1. AMITs should be clearly named to differentiate their purpose from the corporate AM Team.

2. Where appropriate, AMITs may be established to cover multiple asset classes by the same group of AMIT participants.

FINANCING STRATEGY

Sound financial decisions and developing an effective long-term funding strategy are critical to the implementation of an asset management program. Halifax Water has a funding strategy that was developed through evaluation of alternatives using three general principles:

1. Rate stability and affordability
2. HRWC's long-term financial sustainability
3. Intergenerational equity

Halifax Water assesses funding strategies against financial performance ratios such as a target Debt Service Ratio of 35% and a Target Debt/Equity Ratio of 40%/60%. These two targets provide benchmarks for HRWC's capital financing strategy when considering future use of debt. Additionally, Halifax Water monitors affordability by considering the average residential bill as a % of median household income, and by benchmarking rates for service with other utilities.

Capital financing strategies are reviewed and updated as required to reflect changes in key assumptions such as:

1. Interest rates
2. Availability of Federal/Provincial infrastructure funding
3. Impact of the Regional Development Charge
4. Financial constraints posed by rates and affordability issues

There are natural constraints in place that restrict the use of debt, such as the ability to absorb the operating costs of new capital, annual operating budget pressures caused by increased debt service and depreciation, and rate affordability and sensitivity around increasing rates. The impact of HRWC debt on HRM debt limits and policies as well as the current Nova Scotia Municipal Finance Corporation (MFC) requirement that HRM guarantee most of HRWC's debt are also considerations in the development of an efficient capital structure. In September 2014, HRM Council approved a blanket guarantee for HRWC debt subject to HRWC maintaining a debt service ratio of 35% or less.

Asset strategy funding is often a complex process drawing from a number of funding sources. The funding of Halifax Water's programs strives to maximize the use of external funding to limit the need for politically unappealing rate increases. However, ageing infrastructure and population demographic changes will create a need to replace and expand the current asset base which requires funding.

The renewal needs are based on asset replacement at end of life. With enhanced maintenance practices or interventions prioritized on remaining service life, Halifax Water may be able to extend asset life and defer the timing for full asset reinvestment. However, this is unlikely to completely address the funding gap. There is an optimal balance between enhanced maintenance expenses and capital expenses. This will vary for each asset class but the principle of finding that optimal balance of costs and benefits applies universally. An exercise to identify all factors (e.g. condition, performance, health and safety, environmental impacts, etc.) that will influence reinvestment needs would be beneficial.

A survey carried out in 2016 for the Canadian Infrastructure Report Card (CIRC) reported current reinvestment rates from municipalities across the country. Values are shown at Figure 7 of the current reinvestment rates reported from the 2016 CIRC survey and the average of Halifax Water's 2017/18 and

2018/19 reinvestment rates from expenditures reported in the National Water and Wastewater Benchmarking Initiative (NWWBI). As the completion of capital projects varies each year affecting Halifax Water's capital investment values, it would be worth looking at reinvestment rate trends over a number of years. The CIRC survey is being updated in 2019 and results will be brought forward into the next AMP.




Figure 8 - Reinvestment Rates

Halifax Water uses a range of funding strategies to provide capital needed including incremental rate increases and gradualism, borrowing strategy and debt service ratio, and reassessment of current LOS for a given asset class. Incremental rate increases and gradualism support the need to reasonably introduce rate changes to allow the ratepayers to absorb the increases more slowly rather than be faced with “sticker shock” or drastic increases.

Halifax Water can assess its ability to borrow money responsibly within industry debt service ratio levels and without compromising borrowing needs in the future. Reviewing the historical and existing LOS may yield opportunities for LOS adjustment that would have funding implications. Adjustments to LOS must also be balanced with associated risks from these changes and would be subject to approval at the senior management level.

Halifax Water's financing needs and strategy have been thoroughly assessed in its Cost of Service Strategy, Debt Strategy, semi-annual Rate Applications, and financial model. These documents and tools

demonstrate that Halifax Water is proceeding towards the sustained level of investment needed annually.

ASSET MANAGEMENT PLAN IMPROVEMENTS

Recommendations for improvements to the corporate AM Program, AMP, and the overall framework and process are part of a continuous improvement approach and support a learning organization philosophy. That is, we work with what we know, we gather and learn more, and we incorporate that learning back into our programs.

Table 5 provides a summary of recommendations for consideration during the annual work plans and updates.

Table 5 - Asset Management Plan and Program Improvements

Corporate AM Program	AMP
<ul style="list-style-type: none">Establish and action the AMITs for all asset classes (implemented via pilot classes initially and phased in)Review and enhance methods for communicating asset status in a simple mannerEnsure data model and data governance give consideration to asset management needsEnhance data collection and analysis processes to link criticality, performance, and condition to other influencing factorsCoordinate and integrate data from condition assessment projects with other corporate initiatives (e.g. Asset Registry Index Project, Data Governance, Asset Accounting/IFRS, Cityworks)Develop an enhanced risk-based capital project prioritization method (with input from the AMITs as applicable)Develop methods to evaluate the effectiveness of the AMP and AMIT approach and feedback the results into the overall program	<ul style="list-style-type: none">Through the AMITs, review all AMP recommendations for the respective asset class, confirm priorities for the current year, and develop a workplan to enable input into the next iteration of the AMPAlign asset replacement costs with the cost estimating framework and unit cost analysis effort (bring forward asset classes requiring additional cost analysis)Work with Finance to develop approach for advising on actual capital expenditures for each asset type to allow an update from planned capital renewal expenditures (enable comparisons of planned to actual expenditures)Investigate the use of asset optimization / decision support software to provide a consistent approach to short and long term capital expenditure planningExtend Cityworks deployment throughout the organization and develop work flows to support corporate tracking of corporate initiativesLeverage Cityworks work order information to visualize activities and assess impacts on service levels or identify possible changes to operating and maintenance practices

Asset Management Plan Monitoring

The AMP is intended to drive changes to practices or behaviors that facilitate decision making and optimized use of information. Therefore, monitoring of the plans themselves is critical to evaluating the effectiveness of each AMP and AMIT. The proposed AMIT approach provides an opportunity to embed asset management principles throughout the organization and allows the team members to have line-of-sight between the work they perform daily and the larger critical success factors for the utility overall.

ASSET MANAGEMENT PLAN – 2018/19

The introduction of the AMIT pilots has shown an increase in overall understanding of asset management as a means to better understand the utility's assets and how and when interventions are needed.

As each iteration of Halifax Water's AMP is published, the level of confidence in the data and information that support it increases. Acknowledgement is made that the AMP is based on best available corporate information and that the detail and level of clarity will improve over time as better information becomes available.

Halifax Water encourages a culture of continuous improvement and celebrates innovation and the Asset Management Program must also be exposed to the rigour of continuous improvement. The progress of the program needs to be monitored to identify opportunities to change directions, adjust slightly, and to promote the positive outcomes achieved.

Initiatives to monitor the plan will include:

- Ensuring asset management statistics are updated annually
- Including past years' performance data in future versions
- Encouraging AMITs to analyze data and identify trends and potential responses
- Reviewing plan improvement opportunities as part of AMIT workplan options
- Reviewing and highlighting how the AMP is contributing to integrating asset management throughout the organization
- Identifying metrics that may drive changes in behavior, maintenance practices, or approach to asset interventions
- Accurately allocating expenditures to the appropriate driver (asset renewal, compliance and growth) to ensure the AMP reports on true asset renewal expenditures

Halifax Water can build on the experience of effective multidisciplinary work teams (e.g. previous condition assessment projects, pilot AMITs). Extending the AMITs to additional asset classes will further work to integrate and embed asset management principles throughout the organization. This supports the "line of sight" concept and staff will be able to better understand the impact their actions have on the utility as a whole and on the rate payers benefiting from the service. The outcomes of the AMP and AMITs will benefit from improved communications leveraging opportunities such as Halifax Water's intranet to inform personnel on what is happening. In terms of collected data, it must be purpose-driven and used for making decisions. Figure 8 shows the transformation of data to knowledge such that staff can use it for defendable decisions.




Figure 9 - Evolution from Data to Knowledge

Halifax Water will benefit from enhancing the way Asset Management Program outcomes are communicated and how leading AM practices permeate throughout the organization for the purpose of service to its customers.



HALIFAX WATER
2019 INTEGRATED RESOURCE PLAN

APPENDIX C
IRP CAPITAL PROGRAM

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
1	Install new twinned gravity pressure sewer (825mm and 450mm)	East	Wastewater - Trunk Sewers	\$23,372,000	2022	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	6,7,9,13,14
2	Connect Beaver Crescent PS and Caldwell PS forcemains to new 450mm gravity pressure sewer	East	Wastewater - Force mains	\$78,000	2026	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	6,7,9,13,14
3	Install four (4) new pump out stations along gravity pressure sewer	East	Wastewater - Structures	\$1,676,000	2023	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	6,7,9,13,14
4	Install gate valves at surge tank between Bissett Lake Pumping Station and gravity pressure sewer	East	Wastewater - Structures	\$420,000	2026	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	6,7,9,13,14
5	Decommission existing 450mm gravity pressure sewer	East	Wastewater - Trunk Sewers	\$559,000	2043	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	6,7,9,13,14
6	Upgrade Quigley's Corner Pumping Station	East	Wastewater - Structures	\$2,875,000	2022	Master Plan	Asset Renewal - Compliance - Growth	47.5:47.5:5	6,7,9,10,13
7	Optimize operation of Quigley's Corner Pumping Station	East	Wastewater - Structures	\$336,000	2021	Master Plan	Asset Renewal - Compliance - Growth	47.5:47.5:5	7,11,14
8	Upgrade Memorial Drive Pumping Station	East	Wastewater - Structures	\$2,633,000	2031	Master Plan	Asset Renewal - Compliance	50:50	7,9,11
9	Upgrade Beaver Crescent Pumping Station	East	Wastewater - Structures	\$168,000	2036	Master Plan	Asset Renewal - Compliance	50:50	7,9,11
10	Upgrade Bissett Lake Pumping Station	East	Wastewater - Structures	\$2,934,000	2041	Master Plan	Asset Renewal - Compliance - Growth	25:25:50	6,7,9,10,13
11	Upgrade Caldwell Road Pumping Station	East	Wastewater - Structures	\$631,000	2039	Master Plan	Asset Renewal - Growth	25:75	6,7,9,10,13
12	RDII Reduction Program (FMZ23)	East	Wastewater - Collection Sanitary	\$3,204,580	2031	Master Plan	Compliance - Growth	5:95	6,7,9,14
13	RDII Reduction Program (FMZ24)	East	Wastewater - Collection Sanitary	\$1,570,040	2022	Master Plan	Compliance - Growth	5:95	6,7,9,14
14	RDII Reduction Program (FMZ37)	East	Wastewater - Collection Sanitary	\$2,479,704	2022	Master Plan	Compliance - Growth	5:95	6,7,9,14
15	Local network upgrades on Caldwell Road	East	Wastewater - Collection Sanitary	\$607,000	2036	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	7,9,10,13
16	Local network upgrades on Colby Drive	East	Wastewater - Collection Sanitary	\$1,176,000	2031	Master Plan	Asset Renewal - Compliance	50:50	7,9,10
17	Local network upgrades on Forest Hill Parkway	East	Wastewater - Collection Sanitary	\$4,275,000	2041	Master Plan	Compliance	100	7,9,10
18	Eastern Passage SSO Management Study	East	Wastewater - Collection System	\$484,000	2023	Master Plan	Compliance	100	3,6,9
19	LoWSCA: Canal Street Separation	East	Wastewater - Collection System	\$1,842,000	2022	Master Plan	Compliance - Growth	25:75	7,8,9,13
20	LoWSCA: Wyse Road Separation (Phase 1)	East	Wastewater - Collection System	\$3,860,000	2022	Master Plan	Compliance - Growth	25:75	7,8,9,13
21	LoWSCA: Wyse Road Separation (Phase 2)	East	Wastewater - Collection System	\$2,802,000	2022	Master Plan	Compliance - Growth	75:25	7,8,9,13
22	Additional Sewer Separation on Wyse Street	East	Wastewater - Collection System	\$1,912,000	2031	Master Plan	Compliance - Growth	25:75	6,7,8,9,13
23	Albro Lake Watershed Separation	East	Wastewater - Collection System	\$8,111,000	2022	Master Plan	Compliance - Growth	5:95	6,7,8,9,13
24	Maynard Lake and Clement Street Wetland Separation (Phase 1)	East	Wastewater - Collection System	\$642,000	2025	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	6,7,8,9,13
25	Maynard Lake and Clement Street Wetland Separation (Phase 2)	East	Wastewater - Collection System	\$4,540,000	2028	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	6,7,8,9,13
26	Maynard Lake and Clement Street Wetland Separation (Phase 3)	East	Wastewater - Collection System	\$1,155,000	2028	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	6,7,8,9,13
27	Maynard Lake and Clement Street Wetland Separation (Phase 4)	East	Wastewater - Collection System	\$453,000	2028	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	6,7,8,9,13
28	New Valleyford Pumping Station	East	Wastewater - Structures	\$10,446,000	2041	Master Plan	Compliance - Growth	75:25	6,7,9,10,13
29	390 Waverley Road Force main Upgrades	East	Wastewater - Collection System	\$11,361,000	2022	Master Plan	Growth	100	6,7,9,13,14
30	Anderson Pumping Station Upgrades	East	Wastewater - Structures	\$340,000	2031	Master Plan	Asset Renewal - Compliance	50:50	6,7,9,10
31	Upgrades to Dartmouth WWTF	East	Wastewater - Treatment Facilities	\$12,572,000	2041	Master Plan	Growth	100	4,7,9,10,13
32	RDII Reduction Program (FMZ27)	East	Wastewater - Collection Sanitary	\$5,941,076	2022	Master Plan	Compliance - Growth	25:75	6,7,9,14

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
33	RDII Reduction Program (FMZ45)	East	Wastewater - Collection Sanitary	\$1,120,232	2031	Master Plan	Compliance - Growth	5:95	6,7,9,14
34	Additional flow monitoring	East	Wastewater - Collection Sanitary	\$252,000	2021	Master Plan	Compliance - Growth	90:10	3,9
35	Dartmouth CSO Flow Management Plan	East	Wastewater - Collection System	\$675,000	2036	Master Plan	Compliance - Growth	90:10	3,6,9
36	Green St. Sewer Upsize	East	Wastewater - Collection Sanitary	\$513,000	2041	Master Plan	Asset Renewal - Compliance	50:50	7,9,10
37	Pinecrest Dr. Sewer Upgrade	East	Wastewater - Collection Sanitary	\$1,013,000	2034	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	7,9,10,13
38	Peddars Way Sewer Upgrade	East	Wastewater - Collection Sanitary	\$555,000	2031	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	7,9,10,13
39	Atlantic Street Sewer Upgrade	East	Wastewater - Collection Sanitary	\$3,831,000	2026	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	7,9,10,13
40	Akerley Blvd and Railway Alignment Sewer Upgrade	East	Wastewater - Collection Sanitary	\$4,814,000	2041	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	7,9,10,13
41	Pleasant Street Sewer Upgrade	East	Wastewater - Collection Sanitary	\$767,000	2021	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	7,9,10,13
42	Princess Margaret Blvd. Sewer Upgrade	East	Wastewater - Collection Sanitary	\$3,106,000	2031	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	7,9,10,13
43	Anderson Lake Development Connection	East	Wastewater - Collection Sanitary	\$7,609,000	2036	Master Plan	Growth	100	9,13
44	Marvin Street Connection to Cuisack CSO	East	Wastewater - Collection Sanitary	\$1,380,000	2026	Master Plan	Compliance - Growth	47.5:47.5:5	6,7,9,14
45	King Street Diversion	East	Wastewater - Collection Sanitary	\$78,000	2026	Master Plan	Compliance - Growth	47.5:47.5:5	6,7,9,14
46	Diversion to Eastern Passage	East	Wastewater - Collection Sanitary	\$12,113,000	2041	Master Plan	Growth	100	6,9,13,14
47	Dartmouth SSO Flow Management Plan	East	Wastewater - Collection Sanitary	\$555,000	2023	Master Plan	Compliance	100	3,6,9
48	Sackville Trunk Sewer Upgrades (1200mm diameter)	Central	Wastewater - Trunk Sewers	\$5,101,000	2041	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	7,9,10,13
49	Sackville Trunk Sewer Upgrades (1050mm diameter)	Central	Wastewater - Trunk Sewers	\$8,246,000	2041	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	7,9,10,13
50	Sackville Trunk Sewer Upgrades (1500mm diameter)	Central	Wastewater - Trunk Sewers	\$144,000	2041	Master Plan	Asset Renewal - Compliance - Growth	25:25:50	7,9,10,13
51	New 5ML storage tank in Lower Sackville (GoodLife Fitness Sackville Downsview Plaza)	Central	Wastewater - Structures	\$17,469,000	2031	Master Plan	Compliance - Growth	5:95	9,10,13,14
52	Fish Hatchery Park Pumping Station Upgrade	Central	Wastewater - Structures	\$10,529,000	2036	Master Plan	Asset Renewal - Compliance - Growth	25:25:50	6,9,10,13
53	Pumping Station (Beaver Bank #3 PS and Majestic Avenue PS)	Central	Wastewater - Structures	\$1,090,000	2036	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	6,9,10,13
54	Mill Cove Wastewater Treatment Plant Capacity Upgrade	Central	Wastewater - Treatment Facilities	\$89,256,000	2022	Master Plan	Asset Renewal - Compliance - Growth	25:25:50	1,4,6,9,10,13
55	RDII Reduction Program (FMZ07, FMZ10, & FMZ40)	Central	Wastewater - Collection Sanitary	\$9,288,248	2022	Master Plan	Compliance - Growth	5:95	6,7,9,14
56	RDII Reduction Program (FMZ02 & FMZ03)	Central	Wastewater - Collection Sanitary	\$8,023,065	2031	Master Plan	Compliance - Growth	5:95	6,7,9,14
57	Local network upgrades on Beaver Bank Rd. North on Glendale Dr.	Central	Wastewater - Collection Sanitary	\$2,086,000	2022	Master Plan	Compliance - Growth	75:25	7,9,10
58	Local network upgrades on Beaver Bank Rd. at Galloway Dr.	Central	Wastewater - Collection Sanitary	\$1,490,000	2022	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	7,9,10,13
59	Local network upgrades on Beaver Bank Rd by Windgate Drive	Central	Wastewater - Collection Sanitary	\$1,667,000	2022	Master Plan	Asset Renewal - Compliance - Growth	37.5:37.5:25	7,9,10
60	Local network upgrades on Old Sackville Road south of Harvest Hwy	Central	Wastewater - Collection Sanitary	\$845,000	2036	Master Plan	Asset Renewal - Compliance	50:50	1,7,9,10
61	Local network upgrades on Hallmark Ave.	Central	Wastewater - Collection Sanitary	\$437,000	2036	Master Plan	Asset Renewal - Compliance	50:50	7,9,10
62	Local sewer upgrades on Waterfront Drive	Central	Wastewater - Collection Sanitary	\$500,000	2036	Master Plan	Asset Renewal - Compliance	50:50	7,9,10
63	Springfield Lake Connection to Sackville	Central	Wastewater - Collection Sanitary	\$6,226,000	2043	Master Plan	Compliance - Growth	50:50	1,7,9,13
64	Central Region SSO Management Study	Central	Wastewater - Collection Sanitary	\$1,086,000	2024	Master Plan	Compliance	100	3,6,9

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
65	WRWIP: Spring Garden Area Sewer Separation	West	Wastewater - Collection System	\$7,281,000	2021	Master Plan	Compliance - Growth	50:50	7,8,9,13
66	WRWIP: Young Street Area Sewer Separation	West	Wastewater - Collection System	\$21,879,000	2022	Master Plan	Compliance - Growth	25:75	7,8,9,13
67	WRWIP: Sewer Separation Upstream of Kempt CSO	West	Wastewater - Collection System	\$14,752,000	2021	Master Plan	Compliance - Growth	5:95	7,8,9,13
68	WRWIP: Linear Upsize - Gottingen & Cogswell Area	West	Wastewater - Collection System	\$221,000	2019	Master Plan	Compliance - Growth	5:95	7,9,10,13
69	WRWIP: Young Pumping Station Upgrade	West	Wastewater - Structures	\$2,169,000	2027	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	6,7,9,10,13
70	WRWIP: New Fairfield Holding Tank	West	Wastewater - Structures	\$12,403,000	2046	Master Plan	Asset Renewal - Compliance - Growth	25:25:50	6,7,9,13
71	WRWIP: Replace Armdale Pumping Station Force mains	West	Wastewater - Force mains	\$3,850,000	2022	Master Plan	Asset Renewal - Growth	50:50	3,7,9,10,13
72	WRWIP: BLT WWTF Decommission - New Timberlea PS	West	Wastewater - Structures	\$5,928,000	2022	Master Plan	Compliance - Growth	5:95	1,9,13
73	WRWIP: BLT WWTF Decommission - New Timberlea Force main	West	Wastewater - Force mains	\$19,436,000	2022	Master Plan	Compliance - Growth	5:95	1,9,13
74	WRWIP: BLT WWTF Decommission	West	Wastewater - Treatment Facilities	\$500,000	2020	Master Plan	Compliance - Growth	5:95	1,9,13
75	WRWIP: RDII Reduction Program in Fairview, Clayton Park, and Bridgeview areas	West	Wastewater - Collection Sanitary	\$15,491,589	2021	Master Plan	Compliance - Growth	5:95	6,7,9,14
76	WRWIP: BLT Flow Diversion to Herring Cove - New Crown Drive Pumping Station	West	Wastewater - Structures	\$8,063,000	2033	Master Plan	Compliance - Growth	5:95	1,11,13
77	WRWIP: BLT Flow Diversion to Herring Cove - New Crown Drive Force main	West	Wastewater - Force mains	\$9,026,000	2033	Master Plan	Compliance - Growth	5:95	1,11,13
78	WRWIP: BLT Flow Diversion to Herring Cove - New Gravity Sewer	West	Wastewater - Collection Sanitary	\$4,319,000	2033	Master Plan	Compliance - Growth	5:95	1,10,13
79	WRWIP: BLT Flow Diversion to Herring Cove - New Gravity Sewer	West	Wastewater - Collection Sanitary	\$3,266,000	2033	Master Plan	Compliance - Growth	5:95	1,10,13
80	WRWIP: Herring Cove Road - Gravity Sewer Upsize	West	Wastewater - Collection Sanitary	\$7,439,000	2033	Master Plan	Compliance - Growth	5:95	1,7,9,10,13
81	WRWIP: Fairview Cove Linear Upsize	West	Wastewater - Collection Sanitary	\$19,781,000	2021	Master Plan	Asset Renewal - Compliance - Growth	12.5:12.5:75	6,7,9,10,13
82	WRWIP: Halifax Treatment Plant Capacity Upgrade	West	Wastewater - Treatment Facilities	\$25,142,000	2041	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	1,10,13
83	WRWIP: Linear Upgrades within the Kearney Lake Road Area	West	Wastewater - Collection Sanitary	\$2,997,000	2033	Master Plan	Asset Renewal - Compliance - Growth	2.5:2.5:95	7,9,10,13
84	Infrastructure Master Plan: West Region CSO Management Study	West	Wastewater - Collection Sanitary	\$965,000	2026	Master Plan	Compliance - Growth	90:10	3,6,9
85	Infrastructure Master Plan: West Region SSO Management Study	West	Wastewater - Collection Sanitary	\$415,000	2023	Master Plan	Compliance	100	3,6,9
86	Chain Control Transmission - Existing Peninsula Low Upsize	West	Water - Transmission	\$3,841,000	2022	Master Plan	Asset Renewal - Growth	25:75	10,13
87	Chain Control Transmission - Existing Peninsula Intermediate Upsize	West	Water - Transmission	\$2,650,000	2022	Master Plan	Asset Renewal - Growth	25:75	1,10,13
88	Pepperell Transmission Upsize	West	Water - Distribution	\$2,702,000	2036	Master Plan	Asset Renewal - Growth	25:75	10,13
89	Chain Control Transmission - Existing Peninsula Low Lining	West	Water - Transmission	\$2,916,000	2036	Master Plan	Asset Renewal - Growth	25:75	10,13
90	Chain Control Transmission - Valve Chambers	West	Water - Structures	\$1,258,000	2036	Master Plan	Asset Renewal - Growth	25:75	10,13
91	Replace High Risk Peninsula Transmission (Robie)	West	Water - Transmission	\$17,312,000	2026	Master Plan	Asset Renewal	100	11
92	Peninsula Intermediate Looping - Quinpool Rd to Young St	West	Water - Distribution	\$4,319,000	2022	Master Plan	Asset Renewal - Growth	25:75	10,13
93	Young St. Watermain Upsize	West	Water - Distribution	\$1,315,000	2026	Master Plan	Asset Renewal - Growth	25:75	10,13
94	Robie St. Watermain Upsize	West	Water - Distribution	\$956,000	2026	Master Plan	Asset Renewal - Growth	25:75	10,13
95	Almon St. Watermain Upsize	West	Water - Distribution	\$1,168,000	2026	Master Plan	Asset Renewal - Growth	25:75	10,13
96	Windsor St. Watermain Upsize	West	Water - Distribution	\$1,004,000	2026	Master Plan	Asset Renewal - Growth	25:75	10,13

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
97	Geizer 158 to Lakeside High Watermain Looping	West	Water - Distribution	\$2,249,000	2028	Master Plan	Asset Renewal	100	11
98	Gravity Supply to Brunello	West	Water - Distribution	\$2,328,000	2041	Master Plan	Asset Renewal	100	10,12
99	Dominion Cres. Watermain Upsize	West	Water - Distribution	\$447,000	2041	Master Plan	Asset Renewal	100	10
100	Brunello Booster Pump Upgrades	West	Water - Structures	\$236,000	2021	Master Plan	Asset Renewal	100	10
101	Geizer 158 Looping - Lacewood Dr	West	Water - Distribution	\$2,002,000	2041	Master Plan	Asset Renewal	100	10
102	Geizer Hill Booster Pump Upgrades	West	Water - Structures	\$277,000	2021	Master Plan	Asset Renewal	100	10
103	Leiblin Booster Fire Pump	West	Water - Structures	\$395,000	2019	Master Plan	Asset Renewal	100	10
104	Herring Cove Rd. Watermain Twinning	West	Water - Distribution	\$3,585,000	2022	Master Plan	Asset Renewal	100	11
105	St. Michaels Ave. Watermain Upsize	West	Water - Distribution	\$502,000	2041	Master Plan	Asset Renewal	100	11
106	Herring Cove Rd. Watermain Looping - McIntosh St	West	Water - Distribution	\$2,272,000	2022	Master Plan	Asset Renewal	100	11
107	Lucasville Rd. Twinning (Phase 1)	Central	Water - Distribution	\$8,117,000	2019	Master Plan	Growth	100	13
108	Lucasville Rd. Twinning (Phase 2)	Central	Water - Distribution	\$8,956,000	2026	Master Plan	Growth	100	13
109	New Primary Feed to Sackville High	Central	Water - Distribution	\$4,953,000	2026	Master Plan	Growth	100	13
110	New Sackville Beaver Bank Valve Chamber	Central	Water - Structures	\$839,000	2026	Master Plan	Growth	100	13
111	Reconfiguration of Beaver Bank Booster	Central	Water - Structures	\$100,000	2041	Master Plan	Asset Renewal	100	10,12
112	New Sackville High PRV	Central	Water - Structures	\$420,000	2036	Master Plan	Growth	100	13
113	Cobequid High Looping	Central	Water - Distribution	\$2,233,000	2026	Master Plan	Asset Renewal - Growth	25:75	11,13
114	Windgate Dr. Watermain Upsize	Central	Water - Distribution	\$882,000	2026	Master Plan	Asset Renewal - Growth	25:75	11,13
115	Lively Booster Pump Upgrades	Central	Water - Structures	\$38,000	2036	Master Plan	Asset Renewal	100	10
116	New Hemlock Elevated Tank	West	Water - Structures	\$6,209,000	2022	Master Plan	Asset Renewal - Growth	59:41	10,13
117	Pockwock Transmission Loop through Bedford	Central	Water - Distribution	\$5,069,000	2025	Master Plan	Asset Renewal	100	11
118	Second Geizer 158 Feed	West	Water - Distribution	\$9,612,000	2041	Master Plan	Asset Renewal	100	11
119	New Main Street to Caledonia Road Connection	East	Water - Distribution	\$3,072,000	2022	Master Plan	Asset Renewal	100	11
120	Caledonia Rd. Watermain Twinning	East	Water - Distribution	\$3,429,000	2022	Master Plan	Asset Renewal	100	11
121	New Breeze Dr. Watermain	East	Water - Distribution	\$5,801,000	2022	Master Plan	Asset Renewal	100	11
122	Highway 118 Crossing - Shubie Park to Dartmouth Crossing	East	Water - Distribution	\$6,063,000	2025	Master Plan	Asset Renewal	100	11
123	Windmill Rd. Watermain Upsize	East	Water - Distribution	\$6,104,000	2030	Master Plan	Asset Renewal - Growth	25:75	10,13
124	New Woodside Industrial Park Feed	East	Water - Distribution	\$1,649,000	2025	Master Plan	Asset Renewal	100	10
125	Willowdale to Eastern Passage Connection	East	Water - Distribution	\$6,290,000	2036	Master Plan	Asset Renewal	100	11
126	Tacoma PRV Chamber	East	Water - Structures	\$420,000	2020	Master Plan	Asset Renewal	100	10
127	Pockwock Transmission Twinning - 60in	West	Water - Transmission	\$65,516,000	2031	Master Plan	Asset Renewal - Growth	63:37	11
128	Pockwock Transmission Twinning - 54in	West	Water - Transmission	\$16,228,000	2036	Master Plan	Asset Renewal - Growth	63:37	11

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
129	Extension to Springfield Lake	Central	Water - Distribution	\$3,043,000	2043	Master Plan	Asset Renewal	100	7,10,13
130	Bedford-Burnside System Interconnection (Phase 1)	All	Water - Distribution	\$24,499,000	2036	Master Plan	Asset Renewal - Growth	53:47	9,11,13
131	Bedford-Burnside System Interconnection (Phase 2)	All	Water - Distribution	\$11,779,000	2036	Master Plan	Asset Renewal - Growth	53:47	9,11,13
132	Lyle Emergency Booster Upgrade	East	Water - Structures	\$1,045,000	2026	Master Plan	Asset Renewal - Growth	53:47	11
133	Valving for Central Intermediate Boundary Change	East	Water - Structures	\$629,000	2026	Master Plan	Asset Renewal - Growth	53:47	11
134	Extension of Fall River to Bennery Lake (Phase 1)	East	Water - Distribution	\$8,067,000	2026	Master Plan	Asset Renewal - Growth	26:74	9,11,13
135	Extension of Fall River to Bennery Lake (Phase 2)	East	Water - Distribution	\$9,156,000	2026	Master Plan	Asset Renewal - Growth	26:74	9,11,13
136	Extension of Fall River to Bennery Lake (PS)	East	Water - Structures	\$1,310,000	2026	Master Plan	Asset Renewal - Growth	26:74	9,11,13
137	Decommission Miller Lake WTP - Linear	East	Water - Distribution	\$628,000	2019	Master Plan	Asset Renewal	100	10,12
138	Decommission Miller Lake WTP	East	Water - Treatment Facilities	\$61,000	2019	Master Plan	Asset Renewal	100	10,12
139	Decommission Collins Park WTP - Linear	East	Water - Distribution	\$1,086,000	2041	Master Plan	Asset Renewal	100	10,12
140	Decommission Collins Park WTP	East	Water - Treatment Facilities	\$168,000	2041	Master Plan	Asset Renewal	100	10,12
141	Decommission Silversands WTP - Linear	East	Water - Distribution	\$1,931,000	2041	Master Plan	Asset Renewal	100	10,12
142	Decommission Silversands WTP	East	Water - Treatment Facilities	\$168,000	2041	Master Plan	Asset Renewal	100	10,12
143	Chain Lake Backup Supply Study	West	Water - Transmission	\$50,000	2020	Master Plan	Asset Renewal - Growth	50:50	2,5,11,13
144	Mt. Edward Booster Fire Pump Study	East	Water - Structures	\$50,000	2019	Master Plan	Asset Renewal - Growth	50:50	10,13
145	New Orchard Control Chamber Study	West	Water - Structures	\$50,000	2021	Master Plan	Asset Renewal - Growth	50:50	10,13
146	Robie Emergency Booster Study	West	Water - Structures	\$50,000	2041	Master Plan	Asset Renewal - Growth	50:50	10,13
147	Safe Yield Study	All	Water - Treatment Facilities	\$100,000	2020	Master Plan	Compliance - Growth	50:50	2,5,13
148	New Hydraulic Water Model (InfoWater)	All	Water - Corporate Projects	\$200,000	2020	Master Plan	Asset Renewal - Growth	50:50	9,10,12,13
149	Comprehensive PRV Study	All	Water - Structures	\$50,000	2019	Master Plan	Asset Renewal - Growth	50:50	10,12,13
150	Transmission Main Risk Assessment and Prioritization Framework	All	Water - Transmission	\$50,000	2020	Master Plan	Asset Renewal - Growth	50:50	10,13
151	Tomahawk Lake Supply Study	Central	Water - Treatment Facilities	\$50,000	2036	Master Plan	Compliance - Growth	50:50	2,5,7,9,13
152	Aerotech Storage	Central	Water - Structures	\$4,752,000	2022	Master Plan	Asset Renewal - Growth	20:80	2,10,13
153	Water Supply Plants (A1) - Asset Renewal	All	Water - Treatment Facilities	\$230,428,000	2019-2048	AMPs	Asset Renewal	100	2,10
154	Water Supply Dams (A2) - Asset Renewal	All	Water - Structures	\$8,345,000	2019-2048	AMPs	Asset Renewal	100	2,10
155	Water Chambers and Booster Stations (A3) - Asset Renewal	All	Water - Structures	\$25,164,682	2019-2048	AMPs	Asset Renewal	100	10
156	Water Transmission Mains (A4) - Asset Renewal	All	Water - Transmission	\$269,144,527	2019-2048	AMPs	Asset Renewal	100	10
157	Water Distribution Mains (A5) - Asset Renewal	All	Water - Distribution	\$301,734,210	2019-2048	AMPs	Asset Renewal	100	10
158	Water Reservoirs (A6) - Asset Renewal	All	Water - Structures	\$32,249,015	2019-2048	AMPs	Asset Renewal	100	10,11
159	Wastewater Treatment Facilities (B1) - Asset Renewal	All	Wastewater - Treatment Facilities	\$373,129,278	2019-2048	AMPs	Asset Renewal	100	10
160	Wastewater Pumping Stations (B2) - Asset Renewal	All	Wastewater - Structures	\$337,852,112	2019-2048	AMPs	Asset Renewal	100	10

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
161	Wastewater Gravity Sewers (B3) - Asset Renewal	All	Wastewater - Collection System	\$248,764,304	2019-2048	AMPs	Asset Renewal	100	10
162	Forcemains (B4) - Asset Renewal	All	Wastewater - Force mains	\$48,139,079	2019-2048	AMPs	Asset Renewal	100	10
163	Stormwater Management Structures (C1) - Asset Renewal	All	Stormwater - Structures	\$10,538,402	2019-2048	AMPs	Asset Renewal	100	10
164	Stormwater Gravity Sewers (C2) - Asset Renewal	All	Stormwater - Pipes	\$162,116,838	2019-2048	AMPs	Asset Renewal	100	7,10
165	Stormwater Cross Culverts (C3) - Asset Renewal	All	Stormwater - Culverts/Ditches	\$65,229,942	2019-2048	AMPs	Asset Renewal	100	7,10
166	Driveway Culvert (C4) - Asset Renewal	All	Stormwater - Culverts/Ditches	\$25,500,000	2019-2048	AMPs	Asset Renewal	100	7,10
167	JD Kline WSP - Process Upgrades - PH 1	West	Water - Treatment Facilities	\$32,660,000	2020-2025	Compliance Plan	Compliance	100	2
168	JD Kline WSP - Process Upgrades - PH 2	West	Water - Treatment Facilities	\$25,440,000	2025-2028	Compliance Plan	Compliance	100	2
169	Lake Major WSP - Process Upgrades - PH 1	East	Water - Treatment Facilities	\$31,163,000	2020-2024	Compliance Plan	Compliance	100	2
170	Lake Major WSP - Process Upgrades - PH 2	East	Water - Treatment Facilities	\$16,960,000	2027-2030	Compliance Plan	Compliance	100	2
171	Halifax WWTF - Preliminary Treatment	West	Wastewater - Treatment Facilities	\$1,950,000	2022	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
172	Halifax WWTF - Coagulant Dosing System	West	Wastewater - Treatment Facilities	\$135,000	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
173	Halifax WWTF - Polymer Dosing System	West	Wastewater - Treatment Facilities	\$39,500	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
174	Halifax WWTF - Hydraulic Balancing Improvements	West	Wastewater - Treatment Facilities	\$395,000	2019	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
175	Halifax WWTF - Disinfection Upgrades	West	Wastewater - Treatment Facilities	\$850,000	2023	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
176	Halifax WWTF - UV System Level Controls	West	Wastewater - Treatment Facilities	\$385,000	2023	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
177	Halifax WWTF - Solids Handling	West	Wastewater - Treatment Facilities	\$935,000	2021	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
178	Halifax WWTF - Odour Control - Activated Carbon Reactors	West	Wastewater - Treatment Facilities	\$275,000	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
179	Halifax WWTF - Ballasted Flocculation Upgrades	West	Wastewater - Treatment Facilities	\$4,070,000	2029	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
180	Halifax WWTF - Upgrade to secondary treatment / optimize advance primary treatment	West	Wastewater - Treatment Facilities	\$160,750,000	2040	Compliance Plan	Compliance	100	1,4
181	Dartmouth WWTF - Preliminary Treatment	East	Wastewater - Treatment Facilities	\$1,785,000	2022	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
182	Dartmouth WWTF - Coagulant Dosing System	East	Wastewater - Treatment Facilities	\$120,000	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
183	Dartmouth WWTF - Polymer Dosing System	East	Wastewater - Treatment Facilities	\$25,000	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
184	Dartmouth WWTF - Hydraulic Balancing Improvements	East	Wastewater - Treatment Facilities	\$335,000	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
185	Dartmouth WWTF - Disinfection Upgrades	East	Wastewater - Treatment Facilities	\$775,000	2021	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
186	Dartmouth WWTF - UV System Level Controls	East	Wastewater - Treatment Facilities	\$325,000	2023	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
187	Dartmouth WWTF - Solids Handling	East	Wastewater - Treatment Facilities	\$735,000	2023	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
188	Dartmouth WWTF - Ballasted Flocculation Upgrades	East	Wastewater - Treatment Facilities	\$3,800,000	2029	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
189	Dartmouth WWTF - Upgrade to secondary treatment / optimize advance primary treatment	East	Wastewater - Treatment Facilities	\$87,400,000	2038	Compliance Plan	Compliance	100	1,4
190	Herring Cove - Preliminary Treatment	West	Wastewater - Treatment Facilities	\$1,020,000	2022	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
191	Herring Cove - UV System Level Controls	West	Wastewater - Treatment Facilities	\$300,000	2023	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
192	Herring Cove - Odour Control - Activated Carbon Reactors	West	Wastewater - Treatment Facilities	\$165,000	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
193	Herring Cove - Ballasted Flocculation Upgrades	West	Wastewater - Treatment Facilities	\$3,265,000	2025	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
194	Herring Cove - Upgrade to secondary treatment / optimize advance primary treatment	West	Wastewater - Treatment Facilities	\$38,200,000	2039	Compliance Plan	Compliance	100	1,4
195	Lakeside-Timberlea WWTF - Improve Plant Hydraulics	West	Wastewater - Treatment Facilities	\$25,000	2020	Compliance Plan	Asset Renewal - Compliance	50:50	1,10
196	Wet Weather Management Program	All	Wastewater - Corporate Projects	\$7,250,000	2020-2048	Compliance Plan	Asset Renewal - Compliance - Growth	33:33:33	3,6,9,10,14
197	Armdale CSO Screening	West	Wastewater - Collection System	\$3,000,000	2025	Compliance Plan	Compliance	100	6,7
198	Quinpool Road CSO Screening	East	Wastewater - Collection System	\$3,000,000	2025	Compliance Plan	Compliance	100	6,7
199	Coburg Road CSO Screening	West	Wastewater - Collection System	\$3,000,000	2025	Compliance Plan	Compliance	100	6,7
200	South Street CSO Screening	West	Wastewater - Collection System	\$3,000,000	2025	Compliance Plan	Compliance	100	6,7
201	Beaufort CSO Screening	West	Wastewater - Collection System	\$3,000,000	2025	Compliance Plan	Compliance	100	6,7
202	Automated Flushing Program	All	Water - Distribution	\$580,000	2020-2048	Compliance Plan	Compliance	100	3
203	Corporate Flow Monitoring Program	All	Wastewater - Corporate Projects	\$51,060,000	2019-2048	Compliance Plan	Compliance - Growth	50:50	3,6,13
204	I&I Reduction (SIR) Program Flow Meters and Related Equipment	All	Wastewater - Equipment	\$750,000	2019-2048	Compliance Plan	Compliance	100	3,6,14
205	Watershed Land Acquisition	All	Water - Land	\$3,000,000	2019-2048	Compliance Plan	Compliance	100	5
206	Future Overflow Compliance Program (Enhanced Overflow Program - 10 overflows per year at B&C receiving waters)	All	Wastewater - Collection System	\$198,889,474	2042	Compliance Plan	Compliance	100	6,9
207	Bio-Solids Facility Upgrades	All	Wastewater - Treatment Facilities	\$10,000,000	2023	Compliance Plan	Compliance	100	1,4
208	Regional Development Charge Studies W	All	Water - Corporate Projects	\$425,000	2019,+5...,2048	Corporate Projects	Growth	100	13,14
209	Regional Development Charge Studies WW	All	Wastewater - Corporate Projects	\$425,000	2019,+5...,2048	Corporate Projects	Growth	100	13,14
210	Water System Master Plan Update	All	Water - Corporate Projects	\$4,500,000	2023,+5...,2048	Corporate Projects	Growth	100	7,8,10,13,14
211	Wastewater System Master Plan Update	All	Wastewater - Corporate Projects	\$4,500,000	2023,+5...,2048	Corporate Projects	Growth	100	7,8,10,13,14
212	IT Projects - Water	All	Water - Corporate Projects	\$102,767,500	2019-2048	Corporate Projects	Asset Renewal	100	10
213	IT Projects - Wastewater	All	Wastewater - Corporate Projects	\$82,214,000	2019-2048	Corporate Projects	Asset Renewal	100	10
214	IT Projects - Stormwater	All	Stormwater - Corporate Projects	\$20,778,500	2019-2048	Corporate Projects	Asset Renewal	100	10
215	GIS Projects - Water	All	Water - Corporate Projects	\$10,050,000	2019-2048	Corporate Projects	Asset Renewal	100	10,11
216	GIS Projects - Wastewater	All	Wastewater - Corporate Projects	\$8,215,000	2019-2048	Corporate Projects	Asset Renewal	100	10,11
217	GIS Projects - Stormwater	All	Stormwater - Corporate Projects	\$2,385,000	2019-2048	Corporate Projects	Asset Renewal	100	10,11
218	Asset Management Projects - Water	All	Water - Corporate Projects	\$3,275,000	2019-2048	Corporate Projects	Asset Renewal	100	10,11
219	Asset Management Projects - Wastewater	All	Wastewater - Corporate Projects	\$9,552,500	2019-2048	Corporate Projects	Asset Renewal	100	10,11
220	Asset Management Projects - Stormwater	All	Stormwater - Corporate Projects	\$5,382,500	2019-2048	Corporate Projects	Asset Renewal	100	10,11
221	Facility Projects - Water	All	Water - Corporate Projects	\$20,750,000	2019-2048	Corporate Projects	Asset Renewal	100	10
222	Facility Projects - Wastewater	All	Wastewater - Corporate Projects	\$16,600,000	2019-2048	Corporate Projects	Asset Renewal	100	10
223	Facility Projects - Stormwater	All	Stormwater - Corporate Projects	\$4,150,000	2019-2048	Corporate Projects	Asset Renewal	100	10
224	SCADA & Other Equipment - Water	All	Water - Corporate Projects	\$10,283,500	2019-2048	Corporate Projects	Asset Renewal	100	10

2019 IRP - Long-Term Capital Plan

No.	Project Name	Region	Asset Group	Total Cost (\$2019)	Year in Service	Source of Program/Project	Driver	Driver Allocation (%)	Objectives
225	SCADA & Other Equipment - Wastewater	All	Wastewater - Corporate Projects	\$10,016,800	2019-2048	Corporate Projects	Asset Renewal	100	10
226	SCADA & Other Equipment - Stormwater	All	Stormwater - Corporate Projects	\$79,200	2019-2048	Corporate Projects	Asset Renewal	100	10
227	Fleet Upgrade Program - Water	All	Water - Corporate Projects	\$14,091,000	2019-2048	Corporate Projects	Asset Renewal - Growth	50:50	10
228	Fleet Upgrade Program - Wastewater	All	Wastewater - Corporate Projects	\$30,972,000	2019-2048	Corporate Projects	Asset Renewal - Growth	50:50	10
229	Fleet Upgrade Program - Stormwater	All	Stormwater - Corporate Projects	\$8,993,000	2019-2023	Corporate Projects	Asset Renewal - Growth	50:50	10
230	Integrated Resource Plan W	All	Water - Corporate Projects	\$1,250,000	2024,+5...,2048	Corporate Projects	Asset Renewal - Compliance - Growth	33:33:33	2,5,7,9,10,11,12,13,14
231	Integrated Resource Plan WW	All	Wastewater - Corporate Projects	\$1,000,000	2024,+5...,2048	Corporate Projects	Asset Renewal - Compliance - Growth	33:33:33	1,3,4,6,7,9,10,11,12,13,14
232	Integrated Resource Plan SW	All	Stormwater - Corporate Projects	\$250,000	2024,+5...,2048	Corporate Projects	Asset Renewal - Compliance - Growth	33:33:33	7,8,9,10,11,13,14
233	Climate Change Adaptation - Water	All	Water - Corporate Projects	\$250,000	2020-2026	Corporate Projects	Asset Renewal - Compliance	20:80	9,12
234	Climate Change Adaptation - Wastewater	All	Wastewater - Corporate Projects	\$240,000	2020-2026	Corporate Projects	Asset Renewal - Compliance	20:80	9,12
235	Climate Change Adaptation - Stormwater	All	Stormwater - Corporate Projects	\$210,000	2020-2026	Corporate Projects	Asset Renewal - Compliance	20:80	9,12
236	Energy Management Capital Program (Water)	All	Water - Energy	\$1,200,000	2021-2023	Corporate Projects	Asset Renewal	100	9,12
237	Energy Management Capital Program (Wastewater)	All	Wastewater - Energy	\$14,500,000	2020-2048	Corporate Projects	Asset Renewal	100	9,12
238	Lead Service Line Replacement Program	All	Water - Distribution	\$30,000,000	2019-2048	Corporate Projects	Asset Renewal	100	5,10
239	CCC Various - Water	All	Water - Distribution	\$555,000	2019-2023	Corporate Projects	Growth	100	13
240	CCC Various - Wastewater	All	Wastewater - Collection System	\$7,305,000	2019-2020, 2022-2023	Corporate Projects	Growth	100	13
Total Cost (\$2019)				\$4,053,662,397					